




ARKANSAS POWER & LIGHT COMPANY
 POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

October 19, 1982




2CAN108208

Mr. W. C. Seidle, Chief
 Reactor Project Branch #2
 U. S. Nuclear Regulatory Commission
 Region IV
 611 Ryan Plaza Drive, Suite 1000
 Arlington, Texas 76011

Subject: Arkansas Nuclear One - Unit 2
 Docket No. 368
 License No. NPF-6
 Licensee Event Report
 No. 82-032/03L-0
 (File: 2-0520)

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 2 Technical Specification 6.9.1.9.b, attached is the subject report concerning a pressurizer relief valve (2PSV-4634) which was found to be set above the Technical Specification limit.

Very truly yours

 John R. Marshall
 Manager, Licensing

JRM:GAC:s1

2x

Attachment

cc: Mr. Richard C. DeYoung
 Office of Inspection and Enforcement
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

Mr. Norman M. Haller, Director
 Office of Management & Program Analysis
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

8211020266 821019
 PDR ADOCK 05000368
 S PDR

IE 22