

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

October 25, 1982
QA-2072

E. A. BORGMANN
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT I
10CFR50.55(e) ITEM S-5 INADEQUATE COATINGS
DOCKET NO. 50-358, CONSTRUCTION PERMIT NO.
CPPR-88, W. O. #57300, JOB E-5590, FILE
NO. NRC-9, S-5

Gentlemen:

This letter constitutes an interim report concerning the subject condition initially reported to the Commission on September 28, 1982, as a potentially reportable deficiency under 10CFR50.55(e).

A documentation review of Level I coatings work has revealed discrepancies between inspection records and specification requirements which may render the quality of coatings indeterminate. CG&E has issued Stop Work Order #82-03 to assess the effectiveness of the quality assurance program for ongoing coating work. Previously accepted work is under evaluation and a definitive report will be available by February 15, 1983.

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By

E. A. BORGMANN
SENIOR VICE PRESIDENT

FKP:ec

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W. F. Christianson
Zimmer Project Inspector
Region III

8211020282 821025
PDR ADOCK 05000358
S PDR

1827
OCT 29 1982