



EDISON DRIVE
AUGUSTA, MAINE 04336
(207) 623-3521

September 30, 1982
MN-82-187

JHG-82-175

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Attention: Mr. Ronald C. Haynes, Director

References: (a) License No. DPR-36 (Docket No. 50-309)
(b) MYAPCo Letter to USNRC dated August 13, 1982, MN-82-162

Subject: Response to Inspection No. 50-309/82-08

Dear Sir:

This letter is to remove a potential ambiguity in a commitment made via Reference (b). The Potential ambiguity involves the word "area." The word "cubicle" conveys more precisely the meaning of this commitment.

The second commitment on page three should read:

2. Self-closing gates will be employed as barricades to cubicles where the dose rates are 100-999 mrem/hr. These will be installed at waist level and will have the proper sign attached.

We trust that you find this clarification satisfactory. Should you have any further questions, please feel free to contact us.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY

John H. Garrity, Senior Director
Nuclear Engineering & Licensing

JHG:pjp

cc: Mr. Robert A. Clark
Mr. Paul A. Swetland

8211020305 821028
PDR ADOCK 05000309
Q PDR