DCS No: 50309901217 Date: December 18, 1990

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-90-105

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility:		Licensee Emergency Classification:
Maine Yankee		Notification of Unusual Event
Docket No. 50-309		Alert
Wiscasset, Maine		Site Area Emergency
		General Emergency
		X Not Applicable
Subject: UNPLANN	ED SHUTDOWN FOR G	REATER THAN 72 HOURS

On December 17, 1990 at 3:40 p.m., operators began to decrease reactor power when the calculated primary to secondary leak rate (based on air ejector activity) in steam generator SG-1 increased from 0.004 gpm to 0.01 gpm. Primary to secondary leakage, which had existed in SG-1 since August 1990, had previously increased from 0.0003 gpm to 0.004 gpm during the week of December 9, 1990. At 4:50 a.m. on December 17, the leak rate again increased, to 1.0 gpm, exceeding the 0.15 gpm Technical Specification limit for a single steam generator, and operators accelerated the shut down rate. The reactor was shut down by 7:00 a.m. Gaseous releases remained within Technical Specification limits.

At 5:00 p.m., December 18, the RCS was at 200 psig and 160 F. SG-1 was cooled down, isolated and being drained for inspection. The licensee expects the plant to be shut down for at least 7 days for inspection and repairs.

The State of Maine has been notified of the unplanned shut down.

The Senior Resident Inspector is following licensee actions.

E. McCabe

FTS 346-5231 DISTRIBUTION: OWFN MNBB L-St. Mail: ADM: DMB NL Chairman Carr AEOD RES DOT: Trans only Comm. Rogers IRM PDR Comm. Curtiss OIG NRC Ops Ctr Comm. Remick CA EDO Phillips INPO----OGC NMSS ACRS NSAC----GPA NRR PA OE Regional Offices SP RI Resident Office EWW ASLAP Licensee: (Reactor Licensees)

Region I Form 83 (Rev. April 1988)

CONTACT:

9012280056 901218 PDR 1&E PNO-I-90-105 PDR 2:341