



**Entergy  
Operations**

Entergy Operations, Inc.  
P.O. Box 750  
Port Gibson, MS 39150  
Tel 601-437-6409

**W. T. Cottle**  
Vice President  
Nuclear Operations

December 21, 1990

U.S. Nuclear Regulatory Commission  
Mail Station P1-137  
Washington, D.C. 20555

Attention: Document Control Desk

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-29  
Reactor Water Cleanup System  
Isolation On Low Delta Flow  
LER 90-027

GNRO-90/00005

Gentlemen:

Attached is Licensee Event Report (LER) 90-027 which is a final report.

Yours truly,

*W T Cottle*

WTC/JS/cg  
attachment

cc: (See Next Page)

9012280163 9  
PDR ADOCK 05000416  
S PDR

LER9027/SCMPFLR

27 096

*IF22*  
*11*

December 20, 1990

GNRO-90/00005

Page 3 of 3

bcc: Mr. P. E. Alberstadt (w/a)  
Mr. C. W. Angle (w/a)  
Mr. R. W. Byrd (w/a)  
Mr. M. A. Dietrich (w/a)  
Mr. J. L. Ensley (w/a)  
Mr. W. K. Hughey (w/a)  
Mr. C. R. Hutchinson (w/a)  
Ms. F. K. Mangan (w/o)  
Mr. M. J. Meisner (w/a)  
Mr. G. W. Muench (w/a)  
Mr. T. E. Reaves (w/a)  
Ms. J. Summers (w/2)  
Mr. F. W. Titus (w/a)  
Mr. G. A. Zinke (w/a)  
SRC Secretary (w/a)  
File (LCTS) (w/2)  
File (RPTS) (w/a)  
File (NL) (w/a)  
File (Central) (w/a) ( 8 )

INPO Records Center (w/a)  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

Mr. F. A. Spangenberg (w/a)  
Illinois Power Company  
Clinton Power Station  
P.O. Box 678  
Clinton, Illinois 61727

December 20, 1990  
GNRO-90/00005  
Page 2 of 3

cc: Mr. D. C. Hintz (w/a)  
Mr. R. B. McGehee (w/a)  
Mr. N. S. Reynolds (w/a)  
Mr. H. L. Thomas (w/o)  
Mr. J. L. Mathis (w/a)

Mr. Stewart D. Ebnetter (w/a)  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30323

Mr. L. L. Kintner, Project Manager (w/a)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Mail Stop 11D21  
Washington, D.C. 20555

NRC Form 306 (8-83)										U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3160-0104 EXPIRES 8-31-88											
LICENSEE EVENT REPORT (LER)																					
FACILITY NAME (1) Grand Gulf Nuclear Station - Unit 1										DOCKET NUMBER (2) 0 5 0 0 0 4 1 6					PAGE (3) 1 OF 0 3						
TITLE (4) Reactor Water Cleanup System Isolation On Low Delta Flow																					
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)											
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES					DOCKET NUMBER(S)							
1	1	24	9	0	9	0	0	2	7	0	0	NA					0 5 0 0 0 0				
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5 (Check one or more of the following) (11)																			
2		20.402(b)				20.405(e)				<input checked="" type="checkbox"/> 50.73(a)(2)(iv)					73.21(b)						
POWER LEVEL (10)		20.405(a)(1)(iii)				50.36(a)(1)				50.73(a)(2)(iv)					73.21(e)						
0 2 1 0		20.405(a)(1)(iii)				50.36(a)(2)				50.73(a)(2)(iv)(i)					OTHER (Specify in Abstract below and in Text, NRC Form 305A)						
		20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(iv)(ii)(A)											
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(iv)(ii)(B)											
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(iv)											
LICENSEE CONTACT FOR THIS LER (12)																					
NAME Jewel Summers / Sr. Compliance Coordinator										TELEPHONE NUMBER 6 1 0 1 1 4 3 7 - 1 2 1 1 4 1 9											
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																					
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC												
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)											
<input type="checkbox"/> YES (if yes, complete EXPECTED SUBMISSION DATE)										<input checked="" type="checkbox"/> NO											
ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)																					
<p>On November 24, 1990, during transfer of the Reactor Water Cleanup System (EIS Code: CE) from the pre-pump mode to the post-pump mode, a low differential flow isolation occurred.</p> <p>Contrary to the requirements of the Integrated Operating Instruction (IOI), operators shifted from pre-pump mode to post-pump mode of operations prior to reactor pressure reaching 100 psig. Additionally, the operator started the second RWCU pump prior to reaching 200 psig reactor pressure which is also contrary to the IOI precautions. These actions caused flow perturbations which caused the isolation.</p> <p>Further investigations revealed that an inadequate pre-shift briefing was a contributing factor in this incident. The responsible Shift Superintendents and the reactor operator involved in this incident were counselled.</p> <p>There were no adverse safety consequences as a result of this incident. The RWCU system was restored to service in approximately 73 minutes.</p>																					

NRC Form 200A (8-83)		LICENSEE EVENT REPORT (LER) TEXT CONTINUATION			U.S. NUCLEAR REGULATORY COMMISSION		
FACILITY NAME (1)		DOCKET NUMBER (2)		LER NUMBER (8)			PAGE (3)
Grand Gulf Nuclear Station		0 5 0 0 0 4 1 1 6		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	OF
				9 0	0 1 2 7	0 1 0	0 1 3
<p>TEXT: If more space is required, use additional NRC Form 200A's (17)</p>							
<p>A. Reportable Occurrence</p> <p>On November 24, 1990, during transfer of the Reactor Water Cleanup System (RWCU) from the pre-pump mode to the post-pump mode, a low differential flow isolation occurred. The automatic isolation of the RWCU system isolation valve is reported as an Engineered Safety Feature (ESF) actuation pursuant to 10CFR50.73(a)(2)(iv).</p>							
<p>B. Initial Condition</p> <p>The plant was in Mode 2, Startup, with a reactor pressure of 40 psig.</p>							
<p>C. Description of Occurrence</p> <p>At 2245 on November 24, 1990, the plant was in a startup evolution. Operators began shifting the Reactor Water Cleanup System (EIS Code: CE) from the pre-pump mode to the post-pump mode at 25 psig reactor pressure; however, the Integrated Operating Instruction (IOI) required shifting RWCU operation from pre-pump to post-pump at approximately 100 psig.</p> <p>Operators started the "A" pump, and then started the "B" pump, at which time they noticed erratic differential flow indications. This was also contrary to the Integrated Operating Instruction which cautions against placing both pumps in operation at a reactor pressure less than 200 psig. The operators attempted to adjust flow by using bypass valve G33-F044. In an effort to reduce flow, operators tripped the "B" pump. Upon closure of the G33-F044 valve, all flow was secured to the "A" pump which tripped on low flow. The delta flow timer timed out and the RWCU system containment isolation valves automatically closed. Instrumentation and Control (I&amp;C) personnel were subsequently notified to fill and vent the RWCU inlet transmitters. The RWCU system was restored to service at 2318.</p>							
<p>D. Apparent Cause</p> <p>This incident occurred due to licensed personnel error. The RWCU system is susceptible to perturbations at reactor pressures less than 100 psig when both pumps are operating; thereby, causing the system to isolate on delta flow.</p>							



NRC Form 306A (5-83)		LICENSEE EVENT REPORT (LER) TEXT CONTINUATION			U.S. NUCLEAR REGULATORY COMMISSION		
					APPROVED OMB NO. 3150-0104		
					EXPIRES 8/31/90		
FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (3)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		OF	
Grand Gulf Nuclear Station	08000415	90	027	00	03	OF	03
TEXT (if more space is required, use additional NRC Form 306A's) (17)							
<p>As a result of several RWCU isolations experienced in the past, and efforts to make personnel aware of certain operating conditions, plant procedures were changed to provide adequate margin in the pump suction pressure to prevent system isolations (Reference: LER 88-004, dated February 11, 1988.) All licensed operations personnel were instructed on the significance of these changes and the potential for RWCU system isolations. The reactor operator involved in this incident failed to follow plant procedures which prohibit placing both RWCU pumps in operation at a reactor pressure less than 200 psig.</p> <p>Further investigations revealed that an inadequate pre-shift briefing, i.e., discussions on required hold points by the responsible shift superintendent, was a contributing factor.</p> <p>E. Supplemental Corrective Actions</p> <p>The reactor operator involved in this incident was counselled and disciplinary actions were taken. Additionally, the responsible Shift Superintendents were counselled on the importance of conducting proper pre-shift briefings.</p> <p>F. Safety Assessment</p> <p>There were no adverse safety consequences as a result of this incident. Containment isolation valves responded as designed. Further, no actual unidentified RWCU leakage was present.</p>							

01-S-15-4	Revision 8
Attachment III	Page 2 of 2

NRC SUBMITTAL CERTIFICATION FORM (LERs AND VIOLATION RESPONSES)

I. Letter Number (List AECH, LER, Violation, etc.) GNRO-90/00005 J. SUMMERS 12-17-90  
 Document Originator Date

II. Certification: Responsible Section/Organization OPERATIONS

Page/ Paragraph Number	Sentence Number/Numbers	#BASIS	COMMENTS
PAGE 2.A	SEN. 1	incident report	
PAGE 2.B	SEN 1	incident report	
PAGE 2.C	ALL	FOI, control room logs	
PAGE 2.D	ALL	SOP precautions, FOI procedure interviews with operator involved	
PAGE 3.E	ALL	counselling letters, personnel interviews	
PAGE 3.F	ALL	control room rounds	

#Basis: 1) Indicate when an action was or will be done (date) and how. [Signature] 12-21-90  
 Responsible Supv/Supt Date

2) If statement of fact list supporting document(s) i.e., UFSAR, P&ID, Procedure, etc.

3) May be a statement or conclusion which is only supported by <sup>\*\*</sup> engineering judgement which must be described under basis. Plant Licensing Date

\* Signature indicates certification of the accuracy of indicated portions of the document. Document may be certified with comments.

\*\* Plant Licensing will perform an independent verification for completed action items contained in Licensing Event Report (LER), NRC Violations, or when requested by GGNS General Manger.

NOTE: Use separate sheet for each section/organization.  
 01-S-15-4 ATT III

CONCURRENCE REVIEW FORM

SECTION I

GNRO- 90/00005

RESPONSE DUE: 12/21/90  
(NRC Required)

SUBJECT: LER 90-027, RWCU Isolation On Low Delta Flow

J. Summers 12/19/90  
NRC Document Preparer/Date

G. A. Zinke 12/19/90  
Responsible Section Manager/Date  
Superintendent

L. Daughtery 12/19/90  
Responsible Sect. Supv./Date

Commitment Concurrence

SECTION II

Locations	Commitment	Responsible Organization Primary/Secondary	Due Date
	None		

SECTION III

Concurrence  
Review Required  
Y N

Comments

( )	(X)	<u>VP, Engineering/Date</u>	
(X)	( )	<u>W.S. Coen 12/20/90</u> VP-Operations Grand Gulf/Date	
( )	(X)	<u>Director, Nuclear Plant</u> Engineering/Date	
(X)	( )	<u>EGNS General Manager/Date</u> <u>12/20/90</u>	
(X)	( )	<u>Director, Nuclear</u> licensing/Date <u>12/20/90</u>	
( )	( )		

\*Signature denotes certification

This letter contains commitments requiring procedural implementation

Yes ( ) No ( )