

Y1003J01A44
CLASS I
JUNE 1982

50-245

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL FOR MILLSTONE UNIT 1 RELOAD 8

8211020641 821015
PDR ADOCK 05000245
P PDR

GENERAL  ELECTRIC

Y1003J01A44
Revision 0
Class I
June 1982

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR
MILLSTONE UNIT 1
RELOAD 8

Prepared: J.D. Leaser
J.D. Leaser
Reload Fuel Licensing

Verified: C.L. Hilf
C. L. Hilf
Reload Fuel Licensing

Approved: R.E. Engel 6/25/82
R.E. Engel, Manager
Reload Fuel Licensing

NUCLEAR POWER SYSTEMS DIVISION • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Northeast Utilities Service Company (NUSCo) for NUSCo's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending NUSCo's operating license of the Millstone Nuclear Power Station. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the contract between Northeast Utilities Service Company and General Electric Company for nuclear fuel and related services for the nuclear system for Millstone Nuclear Power Station, dated April 14, 1967, and nothing contained in this document shall be construed as changing said contract. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

1. PLANT-UNIQUE ITEMS (1.0)*

Control Rod Drop Analysis Appendix A
 Transient Analysis Initial Conditions: Appendix B
 GETAB Analysis Initial Conditions: Appendix C

2. RELOAD FUEL BUNDLES (1.0, 2.0, 3.3.1 and 4.0)

<u>Fuel Type</u>	<u>Cycle Loaded</u>	<u>Number</u>	<u>Number Drilled</u>
Irradiated			
8DB262	3	1	0
8DB274H	6	71	0
8DRB265H	7	48	48
8DRB265L	7	100	100
P8DRB265H	8	40	40
P8DRB282	8	128	128
New			
P8DRB282	9	72	72
P8DRB283H	9	<u>120</u>	<u>120</u>
		580	508

3. REFERENCE CORE LOADING PATTERN (3.3.1)

Nominal previous cycle core average exposure at end of cycle: 17580 MWd/ST
 Minimum previous cycle core average exposure at end of cycle from cold shutdown considerations: 17580 MWd/ST
 Assumed reload cycle core average exposure at end of cycle: 18036 MWd/ST
 Core loading pattern: Figure 1

4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH - NO VOIDS, 20°C (3.3.2.1.1 and 3.3.2.1.2)

Beginning of Cycle, k_{eff}	
Uncontrolled	1.113
Fully Controlled	0.955
Strongest Control Rod Out	0.982
R, Maximum Increase on Cold Core Reactivity with Exposure into Cycle, ΔK	0.008

*() Refers to Area of Discussion in "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-4, January 1982.

5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

<u>ppm</u>	<u>Shutdown Margin (Δk)</u> <u>(20°C, Xenon Free)</u>
660	0.043

6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUT (3.3.2.1.5 and S.2.2)(REDY Events Only)

EOC9

Void Fraction (%)	37.0
Average Fuel Temperature (°F)	1171
Void Coefficient N/A* (ζ /% RG)	-6.10/ -7.62
Doppler Coefficient N/A (ζ /°F)	-0.229/ -0.218
Scram Worth N/A (\$)	-46.31/ -37.05

*N = Nuclear Input Data

A = Used in Transient Analysis

7. RELOAD-UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS (S.2.2)

<u>Fuel Design</u>	<u>Peaking Factors</u> <u>(Local, Radial, Axial)</u>			<u>R-</u> <u>Factor</u>	<u>Bundle</u> <u>Power</u> <u>(MWt)</u>	<u>Bundle</u> <u>Flow</u> <u>(1000</u> <u>lb/hr)</u>	<u>Initial</u> <u>MCPR</u>
BOC9 to EOC9							
P8x8R	1.20	1.62	1.40	1.051	5.469	100.5	1.42
8x8R	1.20	1.65	1.40	1.051	5.590	99.2	1.38
8x8	1.22	1.52	1.40	1.098	5.150	102.3	1.38

8. SELECTED MARGIN IMPROVEMENT OPTIONS (S.2.2.2)

Transient Recategorization:	No
Recirculation Pump Trip:	No
Rod Withdrawal Limiter:	No
Thermal Power Monitor	No
Measured Scram Time:	No
Number of Exposure Points:	1

9. CORE-WIDE TRANSIENT ANALYSIS RESULTS (S.2.2.1)

Transient	Flux (%NBR)	Q/A (%NBR)	<u>ΔCPR</u>			Figure
			P8x8R	8x8R	8x8	
Exposure: BOC9 to EOC9 Load Rejection w/o Bypass	613	127	0.35	0.32	0.32	2
Exposure: BOC9 to EOC9 Loss of Feedwater Heater	115	114	0.12	0.12	0.12	3
Exposure: BOC9 to EOC9 Feedwater Controller Failure	109	108	0.07	0.07	0.07	4

10. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY (S.2.2.1)

(Generic Bounding Analysis Results)

<u>Rod Block Reading</u>	<u>ΔCPR (All Fuel Types)</u>
104	0.13
105	0.16
106	0.19
107	0.22
108	0.28
109	0.32
110	0.36

Set point selected is : 107

11. CYCLE MCPR VALUES (S.2.2)

Nonpressurization Events:

Exposure Range: BOC9 to EOC9	<u>P8x8R</u>	<u>8x8R</u>	<u>8x8</u>
Loss of Feedwater Heater	1.19	1.19	1.19
Fuel Loading Error	1.25	----	----
Rod Withdrawal Error	1.29	1.29	1.29

Pressurization Events

Exposure Range: BOC9 to EOC9

	<u>Option A</u>			<u>Option B</u>		
	<u>P8x8R</u>	<u>8x8R</u>	<u>8x8</u>	<u>P8x8R</u>	<u>8x8R</u>	<u>8x8</u>
Load Rejection w/o Bypass	1.48	1.45	1.45	1.43	1.40	1.40
Feedwater Controller Failure	1.19	1.19	1.19	1.12	1.12	1.12

12. OVERPRESSURIZATION ANALYSIS SUMMARY (S.2.3)

<u>Transient</u>	P_{sl} (psig)	P_v (psig)	<u>Plant Response</u>
MSIV Closure (Flux Scram)	1270	1285	Figure 5

13. STABILITY ANALYSIS RESULTS (S.2.4)

Rod Line Analyzed: Extrapolated Rod Block Line

Decay Ratio: Figure 6

Reactor Core Stability Decay Ratio, x_2/x_0 : 0.60

Channel Hydrodynamic Performance Decay Ratio, x_2/x_0

Channel Type

8x8R/P8x8R	0.21
8x8	0.26

14. LOADING ERROR RESULTS (S.2.5.4)

Variable Water Gap Misoriented Bundle Analysis: Yes

Includes 2.2% Power Spiking Penalty: No


<u>Event</u>	<u>Initial MCPR</u>	<u>Resulting MCPR</u>	<u>Resulting LHGR (kW/ft)</u>
Misoriented	1.23	1.07	15.2

15. CONTROL ROD DROP ANALYSIS RESULT (S.2.5.1)

Deleted: See Appendix A

16. LOSS-OF-COOLANT ACCIDENT RESULT (S.2.5.2)

See "Loss-of-Coolant Analysis Report for Millstone Unit 1
Nuclear Power Station," General Electric Company, July 1980,
(NEDO-24085-1, as amended).



FUEL TYPE	
A = 8DB274H	E = P8DRB283H
B = P8DRB265H	F = 8DRB265H
C = P8DRB282	G = 8DRB265L
D = P8DRB282	H = 8DB274H
	I = 8DB262

Figure 1. Reference Core Loading Pattern







Figure 2. Plant Response to Generator Load Rejection Without Bypass, EOC9







Figure 3. Plant Response to Loss of 100°F Feedwater Heating







Figure 4. Plant Response to Feedwater Controller Failure, EOC9

Y1003J01A44

Rev. 0







Figure 5. Plant Response to MSIV Closure (Flux Scram), EOC6




Figure 6. Reactor Core Decay Ratio versus Power

APPENDIX A
CONTROL ROD DROP ANALYSIS

The cycle-specific control rod drop accident analysis has been discontinued for Banked Position Withdrawal Sequence (BPWS) plants based on the fact that in all cases the peak fuel enthalpy from a control rod drop accident would be much less than the 280 cal/gm limit. This change in procedures was reported and justified in Reference A-1.

Reference

- A-1. Letter, R.E. Engel (GE) to D.B. Vassallo (NRC), "Control Rod Drop Accident," February 24, 1982.

APPENDIX B
TRANSIENT ANALYSIS INITIAL CONDITIONS

Rated Steam Flow	7.99×10^6 lb/hr
Turbine Pressure	979 psig

APPENDIX C

GETAB ANALYSIS INITIAL CONDITIONS

Reactor Core Pressure	1065 psia
Inlet Enthalpy	526.0 Btu/lb

Docket No. 50-245

Attachment No. 2
Changes to the
"Loss of Coolant Accident Analysis
Report for Millstone Unit 1 Nuclear Power Station"
NEDO-24085-1, dated July 1980

October 1982