



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 REGION III
 799 ROOSEVELT ROAD
 GLEN ELLYN, ILLINOIS 60137

*DCD/DCB
(RIDS)*

DEC 18 1990

Docket No. 50-265
 License No. DPR-30
 EA 90-203

Commonwealth Edison Company
 ATTN: Mr. Cordell Reed
 Senior Vice President
 Opus West III
 1400 Opus Place
 Downers Grove, IL 60515

Gentlemen:

This refers to the Enforcement Conference conducted by Dr. C. J. Paperiello and members of the NRC staff and with Mr. D. Galle and other members of your staff on December 7, 1990, at the Nuclear Regulatory Commission's Region III Office in Glen Ellyn, Illinois, regarding the apparent violations identified in NRC Inspection Report No. 50-265/90020 (DRP) of activities at the Quad Cities Nuclear Power Station Unit 2, authorized by NRC Operating License No. DPR-30.

The enclosed copy of our report addresses issues discussed during the enforcement conference. One area of concern identified during this conference was the apparent lack of management control of reactor operations associated with the unit 2 turbine torsional test. As stated in the Special Inspection Report No. 50-265/90024, the Assistant Superintendent for Operations failed to communicate any of his expectations to the operating engineers assigned as test directors. Senior plant management must continuously communicate expectations to the operating crew regarding control of plant evolutions, particularly those that are infrequent or unusual.

In Accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed report will be placed in the NRC Public Document Room.


9101020183 901218
 PDR ADDCK 05000265
 Q PDR

11
TE01

DEC 18 1990

We will gladly discuss any questions you have concerning the Enforcement Conference.

Sincerely,


for H. J. Miller, Director
Division of Reactor Projects

Enclosures:

1. Inspection Report
No. 50-265/90024(DRP)
2. Commonwealth Edison
Company Presentation

cc w/enclosure:

D. Galle, Vice President - BWR
Operations
T. Kovach, Nuclear
Licensing Manager
R. L. Bax, Station Manager
DCD/DCB (RIDS)
OC/LFDCB
Resident Inspectors LaSalle
Dresden, Quad Cities
Richard Hubbard
J. W. McCaffrey, Chief, Public
Utilities Division
L. Olshan, NRR LPM
Robert Newmann, Office of Public
Counsel, State of Illinois Center