

OCT 14 1982

- DISTRIBUTION
- Docket File
- Local PDR
- ORB Rdg
- D.Eisenhut
- JHeltemes
- RAClark
- PKreutzer
- OELD
- NSIC
- I&E (1)
- ACRS (10)
- GKuzmycz
- Gray File
- PBender
- TSpeis

Docket No 50-267

Mr. O. R. Lee
 Vice President Production
 Public Service Company of Colorado
 P. O. Box 840
 Denver, Colorado 80201

SUBJECT: ENGINEERED SAFETY FEATURES RESET CONTROLS

The Commission, in a letter dated September 1981, requested that you respond to the concerns presented in I&E Bulletin 80-06 since the concerns were generic and involved considerations of safety system circuits. After reviewing your submittals of analyses and test results, we find that the verification that components of the steam water dump system will not change state on reset of the actuation signal acceptable. We further determined that you fulfill the requirements of the bulletin and have provided adequate evidence that reset controls conform to NRC criteria.

Enclosed is our Safety Evaluation which forms part of our basis for accepting your submittals.

Sincerely,
Original signed by:

Robert A. Clark, Chief
 Operating Reactors Branch #3
 Division of Licensing

Enclosure:
 1. Safety Evaluation

cc: w/enclosures
 See next page

8211040092 821014
 PDR ADOCK 05000267
 G PDR

OFFICE	DL:ORB#3	DL:ORB#3	DL:ORB#3			
SURNAME	PKreutzer	GKuzmycz:dd	RAClark			
DATE	8/15/82	8/23/82	10/15/82			

Ft. St. Vrain
cc list

James B. Graham, Manager
Licensing and Regulation
East Coast Office
General Atomic Company
2021 K. Street, N. W.
Suite 709
Washington, D. C. 20006

Mr. W. Dickerson
NRC Resident Inspector
16805 Weld County Road 19 1/2
Platteville, Colorado 80651

Director, Division of Planning
Department of Local Affairs
615 Columbine Building
1845 Sherman Street
Denver, Colorado 80203

Chairman, Board of County Commissioners
of Weld County, Colorado
Greeley, Colorado 80631

Regional Representative, Radiation Programs
Environmental Protection Agency
1860 Lincoln Street
Denver, Colorado 80203

Mr. Don Warembourg
Nuclear Production Manager
Public Service Company of Colorado
16805 Weld County Road 19 1/2
Platteville, Colorado 80651

Regional Administrator
Nuclear Regulatory Commission, Region IV
Office of Executive Director for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011