



# LAWRENCE LIVERMORE LABORATORY

Operating Reactors - TMI Lessons Learned NUREG-0737 Response  
Evaluations (Program II)

Project 1 - Reactor Coolant System Vents (Item II.B.1)  
NRC FIN A0246-2

FINAL TECHNICAL EVALUATION REPORT FOR COOPER

Prepared by Energy Incorporated - Seattle for Lawrence Livermore  
National Laboratory under contract to the NRC Office of Nuclear  
Reactor Regulation, Division of Licensing.

DL Cognizant Manager - Ed Butcher

DL Project Manager - Beverly Barnhart

July 1, 1982

8211040112 821014  
PDR ADDCK 05000298  
P PDR

TECHNICAL EVALUATION REPORT  
ON REACTOR COOLANT SYSTEM VENTS  
FOR COOPER

INTRODUCTION

The requirements for Reactor Coolant System High Point Vents are stated in paragraph (C)(3)(iii) of 10 CFR 50.44, "Standards for Combustible Gas Control System in Light Water Cooled Power Reactors," and are further described in Standard Review Plan (SRP) Section 5.4.12, "Reactor Coolant System High Point Vents," and Item II.B.1 of NUREG-0737, "Clarification of TMI Action Plan Requirements." In response to these and previous requirements, the Nebraska Public Power District has submitted information in References 1 through 3 in support of the vent system on Cooper Nuclear Station.

EVALUATION

The function of the reactor coolant system (RCS) vent system is to vent noncondensable gases from the high points of the RCS to assure that core cooling during natural circulation will not be inhibited. The Boiling Water Reactor (BWR) Owners' Group has submitted documentation (References 4 through 7) on how the RCS venting requirements are met in General Electric (GE) BWRs. The BWR Owners' Group position has been endorsed by the licensee.

In accordance with the BWR Owners' Group position, the primary means of venting noncondensable gases from the reactor pressure vessel at Cooper are six power-operated, safety-grade automatic depressurization system (ADS) safety/relief valves which alone provide adequate venting.

We have reviewed design information on the valves associated with the above system that will serve as RCS vents and confirmed that they are operable from the main control room. We have also determined that the valves are provided with emergency power and that a degree of redundancy in the RCS vent system is provided by powering different vent paths from different emergency buses. NRC has previously verified that the

safety/relief valves are provided with positive position indication in the main control room (Reference 8). Additional RCS venting occurs at the high pressure coolant injection (HPCI) and reactor core isolation cooling (RCIC) system turbine exhausts. No other protection system that is necessary to maintain adequate core cooling requires remote venting since none are susceptible to the buildup of a large amount of noncondensable gas that could cause a loss of function of these systems.

## CONCLUSION

We conclude, based on the applicability of the BWR Owners' Group position to Cooper and our specific review of the Cooper design, that the existing systems at Cooper are sufficient to effectively vent noncondensable gases from the RCS and meet the requirements of NUREG-0737 Item II.B.1 and paragraph (c)(3)(iii) of 10 CFR 50.44. We therefore recommend that the Cooper RCS venting capability be found acceptable by NRC with the following confirmatory items. NRC must review and approve the existing operating procedures and technical specifications for use of the existing systems as RCS vents.

LABORATORY

## REFERENCES

1. Letter, J.M. Pilant (Nebraska Public Power District) to D.G. Eisenhut (NRC), "Three Mile Island Followup Actions," dated October 17, 1979.
2. Letter, J.M. Pilant (Nebraska Public Power District) to D.G. Eisenhut (NRC), "Post TMI-Requirements /NUREG-0737," dated June 30, 1981.
3. Letter, J.M. Pilant (Nebraska Public Power District) to D.B. Vassallo (NRC), "II.B.1 'RCS High Point Vents' Response to NRC Request," dated April 30, 1982.
4. Letter, T.D. Keenan (BWR Owners' Group) to D.G. Eisenhut (NRC), "BWR Owners' Group Positions on NUREG-0578," dated October 17, 1979.
5. Letter, D.B. Waters (BWR Owners' Group) to NRC (Attn: D.G. Eisenhut), "Preliminary Clarification of TMI Action Plan Requirements — BWR Owners' Group Comments," dated October 8, 1980.
6. General Electric Report NEDO-24708A, Revision 1, "Additional Information Required for NRC Staff Generic Report on Boiling Water Reactors," dated December 1980.
7. Letter, D.B. Waters (BWR Owners' Group) to NRC (Attn: D.G. Eisenhut), "NUREG-0660/0737 Requirement II.B.1: Reactor Coolant System Vents," dated April 24, 1981.
8. NUREG-0737, "Clarification of TMI Action Plan Requirements," Item II.D.3, "Direct Indication of Relief- and Safety- Valve Position," dated November 1980.