



Carolina Power & Light Company

P.O. Box 1551 • Raleigh, N.C. 27602

DEC 18 1990

SERIAL: NLS-90-247

G. E. VAUGHN
Vice President
Nuclear Services Department

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62
NUREG-0612, CONTROL OF HEAVY LOADS

Gentlemen:

In a letter dated February 3, 1984 (NLS-84-002), Carolina Power & Light Company committed to reduce the safe working load for slings by 15% to account for maximum dynamic loading. The purpose of this letter is to inform the Staff of a revision to this commitment under the provisions of 10 CFR 50.59. Rather than the 15% reduction, CP&L will limit the safe working load for slings to the manufacturer's prescribed safe working loads for normal usage, as defined in ANSI B30.9, Section 9.9.1, Operating Practices, and ANSI B30.2, Section 2.3.2, Operations. Additional dynamic loading will be considered when the intended use is in excess of what constitutes normal usage. Engineering Evaluation Report (EER) No. 89-0180, Revision 0, "Justification to Remove 15% Reduction of Safe Working Load for Rigging." will be maintained as part of the 10 CFR 50.59 documentation and the Brunswick Updated FSAR will be revised accordingly as part of the 1991 annual update.

Please refer any questions regarding this submittal to Mr. M. R. Oates at (919) 546-6063.

Yours very truly,

G. E. Vaughn

GEV/MAT

cc: Mr. S. D. Ebnetter
Mr. N. B. Le
Mr. R. L. Prevatte

1/0

9101020287 901218
PDR ADOCK 05000324
PDR

A001