NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M N M N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | 1 (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 6 3 (7) | 1 0 1 2 8 2 (8) | 1 0 2 9 8 2 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During Refueling outage Local Leak Rate testing, CV-2385, Drywell Atmosperic
03 Control System inboard Isolation Valve bypass valve was found leaking in
04 excess of Technical Specification acceptance criteria (T.S. 4.7.A.2.F).
05 No effect on health and safety of Public. No previous similar occurances.
06
07
08
7 8 9 80

09 | SYSTEM CODE S D (11) | CAUSE CODE E (12) | CAUSE SUBCODE X (13) | COMPONENT CODE V A L V E X (14) | COMP SUBCODE G (15) | VALVE SUBCODE Q (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER | EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 1 4 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN B (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER B 2 9 5 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Black, Sivalls & Bryson 2" 600 lb. Globe Valve had a wear groove in its disk
11 face. Valve disk was machined, lapped and reinstalled. Similar valves will
12 be inspected for possible wear.
13
14
7 8 9 80

15 | FACILITY STATUS H (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Local Leak Rate Testing
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES
17 | NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

PERSONNEL INJURIES
18 | NUMBER 0 0 0 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE Z (42) | DESCRIPTION NA
7 8 9 10 80

PUBLICITY
20 | ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 9 10 68 69 80

8211050020 821029
PDR ADOCK 05000263
S PDR

NAME OF PREPARER A. V. Wojchouski PHONE: 612-295-5151

GPO 911-926