

OCT, 19 1982

DISTRIBUTION:

Docket File NRC PDR
LB#2 File Local PDR
JStefano NSIC
EHylton PRC
Region III
Cutchin, OELD
ACRS (16)
WHaass
JSpraul

Docket Nos.: 50-440/441

Mr. Dalwyn R. Davidson
Vice President
System Engineering and Construction
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Davidson:

Subject; Request for Clarification and Additional Information Pertaining
to the QA List for the Perry Nuclear Power Plant (Units 1 and 2)
in Amendments 8 and 9 of the FSAR

The NRC Quality Assurance staff has reviewed Amendments 8 and 9 of the
Final Safety Analysis Report and finds that revisions made to Section 322,
pertaining to the QA list for Perry Units 1 and 2, do not fully or correctly
document commitments made in your letter dated April 20, 1982. Enclosed
is a list of additional information and clarification required to fully
address commitments made to the staff. Please advise the project manager,
John J. Stefano, when we may expect to receive a response within five (5)
days after receipt of this letter. A copy of your response should be
provided to Mr. Jack Spraul of the Quality Assurance Branch staff.

Your immediate attention to this request will be most appreciated and is
urged.

Sincerely,

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure:
As stated

cc: See next page

8211050067 821019
PDR ADOCK 05000440
A PDR

OFFICE ▶	DL:LB#2/PM	DL:LB#2/BC					
SURNAME ▶	JStefano:pt.	ASchwencer					
DATE ▶	10/19/82	10/19/82					

Perry

Mr. Dalwyn R. Davidson
Vice President, Engineering
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

cc: Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Donald H. Hauser, Esq.
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
P. O. Box 1000
Washington, D. C. 20540

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Daniel D. Wilt, Esq.
P. O. Box 08159
Cleveland, Ohio 44108

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry Lodge, Esq.
915 Spitzer Building
Toledo, Ohio 43604

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

Request for Additional Information
Perry Nuclear Power Plants

260.0 Quality Assurance Branch

260.10 Indicate in Table 3.2-1 whether the following items are safety class 1, 2, or 3 and thus subject to the pertinent provisions of 10 CFR 50 Appendix B during the operations phase.

XXIX-12 Jacket water cooling

XXXIV-15 Spent fuel pool and liner

-16 Seismic Category I fill

-17 Foundation for Seismic Category I electrical duct banks and manholes

260.11 The response to NRC question 260.9 indicates the items listed below "will be added to Table 3.2-1." It does not appear that these items have been added to Table 3.2-1 (through FSAR Amendment 9). Indicate where in the table and when these items will be added.

a.21 A note to clarify that valve operators are implicit in the entry for the valves.

b.2 (XXXV) Control room HVAC condenser, charcoal filter housing, valves with safety isolation function, and utility exhaust fan.

c.1 The SPDS

c.5 The SRV position indication

c.8 Additional accident monitoring instrumentation

260.12 The following items are shown in FSAR Table 3.2-1 as Safety Class NSC. Clarify in the table that these items will be subject to the pertinent provisions of 10 CFR 50 Appendix B during the operations phase.

I.6 Reactor internal structures, other

III.6 Motors, pump

XXXII.6 Conduit, cable tray and supports containing non-IE cables in safety class structures where failure may damage other safety related items.

.9 a-c control power inverters

.11 fire stops

XXXIII.4 Conduit, cable tray and supports containing non-IE cables in safety class structures where failure may damage other safety related items.

XXXV.24.d Humidifiers (shown as safety class "other")

XXXV.1.f Dampers, fire control

260.13 FSAR Amendment 9 indicated that page 3.2-28a from Amendment 8 should be removed and replaced with 3.2-28a from Amendment 9. This action deletes item XXXVI from the table which appears to be inadvertent. Item XXXVI should be replaced in Table 3.2-1.