



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ARKANSAS POWER & LIGHT COMPANY

DOCKET NO. 50-368

ARKANSAS NUCLEAR ONE, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 35
License No. NPF-6

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power & Light Company (the licensee) dated August 23, 1982, as supplemented September 22, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-6 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 35, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the
Technical Specifications

Date of Issuance: October 15, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 35

FACILITY OPERATING LICENSE NO. NPF-6

DOCKET NO. 50-368

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Corresponding overleaf pages are provided to maintain document completeness.

Remove Pages

3/4 8-11
through
3/4 8-32

Insert Pages

3/4 8-11
through
3/4 8-32

ELECTRICAL POWER SYSTEMS

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

LIMITING CONDITION FOR OPERATION

3.8.2.5 All containment penetration conductor overcurrent protective devices shown in Table 3.8-1 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one or more of the containment penetration conductor overcurrent protective devices shown in Table 3.8-1 inoperable:

- a. De-energize the circuit(s) by tripping the associated backup circuit breaker within 72 hours and verifying the backup circuit breaker to be tripped at least once per 7 days thereafter; the provisions of Specification 3.0.4 are not applicable to overcurrent devices in circuits which have their backup circuit breakers tripped, or
- b. Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.8.2.5 All containment penetration conductor overcurrent protective devices shown in Table 3.8-1 shall be demonstrated OPERABLE in accordance with the manufacturers' recommendations:

- a. At least once per 18 months:
 1. For at least one 6.9 kv reactor coolant pump circuit, such that all reactor coolant pump circuits are demonstrated OPEARABLE at least once per 72 months, by performance of:
 - (a) A CHANNEL CALIBRATION of the associated protective relays, and
 - (b) An integrated system functional test which includes simulated automatic actuation of the system and verifying that each relay and associated circuit breakers and control circuits function as designed.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. For molded case circuit breakers, by performance of a functional test of a least one circuit breaker of each type, such that all circuit breakers of each type are demonstrated OPERABLE at least once per $N \times 18$ months, where N is the number of circuit breakers of each type. The functional test shall consist of injecting a current input at the specified setpoint to the circuit breaker and verifying that the circuit breaker functions as designed. If any circuit breaker fails to function as designed, all other circuit breakers of that type shall be tested.

- b. At least once per 60 months by subjecting each circuit breaker to an inspection and preventive maintenance in accordance with procedures prepared in conjunction with its manufacturer's recommendations.

TABLE 3.8-1

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|---|--------------------------------|--|
| A. 6900 KVAC | | | |
| 152-11 | 152-13, or 152-14, or 152-15 | Switchgear 2H1 | RCP 2P32A |
| 152-12 | 152-13, or 152-14, or 152-15 | Switchgear 2H1 | RCP 2P32D |
| 152-21 | 152-23, or 152-24, or 152-25 | Switchgear 2H2 | RCP 2P32B |
| 152-22 | 152-23, or 152-24, or 152-25 | Switchgear 2H2 | RCP 2P32C |
| B. 480 VAC | | | |
| 52-131 | None, circuit shall not be energized unless plant is shutdown | 2B1 | Containment Building Crane 2LM2 |
| 52-P501 thru 52-P504 | 52-523 | Primary - 2PP5 Backup - 2B5 | Pressurizer Proportional Heater Bank 1 |
| 52-533 | 52-512 | 2B5 | Hydrogen Recombiner 1 |
| 52-P601 thru 52-P604 | 52-623 | Primary - 2PP6 Backup - 2B6 | Pressurizer Proportional Heater Bank 2 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|----------------------------------|---|
| 52-633 | 52-612 | 2B6 | Hydrogen Recombiner 2 |
| 52-731 | 52-732 | 2B7 | MCC 2B71 |
| 52-824 | 52-823 | 2B8 | MCC 2B81 |
| 52-P701 thru 52-P706 | 52-922 | Primary - 2PP7 Backup - 2B9 | Pressurizer Backup Heater Bank 3 |
| 52-P901 thru 52-P906 | 52-923 | Primary - 2PP9 Backup - 2B9 | Pressurizer Backup Heater Bank 5 |
| 52-P801 thru 52-P806 | 52-1022 | Primary - 2PP8 Backup - 2B10 | Pressurizer Backup Heater Bank 4 |
| 52-1001 thru 52-1006 | 52-1023 | Primary - 2PP10 Backup - 2B10 | Pressurizer Backup Heater Bank 6 |
| C. 480 VAC MCC | | | |
| 52-51A4 | 52-51H2 | MCC 2B51 | Reactor Cavity Cooling Fan 2VSF34A-1 |
| 52-51B2 | 52-51H3 | MCC 2B51 | Containment Sump Isolation MOV 2CV-2060-1 |
| 52-51D3 | 52-51H4 | MCC 2B51 | Containment Recirculating Fan 2VSF31A-1 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|---|
| 52-51D4 | 52-51H5 | MCC 2B51 | Containment Recirculating Fan 2VSF31C-1 |
| 52-51E2 | 52-51H6 | MCC 2B51 | Reactor Drain Tank Drain Isolation Valve 2CV-2202-1 |
| 52-51FI | 52-51H7 | MCC 2B51 | RCP Controlled Bleedoff Isolation Valve 2CV-4846-1 |
| 52-51F2 | 52-51H8 | MCC 2B51 | Safety Injection Tank 2T2A Discharge MOV 2CV-5003-1 |
| 52-51G2 | 52-51L2 | MCC 2B51 | Shutdown Cooling Return Header Iso. Valve 2CV-5084-1 |
| 52-51G3 | 52-51H9 | MCC 2B51 | Check Valve Leakage Drain Valve 2CV-5105-1 |
| 52-5H1 | 52-51L3 | MCC 2B51 | Safety Injection Tank 2T2B Discharge MOV 2CV-5023-1 |
| 52-51K1 | 52-51L4 | MCC 2B51 | Containment Sump Isolation MOV 2CV-5647-1 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|---|
| 52-51K3 | 52-51L5 | MCC 2B51 | Containment Air Purge Isolation Valve 2CV-8289-1 |
| 52-51K4 | 52-51L6 | MCC 2B51 | Containment Air Purge Isolation Valve 2CV-8291-1 |
| 52-51L1 | 52-51L7 | MCC 2B51 | Containment Vent Header Isolation Valve 2CV-2401-1 |
| 52-51M1 | 52-51L8 | MCC 2B51 | Regenerative Heat Exchanger Inlet Valve 2CV-4821-1 |
| 52-51N3 | 52-51L9 | MCC 2B51 | Reactor Cavity Cooling Fan Bypass Damper 2HC08243-1 |
| 52-53G1 | 52-53A5 | MCC 2B53 | Containment Cooling Fan Bypass Damper Motor 2UCDM8203-1 |
| 52-53G2 | 52-53A6 | MCC 2B53 | Containment Cooling Fan Bypass Damper Motor 2UCDM8209-1 |
| 52-53L1 | 52-53K5 | MCC 2B53 | Containment Cooling Fan 2VSF1A |
| 52-53L2 | 52-53K6 | MCC 2B53 | Containment Cooling Fan 2VSF1B |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|--|
| 52-54J2 | 52-54J3 | MCC 2B54 | Containment Elevator Motor 2MM6 |
| 52-54K2 | 52-54J4 | MCC 2B54 | Containment Building Lighting Panel 27 LA |
| 52-54K3 | 52-54J8 | MCC 2B54 | RCP 2P3A Oil Lift Pumps 2P63A1 & A2 |
| 52-54K4 | 52-54F3 | MCC 2B54 | RCP 2P32B Oil Lift Pumps 2P63B1 & B2 |
| 52-61A4 | 52-61H3 | MCC 2B61 | Reactor Cavity Cooling Fan 2VSF34B-2 |
| 52-6103 | 52-61H4 | MCC 2B61 | Containment Recirculating Fan 2VSF31B-2 |
| 52-6104 | 52-61H5 | MCC 2B61 | Containment Recirculating Fan 2VSF31D-2 |
| 52-61F2 | 52-61H6 | MCC 2B61 | Safety Inject. Tank 2T2C Discharge MOV 2CV-5043-2 |
| 52-61G2 | 52-61K8 | MCC 2B61 | Check Valve Leakage Drain Valve 2CV-5106-2 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|--|
| 52-61G3 | 52-61H7 | MCC 2B61 | Reactor Cooling System Charging Line MOV 2CV-4831-2 |
| 52-61G4 | 52-61H8 | MCC 2B61 | Reactor Cooling System Charging Line MOV 2CV-4827-2 |
| 52-61H1 | 52-61K3 | MCC 2B61 | Safety Inj. Tank 2T2D Dis. MOV 2CV-5063-2 |
| 52-61H2 | 52-61K7 | MCC 2B61 | Containment Sump Iso. MOV 2CV-5E48-2 |
| 52-61L3 | 52-61K4 | MCC 2B61 | Letdown Line Stop Valve 2CV-4820-2 |
| 52-61N2 | 52-61K6 | MCC 2B61 | Reactor Cavity Cooling Fan Damper 2HCO 8244-2 |
| 52-62E5 | 52-62C2 | MCC 2B62 | Shutdown Cooling Return Header Iso. Valve 2CV-5086-2 |
| 52-63F2 | 52-63E1 | MCC 2B63 | Containment Chilled Water Isol. Valve 2CV-3850-2 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|--|
| 52-63G4 | 52-63E2 | MCC 2B63 | RCP Cooler Iso. Valve 2CV-5254-2 |
| 52-63L1 | 52-63J1 | MCC 2B63 | Containment Cooling Fan 2VSF1C |
| 52-63L2 | 52-63J2 | MCC 2B63 | Containment Cooling Fan 2VSF1D |
| 52-64D4 | 52-64B3 | MCC 2B64 | Containment Cooling Fan Bypass Damper Motor 2UCDM 8216-2 |
| 52-64E3 | 52-64B4 | MCC 2B64 | Pressurizer Auxiliary Spray MOV 2CV-4824-2 |
| 52-64E4 | 52-64C2 | MCC 2B64 | Containment Cooling Fan Bypass Damper Motor 2UCDM 8222-2 |
| 52-64J1 | 52-64B1 | MCC 2B64 | RCP 2P32C Oil Lift Pumps 2P63C1 & C2 |
| 52-64K1 | 52-64H2 | MCC 2B64 | RCP 2P32D Oil Lift Pumps 2P63D1 & D2 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|---------------------------------|--|
| <u>D. 480 /277</u> | | | |
| 21PA-19 | 52-15C1 | Primary - 21PA Backup - 2B15 | Space Heater for RCP 2P32A |
| 21PA-25 | 52-15C1 | Primary - 21PA Backup - 2B15 | Space Heater for RCP 2P32B |
| 21PA-31 | 52-15C1 | Primary - 21PA Backup - 2B15 | Space Heater for RCP 2P32C |
| 21PA-20 | 52-15C1 | Primary - 21PA Backup - 2B15 | Space Heater for RCP 2P32D |
| <u>E. 125 VAC</u> | | | |
| 72-0318 | 72-0320 | DC Control Center 2D03 | Containment Bldg 125 VDC Lighting Panel 22DA |
| 72-26A3 | 72-26A2 | DC MCC 2D26 | Pressurizer Vent Valve 2CV-4697-2 |
| 72-27A3 | 72-27A2 | DC MCC 2D27 | Pressurizer Vent Valve 2CV-4698-1 |
| 6 amp fuse in 2C116 | 2D21BKR26 | DC MCC 2D21 | RCS Sample Line Solenoid Valves 2SV-4632, 39 & 65 |
| <u>F. 240 VAC</u> | | | |
| CEA 1 CB101 | CB3021 & CB3022 | 2C72 | CEA 1 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CEA 2 CB101 | CB3001 | 2C70 | CEA 2 |
| CEA 3 CB102 | CB3001 | 2C70 | CEA 3 |
| CEA 4 CB103 | CB3001 | 2C70 | CEA 4 |
| CEA 5 CB104 | CB3001 | 2C70 | CEA 5 |
| CEA 6 CB101 | CB3002 | 2C70 | CEA 6 |
| CEA 7 CB102 | CB3002 | 2C70 | CEA 7 |
| CEA 8 CB103 | CB3002 | 2C70 | CEA 8 |
| CEA 9 CB104 | CB3002 | 2C70 | CEA 9 |
| CEA 10 CB101 | CB3002 | 2C70 | CEA 10 |
| CEA 11 CB102 | CB3003 | 2C70 | CEA 11 |
| CEA 12 CB103 | CB3003 | 2C70 | CEA 12 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CEA 13 CB104 | CB3003 | 2C70 | CEA 13 |
| CEA 14 CB101 | CB3004 | 2C70 | CEA 14 |
| CEA 16 CB102 | CB3004 | 2C70 | CEA 16 |
| CEA 18 CB103 | CB3004 | 2C70 | CEA 18 |
| CEA 20 CB104 | CB3004 | 2C70 | CEA 20 |
| CEA 15 CB101 | CB3005 | 2C70 | CEA 15 |
| CEA 17 CB102 | CB3005 | 2C70 | CEA 17 |
| CEA 19 CB103 | CB3005 | 2C70 | CEA 19 |
| CEA 21 CB104 | CB3005 | 2C70 | CEA 21 |
| CEA 22 CB101 | CB3006 | 2C70 | CEA 22 |
| CEA 23 CB102 | CB3006 | 2C70 | CEA 23 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CB24 CB103 | CB3006 | 2C70 | CEA 24 |
| CEA 25 CB104 | CB3006 | 2C70 | CEA 25 |
| CEA 26 CB101 | CB3007 | 2C70 | CEA 26 |
| CEA 27 CB102 | CB3007 | 2C70 | CEA 27 |
| CEA 28 CB103 | CB3007 | 2C70 | CEA 28 |
| CEA 29 CB104 | CB3007 | 2C70 | CEA 29 |
| CEA 30 CB101 | CB3008 | 2C70 | CEA 30 |
| CEA 32 CB102 | CB3008 | 2C70 | CEA 32 |
| CEA 34 CB103 | CB3008 | 2C70 | CEA 34 |
| CEA 36 CB104 | CB3008 | 2C70 | CEA 36 |
| CEA 31 CB101 | CB3009 | 2C70 | CEA 31 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CEA 33 CB102 | CB3009 | 2C70 | CEA 33 |
| CEA 35 CB103 | CB3009 | 2C70 | CEA 35 |
| CEA 37 CB104 | CB3009 | 2C70 | CEA 37 |
| CEA 38 CB101 | CB3010 | 2C70 | CEA 38 |
| CEA 40 CB102 | CB3010 | 2C70 | CEA 40 |
| CEA 42 CB103 | CB3010 | 2C70 | CEA 42 |
| CEA 44 CB104 | CB3010 | 2C70 | CEA 44 |
| CEA 39 CB101 | CB3011 | 2C71 | CEA 39 |
| CEA 41 CB102 | CB3011 | 2C71 | CEA 41 |
| CEA 43 CB103 | CB3011 | 2C71 | CEA 43 |
| CEA 45 CB104 | CB3011 | 2C71 | CEA 45 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CEA 46 CB101 | CB3012 | 2C71 | CEA 46 |
| CEA 47 CB102 | CB3012 | 2C71 | CEA 47 |
| CEA 48 CB103 | CB3012 | 2C71 | CEA 48 |
| CEA 49 CB104 | CB3012 | 2C71 | CEA 49 |
| CEA 50 CB101 | CB3013 | 2C71 | CEA 50 |
| CEA 52 CB102 | CB3013 | 2C71 | CEA 52 |
| CEA 54 CB103 | CB3013 | 2C71 | CEA 54 |
| CEA 56 CB104 | CB3013 | 2C71 | CEA 56 |
| CEA 51 CB101 | CB3014 | 2C71 | CEA 51 |
| CEA 53 CB102 | CB3014 | 2C71 | CEA 53 |
| CEA 55 CB103 | CB3014 | 2C71 | CEA 55 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CEA 57 CB104 | CB3014 | 2C71 | CEA 57 |
| CEA 58 CB101 | CB3015 | 2C71 | CEA 58 |
| CEA 59 CB102 | CB3015 | 2C71 | CEA 59 |
| CEA 60 CB103 | CB3015 | 2C71 | CEA 60 |
| CEA 61 CB104 | CB3015 | 2C71 | CEA 61 |
| CEA 62 CB101 | CB3016 | 2C71 | CEA 62 |
| CEA 64 CB102 | CB3016 | 2C71 | CEA 64 |
| CEA 66 CB103 | CB3016 | 2C71 | CEA 66 |
| CEA 68 CB104 | CB3016 | 2C71 | CEA 68 |
| CEA 63 CB101 | CB3017 | 2C71 | CEA 63 |
| CEA 65 CB102 | CB3017 | 2C71 | CEA 65 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CEA 67 CB103 | CB3017 | 2C71 | CEA 67 |
| CEA 69 CB104 | CB3017 | 2C71 | CEA 69 |
| CEA 70 CB101 | CB3018 | 2C71 | CEA 70 |
| CEA 73 CB102 | CB3018 | 2C71 | CEA 73 |
| CEA 76 CB103 | CB3018 | 2C71 | CEA 76 |
| CEA 79 CB104 | CB3018 | 2C71 | CEA 79 |
| CEA 71 CB101 | CB3019 | 2C71 | CEA 71 |
| CEA 74 CB102 | CB3019 | 2C71 | CEA 74 |
| CEA 77 CB103 | CB3019 | 2C71 | CEA 77 |
| CEA 80 CB104 | CB3019 | 2C71 | CEA 80 |
| CEA 72 CB101 | CB3020 | 2C71 | CEA 72 |

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

| PRIMARY DEVICE NUMBER | BACKUP DEVICE NUMBER | LOCATION OF DEVICES | SYSTEM POWERED |
|-----------------------------|----------------------------|------------------------|-------------------|
| CEA 75 CB102 | CB3020 | 2C71 | CEA 75 |
| CEA 78 CB103 | CB3020 | 2C71 | CEA 78 |
| CEA 81 CB104 | CB3020 | 2C71 | CEA 81 |

TABLE 3.8-1

TABLE NOTATION DELETED

PAGES 3/4 8-29 THROUGH 3/4 8-31 ARE LEFT BLANK INTENTIONALLY