

MAILGRAM SERVICE CENTER
MIDDLETOWN, VA, 22645

Western Union Mailgram®



1-017605C302 10/29/82 ICS IPMMVID MVN CGBA
06391 MGM MT VERNON IL 10-29 0410P CDT MVIB

NOV 1 1982

US NUCLEAR REGULATORY COMMISSION
JGKEPPLER REGION III
799 ROOSEVELT ROAD
GLEN ELLYN IL 60137

1-015423C302 10/29/82
TLX CPCO PARN JKN
166 CONSUMERS POWER JACKSON MI 15:59 DST 10-29
PMS

US NUCLEAR REGULATORY COMMISSION
JGKEPPLER, REGION III
799 ROOSEVELT ROAD
GLEN ELLYN IL 60137

MSG # TRP406

CPCO PARN JKN

10/29/82

4:00 PM

NOTIFICATION OF POSSIBLE PROMPT REPORTABLE LER

DURING ROUTINE INSPECTION, AN AUXILIARY OPERATOR NOTED A SMALL LEAK IN A PRIMARY SYSTEM INSTRUMENT SENSING LINE. THE LEAKAGE OF ABOUT 1 DRIP PER 8 SECONDS IS FROM A PIN-HOLE TYPE DEFECT IN A WELD IN 1/2" PIPING TO THE DISCHARGE PRESSURE CAGE, PI-IA-06A ON THE #1 REACTOR RECIRCULATION PUMP.

THE LEAKAGE IS BEING PERIODICALLY CHECKED AND THE PIPE IS MANUALLY ISOLATABLE IF DETERIORATION WARRANTS SUCH ACTION. THE EVENT IS DEMMED TO BE REPORTABLE BASED ON TECHNICAL SPECIFICATION 6.9.2A(3).

THIS CONFIRMS A DISCUSSION WITH THE RESIDENT INSPECTION G C WRIGHT AND A TELEPHONE REPORT FROM D E DEMOOR TO R D WALKER OF NRC REGION III AT 1435 HOURS ON 10/29/82.

DAVID J VANDEWALLE, NUCLEAR LICENSING ADM
CONSUMERS POWER CO
JACKSON, MI

CC D P HOFFMAN, BIG ROCK POINT PLANT
D E DEMOOR, BIG ROCK POINT PLANT

1604 EST

8211050212 821101
PDR ADDCK 05000155
S PDR

RSE SIDE FOR WESTERN UNION'S TOLL - FREE PHONE NUMBERS

JE 29

5241 (R 7/82)