



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

October 25, 1982
4410-82-L-0036

Office of Inspection and Enforcement
Attn: Mr. Ronald C. Haynes, Director
Region I
US Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Licensee Event Report 82-030/03L-0

Attached please find Licensee Event Report 82-030/03L-0 concerning the low fuel oil level in Emergency Diesel Generator Day Tank DF-T-1B on September 25, 1982.

This event concerns Section 3.8.1.1 and is considered reportable under Section 6.9.1.9(b) of the Interim Recovery Technical Specifications.

Sincerely,



B. K. Kanga
Director, TMI-2

BKK/SDC/jep

Attachments

CC: Mr. L. H. Barrett, Deputy Program Director - TMI Program Office
Dr. B. J. Snyder, Program Director - TMI Program Office
Mr. V. Stello, Deputy Executive Director

8211060007 821025
PDR ADOCK 05000320
S PDR