

TABLE 3.3.2-1

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1. Low, Level 1	2, 6	2	1, 2, 3	20
	8	2	1, 2, 3	27
2. Low, Level 3	1	2	1, 2, 3	20
b. Drywell Pressure - High	2, 6	2	1, 2, 3	20
c. Main Steam Line				
1. Radiation - High	1	2	1, 2, 3	21
2. Pressure - Low	1(j)	2	1	22
3. Flow - High	1(j)	2/line	1	22
4. Flow - High	1(j)	2	2, 3	21
d. Main Steam Line Tunnel Temperature - High	1(j)	2(d)	1, 2, 3	21
e. Condenser Vacuum - Low	1(j)	2	1, 2(e)	21
f. Turbine Building Area Temperature - High	1(j)	4(d)	1, 2, 3	21
g. Main Stack Radiation - High	(h)	1	1, 2, 3	28
h. Reactor Building Exhaust Radiation - High	6	1	1, 2, 3	20

9101030210 901221
PDR ADOCK 05000324
P PDR