

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 | N | J | S | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
7 8 | 0 | 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 7 | 2 | 7 | 1 | 0 | 0 | 2 | 8 | 2 | 8 | 1 | 0 | 2 | 0 | 8 | 2 | 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On October 2, 1982, during routine operation, the Control Room Operator noticed that
0 3 | the service water flow indication for No. 15 Containment Fan Coil Unit (CFCU) was
0 4 | erratic. The unit was declared inoperable and Action Statement 3.6.2.3.a was entered.
0 5 | Both containment spray systems were operable. The event constituted operation in a
0 6 | degraded mode in accordance with Technical Specification 6.9.1.9.b.
0 7 | (82-067, 82-061, 82-037, 82-029, 82-024)

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
S B (11) C (12) Z (13) I N S T R U (14) T (15) Z (16)

17 | LER RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
8 2 | - | 0 7 7 | / | 0 3 | L | - | 0

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
X (18) Z (19) Z (20) Z (21) 0 0 0 0 (22) Y (23) N (24) A (25) R 3 6 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The erratic flow indication was caused by silt plugging the transmitter sensing lines.
1 1 | The sensing lines were blown down to remove the silt, the CFCU was satisfactorily
1 2 | tested, and the action statement was terminated. A program to blow down transmitters
1 3 | weekly has effectively reduced the frequency of this problem.

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
E (28) 0 9 9 (29) N/A (30) A (31) Operator Observation (32)

1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
Z (33) Z (34) N/A (35) N/A (36)

1 7 | PERSONNEL EXPOSURES | DESCRIPTION
0 0 0 (37) Z (38) N/A (39)

1 8 | PERSONNEL INJURIES | DESCRIPTION
0 0 0 (40) N/A (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION
Z (42) N/A (43)

2 0 | PUBLICITY | DESCRIPTION
N (44) N/A (45)

8211060031 821020
PDR ADOCK 05000272
S PDR

NAME OF PREPARER R. Frahm PHONE 609/935-6000 Ext 3078