LICENSEE EVENT REPORT UPDATED LER
PREVIOUS REPORT 10-13-82 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 M I D C C 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 4 5 5 ELICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T O 1 SOURCE L 6 0 5 0 0 0 3 1 5 7 0 9 1 4 8 2 8 1 0 2 7 8 2 9 BEPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (19) O 12 WITH THE REACTOR COOLANT SYSTEM IN MODE 3, ON SEPTEMBER 14, 1982, A SUPPLY BREAKER
FOR HEAT TRACE CIRCUITS WAS FOUND TRIPPED. THIS BREAKER SUPPLIES POWER TO TRAIN "A"
HEAT TRACE CIRCUITS FOR THE BORON INJECTION TANK. ON SEPTEMBER 16, 1982, DURING MODE
2 THIS BREAKER WAS AGAIN FOUND TRIPPED. THESE EVENTS ARE CONTRARY TO TECHNICAL
SPECIFICATION 3.5.4.2. THE PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS
O 7 OCCURRENCE OF A SIMILAR NATURE INCLUDE: 315/81-039.
7 8 9
SYSTEM CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCOD
LER/RO EVENT YEAR SEQUENTIAL REPORT NO. NUMBER 2 2 23 24 26 27 28 29 30 31 32
ACTION FUTURE COMPONENT NPRD-4 PRIME COMP. COMPONENT SUBMITTED FORM SUB. SUPPLIER MANUFACTURER B 13 Z 19 Z 20 Z 21 0 0 0 0 0 N 23 Y 24 N 25 W 1 2 0 26
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) INVESTIGATION REVEALED THAT A LOOSE ALUMINUM WIRE CONNECTION AT THE MECHANICAL LUG
WAS CAUSING A HIGH RESISTANCE CONDITION, THAT CAUSED THE SUPPLY BREAKER TO TRIP.
THE LEADS WERE REMADE AND NO ADDITIONAL SUPPLY BREAKER PROBLEMS HAVE BEEN
ENCOUNTERED SINCE. NO FURTHER ACTION IS PLANNED AT THIS TIME.
7 8 9
FACILITY STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA N
TENSONNEL EXPOSURES
1 7 0 0 0 37 Z 38 NA
1 7 0 0 0 37 Z 38 NA PERSONNEL INJURIES 13 NUMBER DESCRIPTION 41
1 7 0 0 0 37 Z 38 NA PERSONNEL INJURIES NUMBER DESCRIPTION 41 1 8 9 11 12 NA NA NA BO BO BO BO BO BO BO BO BO B
1 7 0 0 0 37 Z 38 NA 8 9 PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA 1 8 9 11 12 NA LOSS OF OR DAMAGE TO FACILITY 43 NA 1 9 Z 42 NA
1 7 0 0 0 37 Z 38 NA 8 9 PERSONNEL INJURIES NUMBER DESCRIPTION 41 1 8 0 0 0 0 40 NA LOSS OF OR DAMAGE TO FACILITY 43 80 B0