LICENSEE EVENT REPORT

Elochold Event Heloni
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 A L J M F 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 5 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T SOURCE L 6 0 5 0 0 0 3 4 8 7 1 0 0 1 8 2 8 1 10 2 9 18 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 At 0745 on 10/01/82 during the performance of FNP-1-STP-612.0 (Reactor Coolant
Pump Bus Reactor Trip Undervoltage Relay Calibration), 1A Reactor Coolant Pump
Undervoltage Relay 27-3 was declared inoperable due to its out of spec. condition.
(65.4 volts actual vs. 75.4 volts required). Tech. Spec sections 3.3.1 and 3.3.2,
in part require this relay to be operable. Tech. Spec. action statement require-
ments were met. Health/safety of the public was not affected.
08
SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
TO REPORT 8 2 0 5 7 0 3 1 0 3 2 0 32 1 0 32 1 0 32 1 0 32 1 0 32 1 0 0 32 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
TAKEN ACTION ON PLANT METHOD HOURS 22 SUBMITTED FORM SUB. SUPPLIER MANOR ACTION ON PLANT METHOD HOURS 22 SUBMITTED FORM SUB. SUPPLIER MANOR ACTION ON PLANT METHOD HOURS 22 SUBMITTED FORM SUB. SUPPLIER MANOR ACTION OF
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) This event was attributed to setpoint drift. Following adjustment of the relay
setpr , 1A Reactor Coolant Pump Undervoltage Relay 27-3 was declared operable at
0815 on 10-01-82.
13
7 8 9
FACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 1 5 E 28 1 0 0 9 NA Surveillance Test 7 8 9 10 12 13 44 45 46 80
ACTIVITY CONTENT RELEASED OF RELEASE NA NA LOCATION OF RELEASE 36 NA PERSONNEL EXPOSURES AMOUNT OF ACTIVITY 35 NA NA 44 45
7 8 9 11 12 13 NA 80
NA NA
LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION NA PUBLICITY PUBLICITY NA B211060053 821029 PDR ADOCK 05000348 NRC USE ONLY
S PDR S PDR S PDR S S S S S S S S S
W. G. Hairston, III (205) 899-5156