



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 29, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Low Pressure Core Spray System
Discharge Line High
Pressure Setpoint Below
Allowed Limit Due To
Incorrect Tolerances In
The Surveillance Procedure
Reference: LER 82-100/03 L-0
AECM-82/520

During surveillance testing of the Low Pressure Core Spray System, the discharge line high pressure setpoint was found below the allowed limit of T.S.4.5.1.c.2.a.1.a. This event is being reported pursuant to T.S.6.9.1.13.a. Attached is LER 82-100/03 L-0.

Yours truly,

[Handwritten Signature]
FOR J. P. McGAUGHY JR

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY
IE 22

B211060065 821029
PDR ADOCK 05000416
S PDR

NOV 1 10:30
USNRC REGION II
ATLANTA, GEORGIA