



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

October 28, 1982
5211-82-234

Mr. R. C. Haynes
Region 1, Regional Administrator
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
LER 82-011/99X-0

Attached is Licensee Event Report 82-011/99X-0 which deals with vendor identified corrosion of one of Three Mile Island-Unit 1's power operated relief valves (PORV). Additional information will be provided as it becomes available.

Sincerely,

H. D. Fukill
Director, TMI-1

HDH:CJS:vjf

Attachment

cc: R. Conte
R. Jacobs
Document Management Branch

8211060066 821028
PDR ADOCK 05000289
S PDR

IER2