

### LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M S G G S | I 2 | 0 0 - 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | \_\_\_\_\_ | 5

CON'T  
0 1 | REPORT SOURCE | 6 | 0 5 0 0 0 4 1 6 | 7 | 0 9 3 0 8 2 | 8 | 1 0 2 9 8 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
0 2 | During surveillance testing of the Low Pressure Core Spray System, the discharge line  
0 3 | high pressure setpoint was found below the allowed limit of T.S.4.5.1.c.2.a.1.a. The  
0 4 | Tech. Spec. limit is 580 + 20, -0 psig. The setpoint, as found during the  
0 5 | surveillance test, was 579.8 psig. There was no threat to the health and safety of  
0 6 | the public and no threat to plant safety. This event is being reported pursuant to  
0 7 | T.S.6.9.1.13.a.

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE  
S F 11 | D 12 | Z 13 | I N S T R U 14 | S 15 | Z 16

17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.  
8 2 | 8 2 | 1 0 0 | / | 0 3 | L | 0

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER  
E 18 | G 19 | Z 20 | Z 21 | 0 0 0 0 | N 23 | N 24 | A 25 | P 3 6 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
1 0 | Incorrect tolerances in Surveillance Procedure 06-IC-1E2i-R-0001 (LPCS System  
1 1 | Discharge Line Hi/Lo Pressure Calibration) allowed the setpoint to be outside the  
1 2 | Tech. Spec. limit. The surveillance procedure was revised correcting the tolerances  
1 3 | and the instrument recalibrated. All surveillance procedures are currently under re-  
1 4 | view and errors of this type will be corrected. This is submitted as a final report.

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION  
B 28 | 0 0 0 29 | NA | B 31 | Surveillance Test 32

1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE  
Z 33 | Z 34 | NA | NA 36

1 7 | PERSONNEL EXPOSURES | DESCRIPTION  
0 0 0 37 | Z 38 | NA 39

1 8 | PERSONNEL INJURIES | DESCRIPTION  
0 0 0 40 | NA 41

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION  
Z 42 | NA 42

2 0 | PUBLICITY | DESCRIPTION  
N 44 | NA 45

8211060069 821029  
PDR ADOCK 05000416  
S PDR

GPO 91-7-952