



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 29, 1982

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
RHR System (LPCI Mode)
Discharge Line High Pressure
Setpoint Below Allowed
Limit Due To Incorrect
Tolerances In The
Surveillance Procedure
Reference: LER 82-099/03 L-0
AECM-82/519

NOV 1 4 40:30
REGIONAL OFFICE
ATLANTA, GEORGIA

While performing surveillance testing on the RHR System (LPCI Mode), the discharge line high pressure setpoint was found below the allowed limit of T.S.4.5.1.c.2.a.1.b. This event is being reported pursuant to T.S.6.9.1.13.a. Attached is LER 82-099/03 L-0.

Yours truly,

J.P. McGaughy, Jr.
FOR J.P. McGaughy, JR.

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY
IE 22

8211060074 821029
PDR ADOCK 05000416
S PDR