

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDCC 2 00-000000-000 341111 4 5

CON'T 01 REPORT SOURCE L 05000316 7 093082 8 102782 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 FOLLOWING UNIT SHUTDOWN, THE REACTOR COOLANT SYSTEM (RCS) DOSE EQUIVALENT (DOSEQ)
03 IODINE-131 CONCENTRATION EXCEEDED THE 1.0 uCi/gram STEADY STATE LIMIT OF TECHNICAL
04 SPECIFICATION 3.4.8. THE IODINE LEVELS REMAINED IN EXCESS OF TECHNICAL SPECIFICATION
05 LIMITS UNTIL 0902 HOURS ON OCTOBER 2, 1982. THE PUBLIC HEALTH AND SAFETY WERE NOT
06 AFFECTED. PREVIOUS OCCURRENCES OF A SIMILAR NATURE INCLUDE: 50-315/76-059, 78-026;
07 50-316/81-049, 82-004, 013, 018, 067, 075, 078.

09 SYSTEM CODE C G 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 82 21 22 079 24 26 27 03 28 29 L 30 31 0 32
ACTION TAKEN X 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 22 ATTACHMENT SUBMITTED Y 23 NRPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 ON SEPTEMBER 30, 1982, FOLLOWING A CONTROLLED UNIT SHUTDOWN, THE RCS DOSEQ-I-131
11 SPIKED TO 2.15 uCi/gram. PRIOR TO THE SHUTDOWN, THE RCS DOSEQ-I-131 WAS AVERAGING
12 9.5 x 10^-2 uCi/gram. IN AN ATTEMPT TO PREVENT RECURRENCE, FUEL SIPPING WILL BE
13 PERFORMED DURING THE UPCOMING REFUELING OUTAGE IN AN EFFORT TO LOCATE AND REPLACE
14 THE LEAKING FUEL ASSEMBLIES. (SEE ATTACHED SUPPLEMENT)

15 FACILITY STATUS G 28 % POWER 000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION ROUTINE CHEMICAL ANALYSIS 32

16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 ISSUED N 44 DESCRIPTION NA 45

8211060075 821027 PDR ADOCK 05000316 S PDR

NAME OF PREPARER R. A. PALMER

PHONE 616-465-5901

ATTACHMENT TO LER# 82-079/03L-0

SUPPLEMENT TO CAUSE DESCRIPTION

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF APPENDIX A TECHNICAL SPECIFICATIONS 3.4.8 AND 6.9.1. ON SEPTEMBER 30, 1982, THE DOSE EQUIVALENT IODINE-131 ACTIVITY IN THE UNIT 2 REACTOR COOLANT SYSTEM WAS FOUND OUT OF SPECIFICATION.

AT 1615 HOURS ON SEPTEMBER 30, 1982, THE UNIT STARTED A CONTROLLED SHUTDOWN, WITH THE REACTOR TRIPPING FROM APPROXIMATELY 11% POWER AT 1843 HOURS ON SEPTEMBER 30, 1982. LABORATORY ANALYSIS AT 1913 HOURS ON SEPTEMBER 30, 1982, INDICATED THE REACTOR COOLANT DOSE EQUIVALENT IODINE-131 CONCENTRATION HAD EXCEEDED THE TECHNICAL SPECIFICATION LIMITS OF 1.0  $\mu\text{Ci}/\text{gram}$ . \*THE DOSE EQUIVALENT IODINE-131 ACTIVITY SPIKED TO A MAXIMUM OF 2.15  $\mu\text{Ci}/\text{gram}$  AT 2116 HOURS ON SEPTEMBER 30, 1982. THE REACTOR COOLANT SYSTEM DOSE EQUIVALENT IODINE REMAINED ABOVE TECHNICAL SPECIFICATION LIMITS UNTIL 0902 HOURS ON OCTOBER 2, 1982. ALL SUBSEQUENT DOSE EQUIVALENT IODINE ANALYSIS INDICATED DECREASING LEVELS OF IODINE. FOLLOWING THE SHUTDOWN, THE UNIT WAS COOLED DOWN TO MODE 4 AND THE RHR SYSTEM PUT IN SERVICE. DUE TO RESIDUAL AMMONIA CONTAMINATION IN THE RHR THE CVCS DEMINERALIZER WAS BYPASSED FROM 0315 HOURS ON OCTOBER 1, 1982, TO 1759 HOURS ON OCTOBER 2, 1982. IODINE RELEASE AT THIS TIME PERIOD IS CONSISTENT WITH DATA REPORTED IN WESTINGHOUSE ELECTRIC CORPORATION WCAP-8637, "IODINE BEHAVIOR UNDER TRANSIENT CONDITIONS IN THE PRESSURIZED WATER REACTOR". DOSE EQUIVALENT IODINE-131 VALUES WERE IN THE "ACCEPTABLE OPERATION" PORTION OF TECHNICAL SPECIFICATION FIGURE 3.4-1 AT ALL TIMES DURING THE TRANSIENT. ALL APPLICABLE TECHNICAL SPECIFICATION ACTION ITEMS WERE MET DURING THIS TIME.

IN AN ATTEMPT TO PREVENT RECURRENCE, FUEL SIPPING WILL BE PERFORMED DURING THE UPCOMING REFUELING OUTAGE IN AN EFFORT TO LOCATE AND REPLACE THE LEAKING FUEL ASSEMBLIES.

ATTACHMENT TO LER# 82-079/03L-0

SUPPLEMENT TO CAUSE DESCRIPTION (CONT'D)

FUEL BURNUP BY THE REGION AND ALL ADDITIONAL DATA, AS REQUIRED BY TECHNICAL SPECIFICATION 3.4.8, IS FOUND IN THE ATTACHMENTS.

\*COOLANT SAMPLES ARE BROUGHT TO AMBIENT CONDITIONS PRIOR TO COUNTING; THEREFORE UNITS OF  $\mu\text{Ci}/\text{gram}$  AND  $\mu\text{Ci}/\text{cc}$  ARE CONSIDERED INTERCHANGEABLE.

BURNUP CALCULATION SUMMARY SHEET  
D. C. COOK UNIT 2

UNIT NO. 2

REPORT NO. 19

CYCLE NO. 3


DATE OCTOBER 14, 1982

PERIOD 01JUL82-30SEP82

REGION NO	BURNUP FOR PERIOD (MWD/MTU)	CUMULATIVE BURNUP (MWD/MTU)	ENERGY FOR PERIOD (BTU)	CUMULATIVE ENERGY (BTU)
1	0.1538E+04	0.2562E+05	0.1217E+13	0.2029E+14
2	0.2885E+04	0.3052E+05	0.8688E+13	0.9191E+14
3	0.2815E+04	0.1601E+05	0.9718E+13	0.5526E+14
CORE TOTAL	0.2705E+04	0.2308E+05	0.1962E+14	0.1675E+15

UNIT 2 REMOTOR COUNT Dosed I-131 ( $\mu\text{Ci/cc}$ ) vs Time

DAVID C. COOK NUCLEAR UNIT



DIETZGEN CORPORATION  
MADE IN U.S.A.

Dose 60  
I-131  
 $\mu\text{Ci/cc}$   
NO. 3412 1710 DIETZGEN, INC.  
3 CYCLES X 1000 RPM  
DEM. 10000100

$\times 10^{-7}$

9-29-82


9-30

10-1

10-2

10-3

10-4-82



DIETZEN CORPORATION  
 MADE IN U.S.A.  
 % Over

LE Down  
 GPM  
 DIETZEN GRAPH PAPER  
 120  
 75




FIGURE 3.4-1

DOSE EQUIVALENT I-131 Primary Coolant Specific Activity Limit Versus Percent of RATED THERMAL POWER with the Primary Coolant Specific Activity  $> 1.0 \mu\text{Ci}/\text{gram}$  Dose Equivalent I-131