(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A L J M F 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 4 (7) | 1 0 0 1 8 2 (8) | 1 0 2 8 8 2 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0450 on 10/01/82, Containment Atmosphere Particulate Activity Monitor R-11 was
03 declared inoperable when the indicator failed low. Tech. Spec. 3.4.7.1, in part,
04 requires R-11 to be operable. Tech. Spec. 3.4.7.1 action statement requirements were
05 met. Health/safety of the public was not affected.
06
07
08

09 | SYSTEM CODE C I (11) | CAUSE CODE E (12) | CAUSE SUBCODE G (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE P (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 4 1 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN C (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER W 1 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This event was caused by a faulty low voltage power supply card. Following the replace-
11 ment of the power supply card, R-11 was declared operable at 0756 on 10/01/82.
12
13
14

15 | FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operational Event

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 | NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 | NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY
19 | TYPE Z (42) | DESCRIPTION (43) NA

PUBLICITY
20 | ISSUED N (44) | DESCRIPTION (45) NA

8211060085 821028
PDR ADOCK 05000364
S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III PHONE (205) 899-5156