

NUCLEAR REGULATORY COMMISSION

T-1147

ORIGINAL

In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

 SUBCOMMITTEE ON RELIABILITY AND PROBABILISTIC
 ASSESSMENT

DATE: November 3, 1982 PAGES: 1 - 231

AT: Washington, D. C.

*TR 4
delete B. white*

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
SUBCOMMITTEE ON RELIABILITY AND PROBABILISTIC ASSESSMENT

- - -

Nuclear Regulatory Commission
1717 H Street, N.W.
Washington, D.C.

Wednesday, November 3, 1982

The meeting of the Subcommittee on Reliability
and Probabilistic Assessment of the Advisory Committee
on Reactor Safeguards was convened at 9:00 a.m.

PRESENT FOR THE ACRS:

- WILLIAM KERR, Chairman
- DAVID OKRENT, Member
- DAVID WARD, Member
- MYER BENDER, Member
- JESSE C. EBERSGLE, Member
- J. CARSON MARK, Member
- CHESTER P. SIESS, Member

DESIGNATED FEDERAL EMPLOYEE:

R. SAVIC

- 1 ACRS CONSULTANTS:
- 2 P. DAVIS
- 3 E. EPLER
- 4 D. POWER
- 5 M. TRIFUNAC
- 6 D. PEDERSEN
- 7 J. MARCHATERRE
- 8 C. MUELLER
- 9 R. SEIDENSTICKER

10 ALSO PRESENT:

- 11 A. THADANI
- 12 E. CHELLIAH
- 13 S. ISRAEL
- 14 T. PRATT
- 15 I. PAPAZOGLU
- 16 S. VARGA
- 17 MR. KAUFMANN
- 18 S. ACHARYA
- 19 A. SCHWENCER
- 20 MR. MEYER

21
22
23
24
25

P R O C E E D I N G S

1
2 MR. KERR: The meeting will come to order.

3 This is a meeting of the Advisory committee on
4 Reactor Safeguards Subcommittee on Reliability and
5 Probabilistic Assessment.

6 My name is William Kerr. The other ACRS
7 members present at this point are Mr. Okrent, Mr.
8 Bender, and Mr. Ebersole. The consultants here present
9 for the Committee are Messrs. Davis, Epler, Power,
10 Pedersen, Marchaterre, Mueller, and Seidensticker.

11 Mr. Richard Savio is the Designated Federal
12 Employee for the meeting, which is being conducted in
13 accordance with the provisions of the Federal Advisory
14 Committee Act and the Government in the Sunshine Act.

15 Rules for participation in today's meeting
16 have been announced as part of the notice of the meeting
17 published in the Federal Register on Thursday, October
18 21, 1982. A transcript of the meeting is being kept,
19 and will be available by November 5, 1982.

20 I request that each speaker identify himself
21 and use a microphone.

22 We have received -- there is a "no" missing, I
23 think. Mr. Savio, the Designated Federal Employee,
24 there should be a "no" in here? We have received no
25 written requests for time to make oral statements.

1 We will proceed with the meeting, and I call
2 upon Mr. Thadani to orchestrate that part. That will be
3 the NRC staff presentation. Mr. Thadani.

4 MR. THADANI: My name is Ashok Thadani, NRR
5 staff. With me today are some members of staff as well
6 as consultants who have been supporting us in our
7 reviews that we have performed to date.

8 Before we get into summarizing the results of
9 our review of the Indian Point and Limerick risk
10 assessments, I would like to just take a few minutes to
11 give you some background on the motivation for
12 performing these studies.

13 MR. KERR: Excuse me. Is that mike on? It
14 is? Maybe you or it should get closer.

15 MR. THADANI: Is that better?

16 MR. KERR: I think so.

17 MR. THADANI: Following the TMI 2 accident,
18 the Commission deemed it necessary to reassess the
19 safety of all nuclear power plants with some special
20 emphasis on high population density sites, such as
21 Indian Point and Limerick. During the last two years,
22 several key events have taken place. I will list some
23 of them.

24 The Union of Concerned Scientists petitioned
25 to shut down Indian Point units. The NRR director

1 ordered implementation of interim measures which would
 2 improve the safety of the plants, and studies are under
 3 way to determine whether any additional actions would be
 4 necessary. The Commission decided that the operation of
 5 Indian Point units should not be suspended, but
 6 recommended that proceedings be initiated to primarily
 7 determine how the population around these sites would
 8 impact risk as compared to risks at other sites.

9 With this sort of a background regarding the
 10 concern with high population density sites, the
 11 licensees for Indian Point Units 2 and 3 and the
 12 Limerick applicants submitted PRA's for their plants.
 13 Along with their PRA's, they identified some
 14 modifications which they believed would improve the
 15 safety of these plants.

16 We have been reviewing these studies now for
 17 the past several months. The objective of our review is
 18 pretty similar in terms of both Limerick and Indian
 19 Point. There is a key difference. As far as the Indian
 20 Point review is concerned, the emphasis really is on
 21 reviewing the study and assisting us in the preparation
 22 of our testimony regarding the Indian Point facilities
 23 as it might compare with other sites, and in particular
 24 to assess the impact of proposed improvements which
 25 include the NRR director's order regarding interim

1 measures regarding how this would impact risk.

2 In terms of Limerick, about two years ago the
3 applicant was asked to perform a PRA by the NRC. The
4 concern again was the population around the site, and
5 the hope that if we were to go ahead and do a PRA early
6 enough, we might learn something from it and determine
7 if any actions might be needed in view of the high
8 population density around the site.

9 We have basically been assisted in the reviews
10 of these PRA's by two major labs with some other
11 subcontractors. Sandia has been assisting us in terms
12 of the review of Indian Point's risk study, in
13 particular that portion of the study that relates to
14 core damage accident sequences and their
15 quantification. Brookhaven National Lab has been
16 primarily supporting us in terms of the containment
17 analysis work.

18 In terms of Limerick, Brookhaven has been
19 reviewing and supporting us in all aspects of the PRA.

20 Our assessment of the core damage accident
21 sequences and their quantification -- when I say our, I
22 am referring to the Sandia assessment -- it is
23 essentially complete. Our testimony is still under
24 preparation for Indian Point. In terms of Limerick, the
25 preliminary analysis is complete. We just received a

1 draft report from BNL. BNL expects to complete its
2 review in about three months. The staff will complete
3 its review and evaluation by the summer of next year.

4 Today, we are ready to give you some summary
5 results of the assessments done so far. We will begin
6 with Indian Point and then move on to Limerick, if that
7 is acceptable to you. We could certainly switch it
8 around. Let me introduce Sam Israel, who will give us
9 his assessment of the Indian Point study.

10 MR. ISRAEL: Good morning. I guess I will
11 apologize. The first two pages on the handout are in
12 reverse order. I am also presuming that the Committee
13 and the consultants have seen the Sandia draft letter
14 report on Indian Point, the review of the Indian Point
15 study, the assumptions I am going to make.

16 (Slide.)

17 MR. ISRAEL: We requested Sandia to review the
18 Indian Point probabilistic safety study. They had about
19 three months to do this. Basically, their review
20 consisted of reading the IPPSS study and also bringing
21 to the review whatever experience Sandia personnel had
22 from previous PRA's. They did not do any de novo review
23 of the plant itself. So basically the information was
24 reviewing the IPPSS study and their own knowledge and
25 background.

1 My first slide deals with core melt
2 frequencies for both Units 2 and 3. Basically, my talk
3 will deal mostly with numbers. Sandia in its charter
4 was requested to revise or come up with their best
5 estimate of what the core melt frequencies were at the
6 units based on the review of the IPPSS study. I have up
7 here a table showing Units 2 and 3, the IPPSS value for
8 core melt frequencies, and the Sandia values.

9 MR. KERR: Excuse me. Is that what "revised"
10 means?

11 MR. ISRAEL: That's correct. Those are
12 Sandia's numbers. These numbers are as of September of
13 this year. These numbers were recorded in their report,
14 their draft letter report.

15 MR. KERR: Does revised imply that these have
16 now been discussed with the people who did the Indian
17 Point study, and there is general agreement that they
18 are more valid than the earlier ones, or does revised
19 simply mean these are the results reached by Sandia?

20 MR. ISRAEL: These were results obtained by
21 Sandia. They issued the report roughly September 1st.
22 The staff and the licensee had about one month to review
23 the Sandia report, and made comments on the report. We
24 had a meeting with the staff and the licensee in Sandia
25 in October, about two weeks ago, and now Sandia is in

1 the process of assimilating whatever that give and take
2 was in that October meeting and the information received
3 from various memos. They may or may not revise these
4 numbers that I have up here. They are scheduled to
5 provide a final report by December 15th.

6 So, these numbers I have here are the numbers
7 based on Sandia's initial review, some interaction
8 obviously with the licensee, interaction being getting
9 the information and bargaining, so to speak, with the
10 licensee as to whether these numbers seemed more
11 appropriate or not. These are as of September 31st, and
12 they could very well change, and in fact they will
13 change, and I will explain that later on in my talk.

14 Roughly, the internal for Indian Point 2 they
15 have increased by about a factor of two here. On Indian
16 Point 3 it is about a factor of two, about a factor of
17 four on the external, a factor of four. Overall it's a
18 factor of three increase in the estimated core melt
19 frequencies on both Unit 2 and Unit 3.

20 MR. DAVIS: Excuse me. A question.

21 MR. ISRAEL: Yes.

22 MR. DAVIS: In the review by Sandia, did they
23 look both for factors that would tend to decrease the
24 core melt probability as well as increase it? That may
25 sound like a trivial question, but it seems to me

1 that --

2 MR. ISRAEL: As a matter of fact, in my next
3 slide you will see they have increased the frequencies.
4 Whether they made a special point of looking for these,
5 I can't say.

6 MR. DAVIS: I found several conservatisms in
7 the study that would tend to decrease the result by the
8 applicant, and I am curious as to whether those things
9 were pursued in its review. Maybe we will find out.

10 MR. ISRAEL: We will find out.

11 (Slide.)

12 MR. ISRAEL: What I have tried to do here in
13 an overall vu-graph is to indicate what the dominant
14 types of events were that proposed the core melt
15 frequencies that were shown in the last slide. Roughly,
16 this is greater than 80 percent of the core melt
17 frequency. This is the IPPSS study. This is Sandia
18 (indicating). Seismic, fire, hurricane, tornado, LOCA,
19 recirc, station blackout. An additional one that Sandia
20 has picked up is component cooling water pipe break,
21 which I will discuss later on.

22 These comprise better than 80 percent of the
23 core melt frequency. For Unit 3, fire and LOCA during
24 recirc were the dominant sequences. Sandia also agreed
25 to those dominant sequences. They also picked up

1 component cooling water pipe break as a significant
2 contributor to core melt.

3 MR. BENDER: Are these in the order of
4 significance?

5 MR. ISRAEL: No, I just put them down.

6 MR. BENDER: Okay.

7 MR. ISRAEL: I guess the point I should make
8 is, there are a large number of external events
9 indicated in the dominant sequences.

10 MR. KERR: What is meant by partial station
11 blackout?

12 MR. ISRAEL: If you have a station blackout,
13 you lose off-site, you also lose on-site AC. You cover
14 off-site power some time into the event after core
15 melt.

16 MR. KERR: It is a short term station
17 blackout?

18 MR. ISRAEL: Yes, as opposed to -- well, I
19 have used this nomenclature. If you had a full station
20 blackout that extended for a long period of time, this
21 obviously gives you core melt. It also makes you
22 vulnerable.

23 MR. KERR: I was trying to understand how you
24 could have anything other than a full station blackout,
25 because station blackout to me means loss of power.

1 MR. ISRAEL: As I say, this is recovered some
2 time into the event.

3 MR. KERR: Partial means short-term.

4 MR. ISRAEL: Yes.

5 MR. BENDER: Sandy, one other question while
6 you have that up there. If I look just at the seismic
7 question, is the reason why it is dominant because the
8 anticipated probability of certain seismic events is
9 such that the higher events have not been designed for,
10 or what?

11 MR. ISRAEL: Yes, but let me get to that.

12 MR. BENDER: All right.

13 MR. ISRAEL: I just wanted to give you an
14 overview as to what the dominant sequences are. I have
15 made a point of not using alphabet soup so you can all
16 understand.

17 MR. BENDER: You get an A+ for that.

18 (Slide.)

19 MR. ISRAEL: I am going to go through the
20 units in order. I will go through Unit 2, and then Unit
21 3. This is Unit 2. This is for events that have
22 containment failure prior to core melt. I am going to
23 apologize. Indian Point has an interfacing LOCA at
24 about 5×10^{-7} . This is about an order of magnitude
25 less than what is in WASH 1400 for Surrey, the reason

1 being that you have extensive integrity checking of the
2 check valves, et cetera, in the interfacing lines.

3 This number has been revised somewhat after
4 interaction between Sandia and the licensee. They have
5 improved the data base. They have changed the modeling
6 a little bit. The number is still fundamentally the
7 same. Sandia has also identified another event that
8 would fall into this category. This is a steam
9 generator tube rupture with a stuck open secondary
10 safety valve. This is an outgrowth of the Ginna event
11 that happened roughly about a year ago, where the
12 operators continued to pump in high pressure injection,
13 and they filled up the secondary line and opened up the
14 safety valve, and there is always the potential for that
15 sticking open.

16 The core melt sequence here is that you have a
17 stuck open safety valve. Now you have a path outside,
18 and you just keep pumping in water from the refueling
19 water storage tank. That will take a good deal of time,
20 somewhere between 12 or 24 hours, before you run out of
21 refueling storage water. So that this then reflects
22 core melt frequency such that the operators have caught
23 on and somehow isolated the event or depressurized the
24 plant down to below 212 degrees, to that you are no
25 longer losing inventory and have RHR.

1 MR. BENDER: The result causes loss of
2 inventory water? You eventually run out of water? Is
3 that the idea?

4 MR. ISRAEL: That's right. That's right. It
5 will take a long time, somewhere between 12 and 24
6 hours. There should be another event on here, and that
7 would be a seismic event that takes out containment on
8 Unit 2. The frequency of that was somewhere around
9 6×10^{-7} . The revised estimate by Sandia would be
10 something like 10^{-7} . That event is an earthquake that
11 is larger than the safe shutdown earthquake, probably up
12 around one G. And there is a -- the earth is packed in
13 against the containment on Unit 2. I am talking about
14 backfill at this level earthquake interfering and
15 disrupting the containment, therefore losing cooling and
16 ultimate core melt.

17 MR. OKRENT: Question. Is the revised
18 estimate 10^{-7} or 10^{-6} for Sandia?

19 MR. ISRAEL: 10^{-6} . I am sorry.

20 MR. OKRENT: Another question. In its
21 comments on Zion, which was not unlike Indian Point,
22 Sandia noted that one could arrive at very large
23 uncertainties several orders of magnitude on interfacing
24 systems LOCA. What is not clear to me is how Sandia
25 arrived at its number, in view of its comment about the

1 large uncertainties that exist and how one might
2 interpret the available data. Did it occur to you?

3 MR. ISRAEL: Let me address that.

4 MR. CKRENT: I read what is in the letter
5 report. I agree you can follow a recipe and get a
6 number. That's not my question.

7 MR. ISRAEL: I understand. When we are here
8 on Zion, the information basically we are using was the
9 information coming from WASH-1400. Interaction with PLG
10 basically back in June said we have this open-ended
11 situation. They went back and they interpreted
12 available information. This interpretation dealt with a
13 logical inference about check valves and the fact that
14 if the check valves were leaking or had failed, that
15 would be noted by some other perturbation in the
16 system.

17 I cannot give you what this logic was, but
18 using that, they were able to go back and go over the
19 available history and come up with new numbers for the
20 leak failure rate, or not the leak failure rate, the
21 rupture failure rate of the check valves, which was an
22 important ingredient.

23 Having data like that also allowed them to
24 have much tighter uncertainties on that type of
25 information. That was for the check valves. The other

1 important ingredient was the suction line, which has two
2 motor operated gate valves. The sequence there that we
3 are concerned about is that the operator failed to close
4 one of the gate valves, and they were sitting there on
5 one of the other gate valves and that ruptured.

6 The key to it was the probability of having a
7 gate valve, one of those gate valves left in an open
8 position. That could only occur -- the position
9 indication was downstream of the system. If the motor
10 had engaged from the valve stem, then you could
11 potentially get an erroneous position indication. PLG
12 went back and they looked through the available
13 literature on the number of times the gear linkage
14 between the motor and the valve stem had become
15 disengaged, and they were able to come up with a better
16 estimate as to what the initial probability of having an
17 erroneous indication would be, so they came up with
18 tighter uncertainty bounds, and that made that problem
19 go away.

20 As you recall, the problem with Zion was, what
21 is the uncertainty on something that basically has not
22 happened? For most of what the licensees have done on
23 Zion, they had taken WASH-1400 and made it 20, 80, or
24 whatever the bounds were, as opposed to 595, which was
25 in WASH-1400, except for this valve situation.

1 Obviously, that gives you tremendously different
2 numbers. However, you are still guessing at what the
3 upper bound is on the situation. Nobody ever arrived at
4 what the correct number bound was for that. We finessed
5 this. We finessed this by going back and developing
6 better data and coming up with tighter estimates.

7 MR. KERR: Now I am confused. I thought you
8 were asking how Sandia arrived at uncertainty
9 estimates. Did I misunderstand your question?

10 MR. ISRAEL: Sandia didn't arrive at
11 uncertainty estimates. The question was, the
12 uncertainty as large as discussed on Zion. The answer
13 is no, because at least in this revised estimate, which
14 was really an interaction with the licensee, the
15 licensee has come up with tighter estimates of what the
16 failure probabilities are for the check valves, and also
17 for leaving the gate valve open.

18 MR. OKRENT: He has answered the question, but
19 I'm not sure whether we have available a critique of the
20 new method. They have gone at getting data, more
21 detailed data, a different way on specific failure
22 modes, and there was very little information on that in
23 the letter report.

24 MR. EBERSOLE: Can I ask a question? Sandy,
25 do these studies account for the fact that you never

1 know whether these check valves are in proper closed
2 position or not?

3 MR. ISRAEL: Yes. Which studies are we
4 talking about?

5 MR. EBERSOLE: These studies themselves.

6 MR. ISRAEL: These reflect that the check
7 valves are leak tested after they are disturbed.

8 MR. EBERSOLE: No, I mean they are stuck flat
9 open and that leaves you vulnerable to a spurious
10 opening, to the only other opening of the low pressure
11 system, the motor valve. You don't have indicators as
12 to where the valve disc is at all.

13 MR. ISRAEL: I go down, I am called to do my
14 refueling, I go back up. When I go back up, I leak test
15 the check valves so I know they are in position. I know
16 I have integrity.

17 MR. EBERSOLE: Every time you upset them, you
18 do that?

19 MR. ISRAEL: That's right. Every time I go
20 back up I am testing these valves.

21 MR. EBERSOLE: So you ascertain that they are
22 bounded by the leak test, and in fact they have not been
23 upset.

24 MR. ISRAEL: That's right.

25 MR. OKRENT: That is something that actually

1 is done, or is something that will be done? And if it
2 is done, how long has it been done -- I am just sort of
3 curious -- for these plants?

4 MR. ISRAEL: That was required by the Denton
5 order of '81, I guess. I cannot tell you how many times
6 it was done over the past year and a half. Both plants
7 are down now, so when they go back up, they will go back
8 into that mode.

9 (Slide.)

10 MR. OKRENT: To some extent, I think it is of
11 interest, although not something that we can try to
12 answer today, for the NRC not only to get an evaluation
13 of what they think the risk will be, given certain
14 things that are promised will be done, but what it was
15 even prior to TMI 2. Let me just leave that as a
16 thought. How much change has occurred, if any, and due
17 to what? Okay.

18 MR. ISRAEL: Okay, on this slide here, I have
19 core melt with no containment cooling. I have tried to
20 put these slides in order of reduced potential risk.
21 Obviously, containment failure prior to core melt gives
22 me potentially the highest significant risk. I have
23 core melt with no containment cooling. This obviously
24 gives me potential problems with risk situations. These
25 revised again are Sandia September 1st seismic.

1 For Unit 2, the seismic event was the Unit 1
2 control building or superheater building banging into
3 the roof of Unit 2 control building, failing the roof,
4 incapacitating the operators in the control room, thus
5 going to core melt because there is no one minding the
6 shop. That occurred at a medium capacity at about .26,
7 and these plants safe shutdown earthquake was about .15,
8 something like that.

9 Sandia's consultant was the same chap who
10 reviewed Zion, John Reid, or Pat Benjamin Associates,
11 anyway. He looked at the seismic portion and you can
12 see the core melt frequency has increased by a factor of
13 two. The reason for this is, there were two different
14 hazards curves presented in the IPPSS study performed by
15 the consultants for the licensee at the point of
16 sustained peak acceleration. One of the studies was
17 about an order of magnitude lower than the other study.
18 The licensee simply weighted both the same and divided
19 them by two and came up with whatever their hazard curve
20 was, whereas Sandia's consultants said they were
21 somewhat skeptical about the hazards curve. It was an
22 order of magnitude lower than the other one, so they
23 discounted that completely, so there was no averaging,
24 thus the difference of two core melt frequency.

25 MR. KERR: Why were they skeptical of the

1 lower one?

2 MR. ISRAEL: I cannot answer that. Buck, can
3 you?

4 MR. ABRAHAM: Buck Abraham, NRR, Geosciences
5 Branch. The magnitude or the intensity used in the
6 study was a little bit low, and the zonation signal for
7 the tectonic province will not be completely represented
8 for the area around Indian Point. They used an
9 intensity of seven, and we used the deterministic
10 method. We think that intensity seven was low for the
11 area. The values estimated was around an order of
12 magnitude less.

13 MR. KERR: You have told me that you think the
14 intensity of one is less than the other, and I still do
15 not know how one decided which is a more nearly valid
16 result. The staff's judgment is that it should be eight
17 rather than seven?

18 MR. ABRAHAM: That's true.

19 MR. KERR: Sandia apparently researched that
20 conclusion independently.

21 MR. ABRAHAM: Yes, and the intensity is more
22 representative of this area.

23 MR. ISRAEL: Fire (indicating). The fires
24 that I have here basically are fires that take out
25 cooling to the reactor coolant pump seals which then

1 fail. They take out the high pressure injection pumps
2 and the ECCS pumps so that you cannot provide cooling
3 after you have this LOCA, and no containment cooling, so
4 therefore I've taken out the service water pumps or the
5 fan coolers or the component cooling water pumps, and I
6 have left myself pretty high and dry with this event.

7 MR. KERR: How would that number compare with
8 one that one would have used prior to the NRC's fire
9 protection limit in 10 CFR 50?

10 MR. ISRAEL: This represents -- since I don't
11 think the licensee has made any modifications with
12 respect to Appendix R yet, this represents what it would
13 look like without Appendix R modifications.

14 MR. KERR: Is the licensee required to make --

15 MR. ISRAEL: Yes, I will try to touch on
16 that. The licensee's analysis was based on a general
17 area fire in tunnels and switchgear rooms and whatever
18 have you that takes out all this electrical equipment.
19 Sandia, based on its experience in the fire area, was
20 concerned about a hot gas layer, a layer such that if
21 you have a fire any place the gases formed go to the
22 ceiling, and that the cabling through their experience
23 would fail at temperatures lower than the ignition
24 temperature of the cabling itself.

25 Therefore, this would essentially enlarge the

1 area, the fire area that would catch the essential
2 electrical equipment, and that has increased by a factor
3 of three.

4 MR. KERR: The insulation would melt rather
5 than ignite?

6 MR. ISRAEL: That's right, would short out.
7 That's my understanding.

8 MR. KERR: Insulation doesn't short out. I
9 was concerned about what would happen to the insulation
10 before it ignited.

11 MR. EBERSOLE: You mean not that it softens
12 and the conductors merge? Is that right?

13 MR. ISRAEL: I don't have any fire people
14 here. There were tests run at Sandia dealing with
15 certain cabling --

16 MR. EBERSOLE: You can melt the insulation
17 before you burn it.

18 MR. ISRAEL: -- that resulted in shorting out
19 of the cabling at temperatures lower than the ignition
20 temperature of the cabling, but that exact mechanism I
21 can't tell you about.

22 MR. EBERSOLE: Does that also mean other
23 provisions in Appendix R haven't been put in at this
24 point?

25 MR. ISRAEL: As I said, this doesn't reflect

1 Appendix R. The licensee for Unit 2 has proposed
2 modifications approximately a month ago that will
3 undoubtedly reduce these core melt frequencies.

4 MR. KERR: Is there any estimate of how much
5 of a reduction will be produced by Appendix R?

6 MR. ISRAEL: The licensee has estimated that
7 it would go down, let's see, by about a factor of 20, I
8 believe.

9 MR. KERR: Twenty?

10 MR. ISRAEL: Right.

11 MR. BENDER: What are we starting from,
12 Sandy? What is the fire frequency that exists, and how
13 much are we improving it by Appendix R?

14 MR. ISRAEL: The fire frequency is whatever it
15 is. You have these general -- they are talking about
16 potential for general fire in the tunnel in the switch
17 gear room.

18 MR. BENDER: The probability of one?

19 MR. ISRAEL: Improvements are such that you
20 bypass the electrical tunnel, the switch gear room, and
21 these general fire prone areas entirely, and you now
22 provide electrical equipment to essential equipment.
23 The fire frequency in these areas hasn't changed. It
24 just bypasses it.

25 MR. BENDER: If you are talking about an

-4

1 improvement of 10 to ten to the minus something or
2 other, you start first with some probability of a fire,
3 then some probability that the fire will damage it in
4 this location, and the damage will be to such a degree
5 that it leads to core melt. That is the logic. I was
6 trying to put the things together, and I guess I don't
7 know where they're put together. Where are they put
8 together?

9 MR. ISRAEL: Right in here. You have the
10 frequency of the fire, the conditional probability that
11 the fire was large enough that it envelopes the
12 essential equipment.

13 MR. BENDER: I just asked what was the
14 frequency of the fire. I know you don't know, and I
15 just wonder where would I find it if I wanted to know
16 it.

17 MR. ISRAEL: That would be in Chapter 7 in the
18 IPPSS report, 2073, something like that.

19 MR. OKRENT: The Appendix R provisions
20 minimize or preclude the possibility of this hot gas
21 streaming effect?

22 MR. ISRAEL: I don't think Appendix R
23 addresses the mechanism for the fire.

24 MR. OKRENT: This is not a mechanism for the
25 fire.

1 MR. ISRAEL: I meant the mechanism for failing
2 the equipment. Appendix R says thou shalt have a fire
3 and it takes out essential equipment, provide me an
4 alternate scheme.

5 MR. OKRENT: But it has certain separation
6 requirements. I was just wondering whether they
7 included this phenomenon.

8 MR. ISRAEL: I'm afraid I cannot answer that,
9 Dr. Okrent. I don't see anybody here from the staff who
10 would be familiar with that.

11 MR. BENDER: Well, in the sense that they
12 don't identify the probability that the barriers are
13 going to be violated so that you get hot gas streaming,
14 they don't pay any attention to them. There may be some
15 implicit reliability in the barriers that isn't stated.

16 MR. EBERSOLE: Sandy, was there in this study
17 a consideration of a fire in the spreading room and the
18 control room?

19 MR. ISRAEL: Yes, in the spreading room, the
20 tunnel, the licensee's response about a fire in the
21 control room was that that would be a fire that would
22 affect enough equipment with no core containment
23 cooling. The frequency of that would be less than this
24 frequency. That was a judgment.

25 MR. EBERSOLE: Does this plant have an

1 auxiliary shutdown room that anticipates a disruption of
2 the control room?

3 MR. ISRAEL: Yes. I guess I wouldn't call it
4 a single auxiliary shutdown. They have panels at
5 various locations in the auxiliary building.

6 MR. EBERSOLE: Are they backwired into the
7 control room circuit boards?

8 MR. ISRAEL: I don't know.

9 MR. EBERSOLE: That's the critical thing. Old
10 GDC 19 let them do that. They did that because they
11 were allowed to. It produces an invalid concept of
12 protection.

13 MR. ISRAEL: I would presume -- this is a wild
14 presumption on my part -- that the people who are
15 looking at Appendix R are concerned about the ability to
16 operate the equipment.

17 MR. EBERSOLE: Can anybody here answer whether
18 or not the plant can be shut down in the absence of
19 functional capability out of the control room?

20 (No response.)

21 MR. KERR: I see no volunteers. Please
22 continue.

23 MR. ISRAEL: Hurricane. Unit 2 has metal
24 sheathed buildings for the diesel generator and for the
25 control room. The licensee had estimated a core melt

1 frequency with no containment cooling of about
2 3×10^{-5} . That is basically you lose off-site power.
3 You also take out your diesel generator, because of the
4 metal sheathed building, and that would give you that
5 kind of core melt frequency.

6 Sandia's consultants analyzed it and said, no,
7 it is higher, about a factor of 20 higher. Two of that
8 is due to the fact that the Sandia consultant believed
9 that for hurricanes of any magnitude, you were going to
10 lose off-site power, so there's a factor of two
11 associated with off-site power. The Sandia consultant
12 also had a more recent NBS hurricane hazards curve that
13 would indicate a much higher frequency of winds. I
14 think it is 200 kilometers in from the coast, whatever
15 it is, so they have re-estimated the hurricane as being
16 20 times higher than the Indian Point estimate.

17 Tornado, there was no difference, the analysis
18 being acceptable.

19 MR. BENDER: Where would an ice storm fit into
20 that same scenario? We have had icing conditions that
21 have knocked out off-site power as well.

22 MR. ISRAEL: That's loss of off-site power.

23 MR. BENDER: What is the difference between
24 that and the hurricane?

25 MR. ISRAEL: It has torn the siding off the

1 diesel generator building, and you've got pouring rain
2 and water, and you fail the off-site emergency power.

3 MR. BENDER: It is the structural integrity of
4 the housing.

5 MR. EBERSOLE: You mean they have a tin house
6 around the diesels? That's the way it's done?

7 MR. ISRAEL: It is metal sheathed, as opposed
8 to being concrete.

9 MR. EBERSOLE: Well, the implications of that
10 snoddy design ought to be noticed with respect to other
11 features of the plant.

12 MR. KERR: They put metal sheaths around
13 them.

14 MR. EBERSOLE: Rolled metal bed.

15 (Slide.)

16 MR. ISRAEL: These are dominant core melt
17 sequences for core melt with containment cooling.
18 Containment cooling for this plant can either be fan
19 coolers or they have sprays. I guess there were only a
20 couple of things I wanted to mention here. The LOCA
21 failure and recirculation mode, the Sandia estimate is
22 about three times higher than the IPPSS estimate, and
23 that has to do with the estimate of operator error,
24 switching over from injection to recirculation for the
25 large and medium LOCA's.

1 Another event that Sandia has picked up is a
2 break in the component cooling water pipe. Indian Point
3 plants, both of them, have headed together their -- each
4 plant individually has their component cooling water
5 headed together, so that the two or three component
6 cooling water pumps can feed water into this headed
7 piping system that would provide water to whatever the
8 auxiliaries were as opposed to some where you have
9 redundancy and one is only providing it to one train of
10 the ECCS, et cetera. So this is functionally
11 redundant.

12 The IPPSS report did look at a failure of the
13 component cooling water pumps as an initiating event,
14 and its probability of going to core melt. The
15 frequency for that was rather low. So we postulated,
16 all right, we have this headed together system. If we
17 had a pipe break in the component cooling water, I would
18 then lose the ability to cool the reactor coolant pump
19 seals. This plant or the analysis of this plant -- it's
20 a Westinghouse plant -- indicated that based on the
21 information put forward, that the pump seals would fail
22 within a half-hour if they didn't have cooling.

23 This obviously goes to a LOCA.

24 MR. KERR: What is meant by a pipe break in
25 this context, that the pipe is broken so seriously --

1 MR. ISRAEL: All the water runs out of the
2 component cooling water system. It has about 23,000
3 gallons.

4 MR. KERR: This is a system that operates at
5 roughly what pressure?

6 MR. ISRAEL: I don't know, 50, 100 psi. It is
7 a low pressure system.

8 MR. KERR: And the probability of that pipe
9 break is assumed to be about what?

10 MR. ISRAEL: Well, herein lies one of the
11 difficulties. The values that were used were the pipe
12 break frequencies that IPPSS had provided, the general
13 pipe break frequencies that ultimately go back to
14 WASH-1400, whatever that data base was in WASH-1400.
15 For such a low pressure system, one would think that
16 those are obviously conservative, those pipe break
17 frequencies. WASH-1400 pipe break frequencies were
18 geared to high energy piping systems, and this probably
19 doesn't qualify.

20 MR. BENDER: Let's look at some other aspects
21 of it. Do we have a discovery probability in this
22 thing? Presumably this is a correctable condition, if
23 you have time to correct it.

24 MR. ISRAEL: I only have a half an hour. Here
25 is the problem. Component cooling water cools the

1 reactor coolant pump seals directly. I can also cool
2 the reactor coolant pump seals with injection from the
3 charging pumps. However, the charging pumps need
4 component cooling water for their system, so even if I
5 had a LOCA, my HPSI pumps would mitigate the LOCA.
6 However, the HPSI pumps need component cooling water for
7 their cooling.

8 Now they do have a backup system for both the
9 charging pumps and the HPSI pumps. They can connect
10 city water. But that means they have to run
11 downstairs. There is a spool piece. They have to bolt
12 in a piece of pipe, put in a valve, and that is probably
13 not going to happen in a half an hour.

14 MR. BENDER: And the component cooling water
15 lines that results from a half-hour time is about what
16 size?

17 MR. ISRAEL: I don't have the answer for that.
18 Those are the major items for that.

19
20
21
22
23
24
25

1 [Slide]

2 MR. ISRAEL: I will quickly go through Unit
3 3. The discussion for this would be the same as I
4 described for Unit 2, and I'm not going to go over it
5 again.

6 [Slide]

7 The fire situation for Unit 3 core melt
8 no-containment cooling is the same. Let's see. Fire is
9 the same as I discussed on Unit 2. The hot gas layer
10 situation. Seismic is a little bit different
11 situation. The seismic analysis here that the Indian
12 Point people presented was for a failure of the diesel
13 fuel oil tanks in the lines leading to the diesel
14 generators.

15 If we have a seismic event, we are going to
16 lose offsite power. This would essentially take out the
17 emergency power.

18 The Sandia consultant, after having been
19 sensitized to the roof falling in on Containment 2 and
20 incapacitating the control room, looked at the ceiling
21 in Unit 3 and it has the same type of ceiling that we
22 have here. These panels, the immediate ceiling above
23 the operators is egg crating. However, there is another
24 false ceiling probably about 5 feet above that that is
25 made of 50-pound panels.

1 I guess the consultant was from California and
2 I guess ceilings always fall in every time you have
3 earthquakes in California, so he estimated what the
4 conditional probability would be for the ceiling falling
5 in on Unit 3. This has nothing to do with banging of
6 one structure against another. This just has to do with
7 the earthquake rocking the grid structure such that the
8 panels fall through and incapacitate the operators.
9 That is why there is this larger difference. The factor
10 of 2 has to do with the weighting factor on the hazards
11 curve.

12 The tornado is the same. Those were the
13 dominant events.

14 MR. BENDER: Which earthquake are we talking
15 about?

16 MR. ISRAEL: This would be up around .6, .8
17 median capacity. This will probably be .80, I guess.

18 MR. EBERSOLE: Sandy, in your control room you
19 spoke about the ceiling being egg crate. Is there a
20 illumination by fluorescent tubes?

21 MR. ISRAEL: Yes, but they are not like this.
22 They are located above the egg crating. Is that right,
23 Buck; they don't have these light fixtures? The light
24 fixtures, the illumination comes from fluorescent tubes
25 above the egg crating.

1 MR. EBERSOLE: Does the egg crating stay in
2 place in a seismic event?

3 MR. ISRAEL: Well, that would obviously come
4 down, too.

5 MR. EBERSOLE: Well, while you always have
6 seismic fixtures for the tubes, the tubes always fall
7 out. Does this lead to implications of a monstrous
8 version where we had one light fixture that fell into a
9 control board?

10 MR. ISRAEL: I don't think so. That light
11 fixture was the bulb. I'm talking about everything
12 coming down. I think that's a different situation.

13 MR. EBERSOLE: Well, my impression is the
14 tubes come out in seismic events. Whether they get to
15 the floor or not is another matter.

16 [Slide]

17 MR. ISRAEL: Okay, moving right along. To
18 answer the question that was asked about production --
19 this is Unit 3 core melt with containment cooling at
20 Sandia. Small LOCA and failure of high pressure
21 recirculation mode. The licensee's analysis looked at
22 the failure data for a high pressure injection pump, and
23 they had one operating failure in something like 40
24 hours.

25 This was during the testing period for a

1 half-hour or hour at a time. One of the pumps obviously
2 had a failure in some amount of time. It gave them a
3 rather high failure rate in a 24-hour period, which
4 resulted in coming up with this frequency for the
5 failure in the high pressure recirculation system.
6 Sandia said they weren't any different on Unit 3 for
7 Unit 2, and Unit 2's pumps had gone, I don't know, 600
8 hours, whatever the number happens to be, without any
9 failures.

10 So they averaged the data together and said
11 they thought that a better estimate would be a lower
12 failure rate for the pumps to run for 24 hours. So the
13 core melt frequency for this was reduced by about a
14 factor of 5. Medium and large LGCAS increased again
15 because of human error in switching from injection to
16 recirculation. The component cooling water pipe break
17 is included here.

18 Those are about the principal features of this
19 slide. Are there any questions?

20 [No response.]

21 That is about all I have to say.

22 MR. KERR: Are there questions?

23 MR. EBERSOLE: One more question. Sandy, you
24 showed a number that the tornado potential is 9.2 x
25 10 and loss of all AC was 5. The relationship

1 between those, does that mean that the important tornado
2 damage is more than just loss of AC power?

3 MR. ISRAEL: My recollection -- I'm talking
4 off the top of my head -- is that that tornado took out
5 the service water pumps.

6 MR. EBERSOLE: That would account for the
7 larger number.

8 MR. OKRENT: Is there a summary available of
9 what transpired in this meeting on September 1?

10 MR. ISRAEL: Yes. In fact, I have put
11 together some of the memos for you, Dr. Okrent. I
12 didn't bother putting that one together because the
13 indication on the fly sheet was that ten copies were
14 sent to the ACRS.

15 MR. BENDER: Let me ask a couple of questions
16 just for clarification.

17 MR. ISRAEL: Yes, there is a memo available.

18 MR. OKRENT: What were the principal outcomes
19 of the discussion, would you say, or what are the things
20 that you expect to receive major reconsideration, if
21 anything, and so forth?

22 MR. ISRAEL: I don't think that the Sandia
23 numbers are going to change because of the interaction
24 at that October meeting. The Sandia numbers may change
25 because at that meeting the licensee offered up his

1 Appendix R modifications for Unit 2. He also offered up
2 a fix for the roof banging together, so the Sandia
3 numbers would probably change because of specific
4 modifications that the licensee is proposing.

5 MR. KERR: I'm sorry, I don't understand the
6 "offering up the fix for Appendix R." Did you mean to
7 say he was going to implement those?

8 MR. ISRAEL: That's right. Everybody is going
9 to implement Appendix R, but he said this is my Appendix
10 R modification. This is what I propose to do to meet
11 Appendix R.

12 MR. BENDER: If you meet Appendix R and you
13 make the structural fix that is being suggested, what
14 answer do you get?

15 MR. ISRAEL: Okay. You want me to postulate
16 for you. That's what I'm supposed to do. Let's see.
17 Here is core melt no containment cooling.

18 [Slide]

19 These numbers dominate the core melt
20 frequencies. So we are going to knock down seismic, we
21 are going to knock down the fire, but we are still left
22 with hurricane. The Sandia consultant after this
23 meeting -- or actually before this meeting was in the
24 process of evaluating what the hazards curve is for a
25 hurricane at the Indian Point site.

1 The licensee also has a program going on, an
2 additional study to evaluate what the hazards curve is,
3 what the fragilities are, actual fragilities with the
4 building, the effect of other buildings in the area, a
5 much more refined and intense study to come up with a
6 better handle on the hurricane number.

7 Mr. Denton, at the time the study came out,
8 when he saw these numbers instituted that he would be
9 alerted when a hurricane of that magnitude was moving up
10 the coast and could threaten New York, and at that point
11 he would potentially take action. Conceivably, if one
12 shut down the plant x hours before a hurricane arrived,
13 even if it took out all electrical, you could be so well
14 cooled that you probably could exist for many hours
15 without having to do anything.

16 MR. KERR: I'm sorry?

17 MR. ISRAEL: There were two courses of action:
18 sharpen your pencil or do something pragmatic.

19 MR. KERR: Are you talking simply about a
20 conjecture or about a possibility?

21 MR. ISRAEL: Evidently we are tied into --

22 MR. KERR: I know you have warnings, but I
23 thought you said Mr. Denton might see a hurricane
24 somewhere down in South Carolina and decide to shut down
25 Indian Point. Is that for real; that is not just

1 over-coffee talk?

2 MR. ISRAEL: Mr. Denton is supposed to be kept
3 apprised of hurricanes moving up the coast, and his
4 actions will depend upon what his interactions are with
5 the meteorology people, et cetera.

6 MR. OKRENT: The seismic review of the Indian
7 Point PRA sort of broke its comments into three
8 categories. It was less than a factor of 2. It was sort
9 of treating them as small and things that you might not
10 carry along, if I recall correctly. If it was 2 to 10,
11 it was moderate; larger than 10, it was big. They
12 mentioned a variety of things that might introduce a
13 factor here or there. Sometimes the factor was only
14 qualitatively assessed, most of the time.

15 The seismic contribution isn't small no matter
16 which column you are looking at, so in fact a factor of
17 2 on that number is really quite different, for example,
18 than a factor of 2 on Event V. In fact, it is different
19 by more than a factor of 100 on what is presented here.
20 How does the staff propose to get some kind of a
21 quantitative handle on the other items mentioned in the
22 seismic review but not included in this particular
23 revision?

24 MR. ISRAEL: At this point in time, Sandia is
25 supposed to, when it complete its report in December, is

1 supposed to come up with estimates of uncertainty. The
2 extent to which they encompass all those qualitative
3 aspects, I cannot say.

4 MR. OKRENT: It may be that the dominant event
5 doesn't have a big uncertainty; that's possible. But in
6 reading it, there are things left open. Similarly, as
7 indicated in the hurricane discussion, it was sort of --

8 MR. ISRAEL: You see, we are always going to
9 have this problem, Dr. Okrent. When you talk about
10 uncertainty and ignorance, it is always going to be
11 there. All we can do is try to estimate. The licensee
12 at the meeting didn't even want to argue about this
13 factor of 2. He said, look, I'm going to put a bumper
14 in, I'm not going to quibble about whether it's 2 or 4
15 or whether my number is right. I'm going to put a
16 number in, I'm going to correct it.

17 Similarly the fire situation. The hot gas
18 layers. There is lot of argument going on about whether
19 -- exactly what type of cable is affected and whether
20 that hot gas layer only affects a foot from the ceiling,
21 what have you. The licensee is coming up with proposals
22 and saying, look, given that I have a failure of all my
23 electrical in that area, I'm going to provide an
24 alternate that will provide specific functions that I
25 need, so if there is a fire in that area, regardless of

1 what its frequency is, I'm going to have an alternate
2 route. I guess in a sense we are being better served by
3 the people moving forward rather than just sharpening
4 their pencils.

5 MR. KERR: Can you put that comment in the
6 context of Appendix R? Is the applicant going to make
7 changes because of this PRA or is he going to make
8 changes that would have been required by Appendix R for
9 both or neither?

10 MR. ISRAEL: Both.

11 MR. KERR: So there are some things he will do
12 because of this PRA that he would not have done just
13 because of Appendix R?

14 MR. ISRAEL: I think what this study has
15 pointed out, and people may quibble with what I'm about
16 to say, is they said, look, if I don't have cooling to
17 my reactor coolant pumps for a half-hour, I have a LOCA
18 and I have to provide cooling for that, so this opened
19 up a whole new area in terms of component cooling water
20 and providing HPSI, providing the HPSI capability in the
21 event that you had a fire.

22 Prior -- I will make this a guess -- prior to
23 this study, people probably were fixating on probably
24 only the auxiliary feedwater system, so that I will
25 guess that this study, then, has opened up the potential

1 for another area to pay attention to in Appendix R.

2 MR. EBERSCLE: May I ask a question, Sandy?
3 If the five items there on the right, or four, rather --
4 we know they are not the totality of all the matters
5 that will produce core melt with no containment cooling,
6 but at least it is some of them. Those numbers up there
7 indicate that something has got to be done, lots of
8 things have got to be done. They sum up to an
9 unacceptable totality. What is contemplated?

10 MR. ISRAEL: Like I told you, that the
11 licensee has proposed a bumper and has proposed
12 something here in the fire space that will reduce those
13 two numbers.

14 MR. EBERSCLE: Those two? What about the top
15 number?

16 MR. ISRAEL: The licensee is sharpening his
17 pencil on that. The licensee is over here in this
18 space. He is over here (indicating). Mr. Denton is --

19 MR. EBERSCLE: When is he proposing to do
20 something?

21 MR. ISRAEL: The licensee's analysis or
22 reevaluation of the hurricane is January -- the dates
23 keep slipping.

24 MR. EBERSCLE: PWRs are supposed to have a
25 remarkable capability for staying in hot standby with

1 just a little bit of water and a little bit of power.
2 Evidently this shows that this one is not rigged to do
3 that. I'm talking about the secondary coolant to
4 atmosphere. What you are evidently telling me is that
5 seal cooling is not provided for in that mode, that they
6 need service water.

7 MR. ISRAEL: That is right.

8 MR. EBERSOLE: They need service water, which
9 is lots of power. They can't get along on a feedwater
10 pump.

11 MR. ISRAEL: They don't have electricity.

12 MR. EBERSOLE: They lose their major source of
13 electricity and they don't have any minor source to run
14 the small auxiliaries if necessary.

15 MR. ISRAEL: That's right.

16 MR. EBERSOLE: Which is no big deal to provide.

17 MR. KERR: Was it the case at Indian Point 2
18 that subsequently one did not have to take into account
19 the effects of hurricanes?

20 MR. ISRAEL: I can't answer that. Indian
21 Point 3 --

22 MR. KERR: I can't understand why one would
23 have to design for tornadoes but not for hurricanes.

24 MR. ISRAEL: That is out of my area. I'm not
25 able to address that. I don't see anybody from the Staff

1 that is here on that.

2 MR. KERR: I am trying to discover what the
3 PRA would reveal that the requirements for an emergency
4 diesel wouldn't have taken care of. What is it about
5 the PRA that an emergency diesel is supposed to
6 function --

7 MR. ISRAEL: I don't know this hurricane is --

8 MR. KERR: It is not unusual to talk about
9 hurricanes up the east coast.

10 MR. ISRAEL: I'm not familiar with what the
11 design criteria are for hurricanes in plant design
12 criteria. I can't answer that. And there isn't anybody
13 here on the Staff that works in that area here today.

14 MR. KERR: Are there other questions?

15 [No response.]

16 You have indicated, I think, two things that
17 are likely to be changed as a result of the PRA. This is
18 what I might call an augmentation of Appendix R.
19 Apparently something is going to be done about possible
20 mitigating fires which is beyond the requirements of
21 Appendix R as you understand it.

22 MR. ISRAEL: No, Appendix R is sort of broad.
23 It says to provide alternate cooling.

24 MR. KERR: I knew Appendix R was rather
25 broad. That is why I'm surprised that there was

1 something here that Appendix R was not equipped to deal
2 with.

3 MR. VARGA: Steve Varga from the Division of
4 Licensing. As you know, we are all working on a
5 schedule for implementation of Appendix R that goes
6 something like this. In July, all the operating reactor
7 utilities had to provide their Appendix R analyses,
8 which they did, Indian Point 2 and Indian Point 3 being
9 ones that have provided some mitigation features. Some
10 were deficient in what we are evaluating.

11 As a result of receipt of the PRA and review
12 of the PRA indicating the dominance of the fire risks
13 categoris, we accelerated the reviews of the submittals
14 and the status of the plants concerning Appendix R. We
15 made visits to Indian Point 2 specifically with a fire
16 team to evaluate the status of the fire protection and
17 particularly the deficiencies that should be corrected
18 as a result of Appendix R.

19 As a result of that visit and the deficiencies
20 that were identified and the deficiencies in the
21 submittals made by the licensee which will take some
22 period of time to correct, the Appendix R reviewers tell
23 me that the deficiencies identified in the PRA, which we
24 have separated as a subset -- for instance, reactor
25 coolant pump, lack of cooling water and hard wiring

1 alternate means of getting power to the pumps that
2 provide the component cooling water -- as a result of
3 the PRA we have gotten a commitment from the licensee
4 that prior to startup, he will fix those specific things
5 that have been identified specifically in the PRA as
6 dominant risk contributors.

7 However, the Appendix R reviewers tell me that
8 a properly conducted Appendix R review would have found
9 and encompassed all of the deficiencies identified in
10 the PRA and that the Appendix R review and the Appendix
11 R corrections will correct and would have corrected the
12 deficiencies, but the time scale is such that with our
13 review and approval and then the modifications, and the
14 rule allows a certain period of time for these
15 modifications to be implemented, we have expedited those
16 three or four things with the licensee and he has
17 committed to complete those, which are included in the
18 report that I am sure the NCRS has received, and the
19 letter to the licensee outlining those specific
20 corrective actions that he will take prior to restart;
21 but the entire Appendix R separation criterion, the
22 lighting and all of that will still take place at some
23 time in the future.

24 MR. KERR: That is very helpful, Steve. What
25 I am trying to identify is what change in risk may

1 result from the PRA. That is, what things are or are
2 likely to be fixed up because of the PRA that would not
3 otherwise have been fixed up. If I interpret your
4 remark correctly, fire protection is not one of these,
5 because a properly carried out review of Appendix R,
6 which I am sure the Staff has done, would have caught
7 this. So a PRA was not necessary for that.

8 MR. VARGA: Absolutely. That is the specific
9 question I ask of the people doing Appendix R reviews.

10 MR. KERR: Now, one thing that has been
11 mentioned that apparently existing regulations would not
12 have changed is the seismic hazard. There is going to
13 be a change made, I think, as a result of the PRA which
14 would not have been made as a result of existing
15 regulations, which calculations indicate will reduce the
16 risk of a seismic contribution to core melt.

17 You also indicate, I think -- well, the answer
18 to this question is not clear -- that there has been
19 identified a contribution to risk from hurricanes which
20 would not have been identified with existing
21 regulations.

22 That one puzzles me because I can't understand
23 why a diesel structure in this location would not have
24 been designed to withstand an historical hurricane, and
25 I think we are talking about historical hurricanes,

1 aren't we, not something considerably beyond the
2 historical hurricane?

3 MR. ISRAEL: I think we are talking about
4 something about 140 miles an hour. I'm not sure that's
5 historical.

6 MR. VARGA: I don't know the specific and I
7 can't recall. I wasn't involved in it at the time, the
8 specific licensee and bases for Indian Point 2 and 3.
9 But I am sure that winds, tornadoes, and hurricanes were
10 part of it. I do recall that with the loss of offsite
11 power there was the alternate gas turbine arrangement
12 that, although not particularly in all of its attributes
13 was what one would consider a first rate reliance for
14 need on emergency power, but nevertheless it was
15 available. It took some period of time to start, and
16 part of the corrective actions we are asking for in the
17 interim before all of Appendix R is completed is the
18 ability to start that gas turbine in a certain period of
19 time and the procedures to be available. I don't know
20 whether or not the Indian Point PRA took into account
21 the gas turbine availability, but the assumption is that
22 it did. And what the licensing basis was for
23 hurricanes I do not recall, and what additional
24 information might have been found from the PRA on
25 hurricanes I don't know.

1 MR. EBERSOLE: May I ask a question, Steve?
2 On the other side of the coin, did you see anything in
3 the Appendix R investigation that you didn't see up here
4 relative to fire?

5 MR. VARGA: I can't answer that question. I
6 don't know.

7 MR. KERR: Mr. Israel, will you help me
8 further? There are these three things, two things, I
9 think, the seismic and the hurricane risk, that would
10 not have been fixed up and presumably will be fixed up
11 because of the PRA. Is there any other major contributor
12 to risk that is fixable and is likely to be fixed up as
13 a result of the PRA?

14 MR. ISRAEL: That is the area of what we
15 ultimately do with the PRA results. They are under
16 review and become part of our testimony for the hearing,
17 so I don't have a definitive answer to give you at this
18 point.

19 MR. KERR: I am not so much looking for things
20 that have been committed to but things that are
21 fixable. This really doesn't just have to do with
22 Indian Point. Here is a very elaborate, very intensive
23 PRA, and presumably one of the virtues of this, at least
24 if one believes the ACRS, is that going through this
25 sort of an exercise locates contributors which can then

1 be fixed. Even though maybe one doesn't believe in
2 numbers entirely, there is a qualitative evaluation here.

3 I have indicated two things, hurricanes and
4 seismic, and maybe they are big enough so that that is
5 really a major contributor, but both puzzle me a bit,
6 however. That is it, as far as you are concerned, of
7 things that are major contributors that are fixable?

8 MR. ISRAEL: That is what I made in my comment
9 right now. Ashok, did you want to make a comment?

10 MR. THADANI: When the licensee submitted the
11 PRA, they wrote us a letter that went along with it in
12 which there was a long list of areas where they felt
13 they could make improvements and they were taking steps
14 to go ahead and make those improvements because they
15 felt they would not only help the risk, but there were
16 about 10 or 12 items.

17 MR. KERR: ACRS probably has a copy of that
18 letter somewhere.

19 MR. THADANI: Yes. If I recollect correctly,
20 a large fraction led to integrity tests, flow
21 verification tests. Mostly they seemed to be procedural.

22 MR. ISRAEL: One of the fixes was in the
23 battery room, Unit 2. They were going to shore up the
24 walls. This had to do with the seismic potential
25 problem.

1 MR. VARGA: I might point out one thing. As
2 you know, this Indian Point 2 and 3 at the present time
3 is a highly contested hearing. Today we have the
4 prehearing conference going on in the New York area.
5 There are a series of questions that the Commission has
6 asked the Board to explore. The Board has admitted a
7 number of contentions. The Board has asked specific
8 questions of its own. We are in the process of
9 preparing testimony. At the same time, life goes on in
10 other areas with regard to Indian Point 2 and 3, that
11 is, the Three Mile Island event items as well.

12 Exactly what the use will be of the PRA as we
13 come to the conclusion of the hearings and come to the
14 conclusion of our reviews remains yet to be seen. As
15 far as the requirement from the Staff for the licensee
16 to make corrections regarding the Appendix R submittals,
17 we are on quite firm regulatory ground there. As far as
18 those items identified in the PRA, which go in some
19 instances beyond the present design basis, the licensee,
20 as Sandy just pointed out, has volunteered fixes, the
21 bumper and some other areas that he has volunteered.

22 I am sure in preparation of his testimony
23 which he will be filing as a result of the Board order
24 that I am sure will come out as a result of the hearing
25 today, in the testimony he files I feel sure that he is

1 probably already making a list of items that he feels he
2 will correct based upon the PRA. What additional
3 requirements we will have him do will remain to the
4 conclusion of our testimony and our recommendations.

5 MR. BENDER: Steve, these things will be in
6 the nature of backfits, don't you think?

7 MR. VARGA: Yes.

8 MR. BENDER: I guess one would have to ask, if
9 it is a backfit, does it involve a substantial reduction
10 in risk? What is the measurement criteria?

11 MR. VARGA: I don't know what the measurement
12 criteria will be. The measurement criteria in the
13 announced policy statement is the ALARA, the \$1,000 per
14 man rem. There have been proposals, of course, that
15 people have been discussing about various criteria, the
16 monetization of risk approach, but I am not sure we have
17 established a consensus or even an approach yet.

18 MR. BENDER: The policy is out for comment.
19 It is just not in the regulatory rule yet, is it?

20 MR. VARGA: No, it is not. It is still out
21 for comment. But it has at least some tacit weight in
22 our deliberations, knowing that it is a statement of
23 policy, that it is out for comment.

24 MR. BENDER: I wonder how the hearing board
25 will address something like that that is in a

1 deliberative state itself.

2 MR. VARGA: Well, in the present hearing at
3 Indian Point, there has been, as you know, a change of
4 chairmen, and consequently there is going to be -- there
5 have been already some changes in the questions and the
6 contentions, but one of the items I am sure we will be
7 addressing in response to the questions the Commission
8 has asked will be the Commission policy statement and
9 our perception of its role and what use we would make of
10 it.

11 MR. BENDER: So it doesn't make any difference
12 that the Commissioners have not yet adopted a policy; it
13 is the policy?

14 MR. VARGA: I don't think so, no. I say we
15 use it in terms of guidance as it evolves to see what
16 effect it has on our deliberations.

17 MR. KERR: Mr. Okrent?

18 MR. OKRENT: Later in today's agenda there is
19 sort of a general kind of discussion available. I am
20 wondering, does the Staff expect to be here for the full
21 meeting or are they going to fold up their tents as soon
22 as they have made the presentation on Indian Point?

23 MR. THADANI: Dr. Okrent, we were planning on
24 staying here part of the time, until about lunch.

25 MR. KERR: We can take care of that, though,

1 by just not having lunch until 4 o'clock.

2 MR. THADANI: Let me rephrase that.

3 [Laughter.]

4 MR. KERR: Did that respond to your question?

5 MR. THADANI: I would really appreciate it if
6 we could leave somewhere around 1 o'clock, and if you
7 think there are some other aspects we should be
8 discussing in terms of plants and so on, perhaps we
9 could do that this morning.

10 MR. KERR: Why don't we decide whether the
11 Staff has answered all our questions by 1 o'clock. If
12 they have not, we may plead with them.

13 MR. OKRENT: Okay. I would like to come back,
14 either now or after the break, as the Chairman prefers,
15 to just find out a little bit more about where the Staff
16 plans to go with regard to what I will call the
17 technical review of Indian Point 2 and 3. In other
18 words, what further kind of technical reviews you think
19 are relevant and how you expect to go at them and so
20 forth. Maybe we could let them think on that while we
21 have a break, Mr. Chairman.

22 MR. KERR: I was going to ask a very similar
23 question: namely, not that you have got this thing, what
24 are you going to do with it? I think I heard either
25 they are not sure what they are going to do with it or

1 they cannot talk about what they are going to do with it
2 because they are in litigation; but I hope we can get
3 some more definite answer.

4 I am also more interested in: Is the Sandia
5 position also the Staff position, and if it is not, how
6 does the Staff plan to arrive at a position?

7 Mr. Mark, we have kept you quiet too long.

8 MR. MARK: That is commendable. I have a very
9 vague question, and I don't really expect an answer, and
10 certainly not a definitive answer. It goes to Steve
11 Varga, in part, and maybe Israel and maybe the Staff
12 generally.

13 We have here a hearing. Obviously the things
14 to be discussed have been worked over and settled and
15 the reg guides have set down regulations to determine
16 the admissible questions, points on which the proceeding
17 is to be held. Is there any room, is there any
18 mechanism, is there any tendency or any possibility,
19 supposing the Staff sees something that is not covered
20 in the reg guides but represents in their view an actual
21 issue? I mean here is a window that is open that
22 shouldn't be there, or whatever.

23 Is there any way and any inclination to act on
24 such things, or is one really tied down and guided by
25 the wordage that is in place?

1 MR. KERR: Is that question directed properly
2 to you, Mr. Varga?

3 MR. VARGA: Yes. The answer to that is we are
4 not tied down. As an example, Harold Denton, when we
5 received the Sandia results and had the presentation by
6 Sandia, I indicated the dominant contributors. As a
7 result of Harold's perception, we had discussions with
8 both Indian Point 2 and 3 management, upper management,
9 and specifically discussed the concerns, the concern for
10 the seismic hazard, the concern for the fire, and the
11 concern for the hurricane.

12 We had a seismic evaluation team up at Indian
13 Point 2 and 3 specifically looking at the pump problem,
14 the ceiling problem, the diesel generator, the diesel
15 fuel tank problem, and we had a team up there for the
16 fire problem and discussed with Indian Point management
17 actions which would be prudent to take without waiting
18 for a specific direction or an evaluation on the part of
19 the Staff.

20 I think as a result of that phone conversation
21 that there were positive steps taken by the utilities in
22 such things as the design of the bumper and the
23 volunteering of the bumper. My perception is there is
24 an acute sensitivity to act immediately on those areas
25 where it appears a significant dominant risk contributor

1 has arisen without waiting for an evaluation of a value
2 impact statement but to see what can be done
3 immediately, and that has been done.

4 MR. MARK: Steve, I think that is --

5 MR. KERR: I think one should also add, I
6 think, the uncertainties of the Staff numbers.

7 MR. MARK: That sounds actually very good to
8 me. I was fishing, I suppose, for the possibility that
9 seismic, of course, is recognized on the agenda as
10 something that has to be discussed. Fire, also. But I
11 am wondering, supposing you or someone you are in touch
12 with sees something that isn't on the agenda and he
13 says, good heavens, this is bad, or it could be better.
14 Is there a mechanism and a way of introducing that into
15 the discussion apart from the tag enumerated items?
16 That is, he finds -- I said an open window. Just to
17 think of something that wasn't by any chance on the list
18 of things to check. Is there a straightforward, easy,
19 customary way for such things to get into the argument
20 so that they indeed have to be given attention?

21 MR. VARGA: If I interpret and restrict your
22 comment to Indian Point for the moment, Indian Point 2
23 and 3, as a result of the PRAs for both Indian Point 2
24 and 3 and for Zion, and the discussions that Sandia has
25 had about the mechanisms and consultants we have had in

1 place reviewing those, the mechanism of surfacing
2 outliers, surfacing areas that have not been considered
3 will have to come through that particular mechanism in
4 terms of the reviewing of the PRAs.

5 We always had in the regulatory process, there
6 is always the mechanism that any reviewer doing any
7 piece of work, where he finds something that has not
8 been taken care of, he has the obligation to surface
9 that immediately, and he has done that. We have seen
10 several instances of that in the past year, of that kind
11 of a sensitivity taking place.

12 But as far as Indian Point 2 and 3 goes, in
13 the answers that we are preparing now, the testimony
14 that we are preparing, the testimony that the
15 intervenors are preparing on the risk questions asked by
16 the Commission, there is a great deal of work going on,
17 as you can see, in reviewing the Indian Point PRA, in
18 the Sandia review of the Indian Point PRA, in our review
19 of both the Sandia evaluation and the Indian Point PRA,
20 and in that mechanism, if a problem or if an outlier is
21 surfaced, we would immediately act on it.

22 Now, whether or not the outliers have to date
23 been properly surfaced or not, I guess the confidence I
24 have is only that we have a very extensive peer review
25 going on, we have Sandia reviewing that review. We

1 have, I am sure, as the hearing progresses, we have a
2 large body of interested public participants that will
3 be carefully and searchingly examining our testimony,
4 and whatever surfaces in that mechanism, we would act
5 on. Those are the mechanisms wherein those kind of
6 concerns would surface.

7 MR. MARK: Thank you. I believe that covers
8 my point.

9 MR. KERR: Other questions of Mr. Israel other
10 than the ones he is going to think on?

11 MR. BENDER: Just one having to do with
12 Steve's observation, that I guess certain outliers are
13 being corrected without considering their value, their
14 cost/benefit relationships and the like. Is that a
15 correct interpretation?

16 MR. VARGA: I didn't mean to say that
17 irrespective of the cost, that they were being
18 corrected, but in the identification of the problem, the
19 consensus was and the consensus is that those corrective
20 actions that could be taken to significantly reduce the
21 dominant risk contributors were so worthwhile that one
22 didn't have to go through and wait for a formalized
23 evaluation. Now, there may be many other things in the
24 PRA where we might have to in terms of backfit, in order
25 to establish the requirement, in spite of the utility's

1 objection we will have to go through a very careful
2 evaluation to make the point.

3 But in those cases where the problem has
4 surfaced and the utility has recognized the problem and
5 has acted more or less in consort with the Staff's
6 considerations to correct the problem without any
7 particular regulatory action on our part.

8 MR. BENDER: There will always be dominant
9 risk contributors. When you get rid of the dominant
10 ones now, the next group will become dominant. I am
11 still concerned about the matter of where to draw the
12 line, and I think I will just leave it there.

13 MR. EBERSOLE: Steve, before you run off, we
14 mentioned the Appendix R studies you have done which
15 interfaced with this. You mentioned doing some seismic
16 studies, some considerations of hurricanes and
17 tornadoes. Indian Point was also the beneficiary of a
18 system interaction study. Somewhere somebody like
19 yourself has got to be at the top of this great heap of
20 studies and see that appropriate strings are tied to
21 each on of these as inputs to this comprehensive thing
22 here.

23 How many inputs have gone into this? Have you
24 picked them up and done that as a summary operation of
25 all of these, or are they just left out there by

1 themselves?

2 MR. VARGA: Let me answer the question. There
3 are none out in left field that I know of. They have not
4 all been completely integrated, but the work is under
5 way to do that. You picked a good one, the Indian Point
6 3 system interaction study. You recall they used the
7 auxiliary feedwater system as the model. They had
8 extensive discussions with you all. One of the
9 multi-plant action items we have, I think it is C-14, is
10 the seismic capability of the auxiliary feedwater
11 systems. As you know, we have gone out to all the
12 utilities with a generic letter. They have all
13 responded. We have received the Indian Point 3 response
14 to our generic letter, and the Indian Point 3 response
15 includes the items that they found from the systems
16 interaction study.

17 We have reviewed those items, the response to
18 the seismic capability of the auxiliary feedwater system
19 and have some concerns with it. We are right now in the
20 process of reviewing both Indian Point 2 and Indian
21 Point 3 based upon the two separate submittals but using
22 the submittal from Indian Point 3, which seems to have a
23 more sophisticated review as a result of the systems
24 interaction study.

25 So we have asked, and I think Sandy can

1 correct that, perhaps, the Indian Point PRA people,
2 PL&G, I think, is going back and taking a look to see
3 what the systems interaction study is on the auxiliary
4 feedwater system from the PRA, but I don't know of any
5 studies -- and I am not an expert on all the PRAS -- but
6 I know of anything associated with Indian Point 2 or 3
7 that seems to have a bearing on the PRA we are following.

8 MR. EBERSCLE: Thank you.

9 MR. KERR: We have a ten-minute break
10 beginning now.

11 [Recess.]

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. KERR: Mr. Thadani, is someone prepared to
2 make some comments in response to the questions just
3 before the break?

4 MR. THADANI: If I understand your question
5 correctly, Mr. Kerr, you were interested, I think, in
6 knowing, now that we have these PRAs, what are we going
7 to do with them.

8 MR. KERR: Yes, sir.

9 MR. THADANI: Obviously, one aspect is to
10 review the PRAs to get a better understanding of what
11 are the factors which might strongly influence risk:
12 that is, identification of dominant contributors, to
13 look at these contributors further to see are they
14 dominant because perhaps our current regulatory
15 requirements have not been implemented? An example is
16 obviously Appendix R in this case.

17 MR. KERR: As Mr. Bender has pointed out, no
18 matter what plants you review, you are going to find
19 some dominant contributors because some are going to be
20 bigger than others. Are you just looking for dominant
21 contributors or are you looking for dominant
22 contributors that are significant?

23 MR. THADANI: We are looking for dominant
24 contributors which are significant. I think
25 "significant" is a rather subjective word.

1 MR. KERR: That is part of the question: Is it
2 at this point subjective?

3 MR. THADANI: It is largely subjective. We do
4 not have safety goals. As Steve Varga earlier pointed
5 out, we do have this Commission position which went out
6 for comments. One thing we would be doing is to take
7 those considerations and use them only as guidelines to
8 point out which ones are dominant in relation to both
9 criteria if they were adopted.

10 So you are quite correct. There is some level
11 beyond which one need not really pursue the sequences
12 with any vigor. It is subjective to a large extent,
13 but the proposed goals are used only in the aspect that
14 if estimates are in those ranges, they would be
15 considered important.

16 Now, one point that I thought did not come
17 out, at least in my perspective, was I quite agree with
18 Mr. Bender that you do have to consider value impact,
19 and I think the NRC in general has been putting more and
20 more attention on value impact, recently, anyway. So
21 when you look at these dominant sequences, I am not sure
22 that one would go out and say you have to fix this. The
23 question to be asked is are the requirements being met?
24 If the answer is yes, then one would have to sit back
25 and say, well, how much is it going to cost me to make

1 any additional improvements?

2 The value impact, I think, is going to be a
3 very important part of any actions which will be
4 required outside the regulations. That would be the
5 general approach we would be following, unless the
6 Commission does come back with a definitive statement on
7 baseline risk.

8 MR. BENDER: I don't know where it stands
9 right now, but I have the impression that some part of
10 the NRC is vigorously pursuing something called a
11 backfit rule and that it may go out for comment soon,
12 too. I am not sure what is going to be in it, but I
13 suspect that whatever people have in mind ought to be
14 cranked into the evaluation process to see whether the
15 PRA approach and the backfit rule are even compatible
16 with each other.

17 MR. MARK: Mr. Chairman.

18 MR. KERR: Yes, sir.

19 MR. MARK: Has there been before I managed to
20 get here any discussion of this recent report from
21 Sandia on the worst case accident?

22 MR. KERR: No, sir.

23 MR. MARK: I'm not prepared to discuss it
24 either because I have not seen the report either, but --
25 as given in the newspapers, it presents a tremendously

1 impressive picture of a disaster. And while I don't
2 think that things like that should influence directly
3 the numbers one decides to apply in a PRA or any study,
4 it is necessary nevertheless to give thought to how to
5 be prepared to comment or how to relate one's own
6 comment to that comment. And while I am sure it is not
7 really part of the discussion today, it is certainly in
8 my mind as a thing that overhangs, glowers over some of
9 the things we are talking about.

10 MR. KERR: I did not take that as a question.

11 MR. MARK: It is not really a question unless
12 Mr. Thadani would wish to comment on the thought they
13 are giving to responding to this rather new and rather
14 troublesome-looking event.

15 MR. KERR: Do you have something on which you
16 are willing to comment, Mr. Thadani?

17 MR. THADANI: I would just as soon not comment
18 on that aspect at this stage.

19 MR. KERR: Mr. Okrent?

20 MR. OKRENT: I have a few questions. A
21 specific one is I think Mr. Israel indicated that one of
22 the technical outcomes from the PRA and the review of
23 the PRA is the concern that you might get a small LOCA
24 arising from a loss of reactor coolant pump seals
25 because you lost power to the systems, that you lost

1 cooling water for the systems that put water in the pump
2 seals, and it was sort of like this was something new.

3 It is my impression that in 1978 at the ANS
4 meeting on probabilistic safety, that Fred said that
5 they had looked at the question of station blackout in
6 France and arrived at the judgment that it was a thing
7 that might occur with the frequency of something times
8 -5
9 10 for even an extended period of time, and that
10 they were going to put in additional systems that would
11 provide cooling water to the reactor coolant pumps
12 seals, and in fact I think they have done it and it is
13 either run from steam or from a dedicated diesel that is
14 supposed to be able to work even when you lose the other
15 systems.

16 So I am a little bit surprised that it seems
17 like a new event to somebody, and I am also surprised
18 that it has not been looked at harder in this country as
19 well as some other things of that sort. That is just an
20 aside; that is not a question, Mr. Chairman.

21 MR. KERR: A speech.

22 MR. CKRENT: A speech, yes. I would like to
23 get back to the general question of how the Staff
24 expects to proceed with regard to what I will call the
25 technical review of risk for Indian Point. I think we
do have what I consider to be a good, not perfect, but a

1 good PRA. I think we have the benefit of what the
2 licensee considers to be a good review of the initiating
3 event portion from Sandia. I don't know if there is
4 going to be a report or is a report on the risk, the
5 overall risk from BNL. I assume there will be?

6 MR. THADANI: At this stage there is no report
7 yet from Brookhaven National Laboratory. In the
8 analyses that have been discussed with you in various
9 meetings, the Staff is rather busy now writing testimony
10 for the hearings.

11 MR. KERR: Mr. Thadani, you are not coming
12 through.

13 MR. THADANI: I will try to stay pretty close
14 to it. The Staff is pretty busy putting together
15 testimony for the hearings now, and I would expect
16 anything that comes back would get lower priority. The
17 first priority is to prepare our testimony, and it is
18 our intention to have one report that would not just
19 include Sandia's assessment but it would include
20 Brookhaven's assessment as well as the Staff's studies,
21 which would give the total picture in terms of the
22 review of IPPSS and our thoughts on what the risks might
23 be.

24 I would expect that to take place not in the
25 next two or three months but perhaps within six months.

1 I do not know what the schedule is going to be in terms
2 of hearings. It has changed and continues to change,
3 and as Steve pointed out, there is a prehearing
4 conference today and there will be some discussion of
5 schedules. But I would not expect us to come up with
6 any additional reports besides the Sandia report on
7 Indian Point. After we have prepared our testimony,
8 then we can focus attention on putting together a report.

9 MR. OKRENT: Let me pursue this matter. I am
10 trying to find out what constitutes, I guess you might
11 say, an adequate status of technical studies. What I
12 said was we had good PRAs and a good review, but in fact
13 if you read the Sandia letter, it says we were able to
14 spend something on the order of two manyears, something
15 like this, and clearly there are parts of it that they
16 were able to do really in quite a detailed fashion
17 because they had the benefit of having looked at systems
18 like this. They knew what kind of data to expect, et
19 cetera, and spending another half man-year in those
20 areas mght not change things significantly.

21 On the other hand, there are many areas where
22 things were treated really in what I would call a review
23 fashion and questions were raised or engineering
24 judgment was a very strong input into what was done
25 rather than even secondhand, let alone firsthand,

1 looking in detail, and certainly fragilities and seismic
2 evaluation is one example of that.

3 I am trying to understand how the Staff will
4 decide what constitutes an adequate technical depth of
5 review. This depends on the purpose, certainly, so I
6 don't expect that one necessarily has the same answer in
7 looking at it on Indian Point as if you are trying to
8 make a judgment on some of the SEP issues, which tend to
9 be secondary in nature at one of the SEP plants, but for
10 the Indian Point plant, what constitutes an adequate
11 review, why, how do you propose to incorporate in this
12 judgment these areas that have been looked at, as I say,
13 only in an incomplete way in a review mode. And in
14 fact, as you know, there are things that are not
15 included in anyone's PRA except under the category
16 "other."

17 MR. THADANI: I will take a crack at it. I
18 don't think I have any real answer to your question.

19 MR. OKRENT: I don't think I have an answer
20 either, but I think we ought to talk about it.

21 MR. THADANI: We don't have much experience
22 reviewing PRAs. We have consultants who, in my opinion,
23 have had extensive experience in both being involved in
24 providing some sort of consultation as well as having
25 conducted PRAs. There was discussion of what kind of an

1 effort it takes typically to review certain pieces. One
2 can develop some rather arbitrary standards, perhaps,
3 and say if it takes you ten months to do a study, you
4 ought to at least spend a month reviewing what was
5 done. It is rather arbitrary. As one gets more and
6 more experienced, hopefully one would take less time, or
7 the reverse of that might be that until one gets a lot
8 of experience, one should spend a fair amount of time
9 reviewing these studies.

10 Two factors. We looked round to see how much
11 help we could get in terms of reviewing these studies,
12 and there was some consideration of schedules as to when
13 we might need some input. A classic example, as Sandy
14 pointed out earlier, is Indian Point. We took the
15 Indian Point study. We got it sometime, I believe it
16 was, in March, the middle of March.

17 We knew we had hearings coming up. We wanted
18 to do two types of reviews. One was a fairly quick
19 review followed by a more comprehensive review. The
20 quick review was to be done in about four months. The
21 more comprehensive review we said would take something
22 on the order of a year or so. As the hearing schedule
23 changes, so does our review process.

24 We have, in my opinion, some of the best
25 people, who understand data, who understand the

1 functional characteristics of the plants, who have
2 sensitivities in terms of how these analyses are done;
3 and added to that, I think, are the detailed studies
4 that have been going on for the past two to three years
5 in terms of containment assessments.

6 I think we have gained a lot of insights from
7 these various studies, and it is at least our judgment,
8 and we could be wrong, at this stage that putting in
9 somewhere around two to three manyears worth of effort
10 in the large study such as Indian Point and reviewing it
11 and providing at leas` what we might think is a balanced
12 assessment is a reasonable kind of effort.

13 I think we don't know as yet if that is a
14 correct statement or not. It depends on other groups
15 reviewing our assessments and coming to certain
16 conclusions, whether we did indeed look at things
17 thoroughly enough or did we spend much too much time
18 that we didn't need to spend. I can't give you an
19 answer. I think we are all struggling at this stage.

20 MR. OKRENT: Well, again, there are areas
21 which seem to be in need of additional information. If
22 one looks through the Sandia letter and if we look at
23 some of the ACRS consultant reports again, that there is
24 additional information which may be of significance in
25 arriving at a better base for engineering judgment or

1 whatever it is you are going to arrive at.

2 What I thought I heard implicitly was you are
3 preparing a kind of final report with the input largely
4 having been developed, except for such feedback as you
5 get from the licensee and its consultant and that you
6 might get at the hearing itself. It seems to me that
7 one could look at the report and the review and so forth
8 and out of this say, well, where are there areas that
9 one should put further effort into and what kind of
10 effort makes sense and so forth. I did not get the
11 feeling that that was part of your plan or whether you
12 thought that was not necessary, or maybe I am just
13 hearing it incorrectly.

14 MR. THADANI: I am not quite sure I follow
15 you, Dr. Okrent.

16 MR. KERR: Let me ask something that I think
17 is parallel to Dave's comments, and maybe if he says
18 yes, it will help. Earlier comments would seem to me to
19 indicate that the Staff has an approach which attempts
20 to compare the risks associated with the Indian Point
21 operation compared with other plants as an inordinate
22 contributor to risk.

23 In a discussion of the safety goals, if I
24 remember correctly and if I interpreted the comments
25 correctly, it was a feeling of at least that segment of

1 the Staff responsible for contributing to that study
2 that the specification of performance of containment
3 systems was sufficiently not well understood that the
4 Staff did not want to put any quantitative criteria or
5 to set any quantitative specifications for containment
6 performance. It may be true of the Indian Point
7 containment in as much detail.

8 I think there is an appropriate discussion of
9 the source term to be used as one attempts to go outside
10 containment. It seems to me both of these are a
11 significant contributor to risk as contrasted with the
12 core melt probability. If there is going to be a risk
13 comparison, has the Staff decided how it is going to
14 deal, for example, with these two issues, with which it
15 seems to me there has been significant uncertainty
16 identified by the Staff and by others, and yet which are
17 rather significant contributors, it seems to me, to what
18 one finally calculates the risk to be? This is not all
19 of your question, but it is that sort of thing.

20 MR. OKRENT: It is certainly a good example,
21 and it makes a point. In other words, there are sort of
22 two kinds of questions. One is on what basis is the
23 Staff going to evaluate a judgment and make
24 recommendations to the Commission with regard to things
25 other than these things you are dealing with the

1 licensee on the telephone, the harder decisions which
2 fall into a grey area. And then there is the other one,
3 just from, let's say, the long-term point of view of
4 trying to improve the usefulness and the quality of the
5 use of the PRA. Is what has been done right in trying
6 to study Indian Point; if not, why? The two are not
7 unrelated. I think Dr. Kerr has certainly raised a
8 couple of the things I had in mind. What we have been
9 talking about today is in the core melt prevention area.

10 MR. THADANI: Well, the two aspects that you
11 talked upon, Dr. Kerr, I indicated earlier that the
12 Staff has had several discussions with the Subcommittee
13 as well as the full Committee in terms of the work the
14 Staff is doing on containment. With future plants you
15 are quite correct, the Staff had indicated that at this
16 stage we are not in a position to specify containment
17 performance for various types of containments in
18 numerical terms in this proposed safety goal
19 consideration.

20 In terms of source term, there is a fair
21 amount of work going on to try to come to better
22 estimates of source terms. If you want to know some
23 details about these programs, we do have Jim Meyer as
24 well as --

25 MR. KERR: My question was, given what I

1 interpret to be a significant uncertainty that is not
2 likely to be resolved as the Indian Point testimony is
3 prepared, I was using this as an example of, it seems to
4 me, rather significant but uncertain questions with
5 which you have to deal at some point. Have you decided
6 how you are going to deal with questions of that kind?

7 MR. THADANI: Well, again, I would like to
8 hold off on one part, which is that there is significant
9 uncertainty in the containment failure modes. If you
10 would like to know generally what the Staff knows now,
11 Jim Meyer can tell you that.

12 MR. KERR: You have decided to have an
13 approach that you are going to use at this point even
14 though there is a good bit of uncertainty in what you
15 got?

16 MR. THADANI: We would have to reflect the
17 results with the associated uncertainties. Obviously,
18 that is the state of our knowledge now. There are
19 clearly uncertainties. In those areas where there are
20 uncertainties, one would have to sit back and decide
21 what programs should be initiated if they are not
22 already in place to try to reduce the uncertainties. It
23 seems to me that is the central goal that such an
24 organization ought to play to get a better understanding
25 of the phenomenon.

1 MR. KERR: I interpreted your question as
2 arriving at a cadre of things and there is another
3 category where things are in reasonably good shape? Is
4 that a valid interpretation? I am talking to you rather
5 than Ashok.

6 MR. OKRENT: Well, that is certainly a good
7 part of the question.

8 MR. THADANI: We are today talking to our
9 Research Office. What areas need further work, at least
10 in terms of probabilistic risk assessments -- and there
11 are no big surprises, I am just telling you what I am
12 convinced you all know -- external events, human
13 reliability, source term. These are dependency
14 analyses, and it is another area where one needs to
15 develop perhaps better methods to try to identify and
16 evaluate these dependencies and include them in the PRAs.

17 The sorts of areas where we are working with
18 Research is to see what can be done in what time frame
19 that they can provide which pieces. We hope to have a
20 plan addressing these aspects within the next three or
21 four months.

22 MR. KERR: In your view, is the present state
23 of the art such that one can use current results for
24 decision-making?

25 MR. THADANI: I think one can use these

1 results as yet another source of information for the
2 decision-maker. If these results point to some
3 deficiencies, I think this is useful information to the
4 decision-maker. If these results say what you are
5 concerned about is not very important, then you look at
6 the basis upon which the PRA came to that conclusion.
7 So I do think this is rather useful information to the
8 decisionmaker. Besides, I think they also help. I
9 recognize your point on uncertainties, but I think they
10 still help in doing the value impact assessments to see
11 if there are not other areas that might be better
12 pursued than the ones that we are pursuing.

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. EBERSOLE: Let me ask a question, Bill.

2 MR. KERR: Just a moment. Do you want to
3 consider this further?

4 MR. OKRENT: Just one or two more minutes.

5 (Applause.)

6 MR. MARK: One.

7 MR. OKRENT: I would suggest that you set up
8 some small but conscious effort to summarize where in
9 the Indian Point PRA there seems to lie the areas which
10 are clearly important or may be important and where the
11 effort expended to date, and I will say the combined
12 effort, meaning not only in this case the licensees,
13 contractors, and your reviewers, but even the research
14 staff coming before it, may have been clearly
15 insufficient or probably insufficient, and then to
16 decide in those cases, can I tell by what I will call
17 more technical assistance kinds of efforts, which I will
18 put the review of Indian Point in, as contrasted to
19 long-range research.

20 I am not against long-range research to give
21 you approved methodology, but I am not sure that
22 everything will fall in that category.

23 MR. THADANI: I know you didn't ask me a
24 question, but I just wanted to make one point, Dr.
25 Okrent. I talked about generalities, external events,

1 human errors, and so on, and yes, indeed, some aspects
2 would be long-range. It is our intention to try to come
3 up with a plan which would lay out what can reasonably
4 be done in what time frame and what the expected return
5 might be in terms of narrowing some of the uncertainties.

6 I certainly did not mean to imply that we were
7 going to talk to Research, and that this is something we
8 would be working on for the next ten years. We may well
9 be, but we would like to try to identify what kind of
10 effort is needed to try to narrow some of the
11 uncertainties and in what areas. That is what I meant
12 when I said we would be preparing a plan.

13 MR. KERR: The two minutes are up. Mr.
14 Ebersole?

15 MR. EBERSOLE: When you start to review one of
16 these things, do you pick it up at first and do sort of
17 a general review of the skeletal aspects of what has
18 been done, to see what has not been done? I was
19 impressed by the consultants' report on the Limerick
20 PRA, in that it doesn't consider external events. It
21 would appear there would be some general criteria that
22 says there shall be consideration of this, that, and the
23 other, or you don't have to include sabotage because
24 nobody knows what to do with it, but in some way, one
25 should bound and identify the scope. Otherwise, why

1 bother with doing uncertainty analyses?

2 All these things start with subjective
3 judgments as to whether you should include them or not,
4 so to some extent all the PRA's start at the subjective
5 level. What do you do to make sure they all get off on
6 a common foot?

7 MR. THADANI: I think you are quite right.
8 You have to have a certain amount of boundary, if you
9 will, in the review. We have attempted to provide at
10 least some level of guidance to the reviewers, and given
11 the scope of this study, clearly, as you point out,
12 Limerick does not treat external event. Given the
13 study, which treats only internal events, the review is
14 limited to the documents we have in front of us. One
15 would start with the initiating events, the data base,
16 the methods, the criterion, and so on.

17 We have attempted to provide at least some
18 minimum level at which these reviews would be
19 performed. In most cases, I think the reviewers have
20 looked beyond those aspects. We have identified
21 initiators that we should at least be looking for to be
22 sure that those are treated. That is not to preclude
23 them from identifying areas that we may not have had a
24 priority in identifying, but there is that level of
25 guidance that is given to the reviewers.

1 MR. EBERSOLE: It certainly ought to be
2 important that you require a disclaimer which is clear
3 and positive at the beginning of the report to what
4 people are taking a comprehensive review of in a partial
5 report.

6 MR. THADANI: I guess I would say a review of
7 a PRA should always have a disclaimer.

8 (General laughter.)

9 MR. KERR: One, I think, last question on this
10 topic before we go on to Limerick. Presumably the
11 Indian Point hearings will discuss risk. I don't know
12 what they will conclude. Either the risk is greater
13 than or about equal to or less than. It is conceivable
14 to me that a conclusion could also be reached if one
15 explored this that it was in compliance with all
16 existing regulations.

17 I am not asking what the Staff is going to do
18 if this is the case, but does the Staff have a mechanism
19 for dealing with the situation in which one would
20 conclude that the risk is higher than average or higher
21 than something or other and yet the plant is in
22 compliance with all existing regulations?

23 (Pause.)

24 MR. KERR: Is a strategy being developed to
25 deal with those eventualities?

1 MR. THADANI: I think the approach is to look
2 at the Indian Point units and to see once they are in
3 compliance regulations what the risk might be given
4 these uncertainties. The staff's perception of risk
5 from other sites as reflected in various studies, I
6 think those would be -- that would provide the
7 background for saying, what do we think the risk is for
8 the Indian Point site as compared to the risk from other
9 sites, but clearly, one would have to be sure that the
10 other plant risk assessments that one is using, that the
11 base was the same, that they also met the regulations.

12 MR. KERR: Since the regulations are not
13 risk-based, it seems to me quite possible that one could
14 find the societal risk, for example, quite different for
15 two sites, each of which would be in compliance with
16 existing regulations.

17 MR. THADANI: That is quite possible.

18 MR. KERR: The next question is, has the staff
19 given thought to what it is going to do if the final
20 results of the study are that the risk of this site is
21 considerably above average, or maybe it will turn out to
22 be considerably below average, as far as I know, but the
23 plant is in compliance with all existing regulations?

24 MR. EBERSOLE: Bill, it seems to me you are
25 talking about a degree of defined prescription.

1 MR. KERR: I am really trying to get out of
2 him, once you reach this, what do you do next? The
3 regulations are what determines whether you run the
4 plant.

5 MR. EBERSOLE: You can interpret all over the
6 map with the regulations.

7 MR. KERR: They may be loose, but they are the
8 best we've got.

9 MR. EBERSOLE: The band width of
10 interpretation can mean all the difference.

11 MR. KERR: I am trying to get the staff's
12 approach to this. If you were responsible for
13 interpreting these regulations, I would have a better
14 idea of what would be done.

15 (General laughter.)

16 MR. KERR: Do you understand the question I am
17 raising?

18 MR. THADANI: I understand your question, Dr.
19 Kerr. I just can't -- I don't know what the answer is
20 going to be. As Steve indicated earlier as well, our --

21 MR. KERR: Then a strategy is not being
22 planned for this eventuality?

23 MR. THADANI: No, not really. At least, let
24 me put it this way, not that I am familiar with.

25 MR. CKRENT: Well, watch the Washington Post.

1 (General laughter.)

2 MR. KERR: Are there other questions or
3 comments?

4 (No response.)

5 MR. KERR: I suggest then that we go to the
6 Limerick presentation.

7 MR. THADANI: We have, as I indicated earlier,
8 Brookhaven National Laboratory reviewing the Limerick
9 risk assessment. We just received the BNL draft
10 document providing their review of the Limerick study.
11 Just to show you how fresh it is, this morning I
12 realized -- I was told that there is a substantial error
13 in that document. The Staff has not yet reviewed that
14 report. We have only had it for a few days.
15 Nevertheless, we would summarize some of the BNL
16 assessment results, and Mr. Chelliah of the Reliability
17 and Risk Assessment Branch would summarize the results.
18 We do have some people from Brookhaven to respond to
19 some of your questions that you might have.

20 Staff has not had enough time to review this.
21 We would like BNL to respond to those questions. We
22 have not done enough --

23 MR. OKRENT: Is someone going to tell us what
24 the substantial error is?

25 MR. KERR: Is it in the Limerick PRA?

1 MR. THADANI: There is a substantial error in
2 the BNL report in its review assessment of the Limerick
3 PRA.

4 MR. CHELLIAH: My name is Euralappa Chelliah
5 from the Risk Assessment Branch. I will be presenting a
6 summary of BNL's review results of the Limerick PRA.

7 As of October 15th, BNL reviewed the Limerick
8 PRA, Revision 4, so BNL's review results are based on
9 the review of Revision 4 of the Limerick PRA.

10 (Slide.)

11 MR. KERR: Try to stand reasonably close to
12 that microphone, if you can.

13 MR. CHELLIAH: BNL reviewed the accident
14 sequence analysis portion, and they have reassessed the
15 core damage frequency. Here is a summary.

16 (Slide.)

17 MR. CHELLIAH: The Limerick PRA predicts 1.5×10^{-5}
18 10^{-5} . BNL's review is 1.1×10^{-4} per reactor year,
19 which is a factor of several higher. You may be
20 interested for the reason these additional support
21 systems include three, some AC dependencies and DC
22 dependencies. The BNL modified somewhat the fault
23 trees, particularly in the area of fault trees for high
24 pressure coolant injection system, the ADS, and the
25 standby liquid control system.

1 Also, BNL updated some of the frequency values
2 for all initiating events.

3 MR. KERR: Excuse me. Does number C imply BNL
4 will be available to the Limerick people, or that they
5 interpreted the data different, or that they used a
6 different data set?

7 MR. CHELLIAH: BNL used the data from the
8 survey of somewhere around about 210 BWR operating
9 reactor experiences, so for example, in the transient
10 frequency, BNL predicts --

11 MR. KERR: Did they use data that were
12 unavailable to the people who did the original PRA, or
13 did they interpret it differently? The term "revised"
14 is used, and I don't know what "revised" means when they
15 revised the frequency.

16 MR. CHELLIAH: They did --

17 MR. SCHWENCER: We have a BNL representative
18 here. They might be able to help you.

19 MR. PAPAZOGLOU: My name is Ioannis
20 Papazoglou. The answer to your question is, all of
21 them. We have a slightly different data base, and we
22 used a different approach. The approach was very
23 similar to one that was used in the Indian Point and
24 Zion PRA's. The difference between the approach that
25 was used in the Limerick area and our revision was, we

1 did not give all of the credit that one would get if
2 they had an operating plant, a plant that is operated
3 for some period of time, and we said this is a new
4 plant, and therefore the data went through a certzin
5 amount of analysis before.

6 MR. KERR: You mean new in terms of being a
7 new model, or the fact that it has not operated yet?

8 MR. PAPAZOGLU: The latter.

9 MR. KERR: Thank you.

10 MR. CHELLIAH: Let us move on to the next
11 one.

12 (Slide.)

13 MR. KERR: Would it be accurate, then, if I
14 may, to say that your results might more nearly reflect
15 what one would expect during the first year or so of
16 operation of the plant rather than being averaged over
17 40 years, or do you average over 40 years but give more
18 weight? What are you then calculating as compared to
19 what the Limerick people might have been calculating?

20 MR. PAPAZOGLU: I will try to answer that.

21 MR. KERR: Do you understand my question?

22 MR. PAPAZOGLU: Yes. What we did was the
23 following. We assumed that Limerick belongs to a group
24 of plants thrt have some sort of similar performance in
25 terms of coming out with an initiating event but not

1 identical to them. Now, some of these plants that are
2 actually operating were seeing differences in their
3 performance. Some of them are better, some of them are
4 worse. What we assumed is, Limerick is going to be --
5 what we used in this particular assessment was the
6 average of all the plants. We did not assume that it
7 was going to be as good as the best or as worse as the
8 worst. There is a substantial amount of detail into how
9 we have reached this revision.

10 MR. KERR: Your interpretation is that
11 Limerick tended to use data that would lower the
12 frequency of initiating events? Or interpret data at
13 least in a way -- whereas yours was more nearly an
14 average?

15 MR. PAPAZOGLU: Let me try a specific
16 example. In the loss of off-site power, we have a
17 difference in the data base, first of all. The Limerick
18 PRA assumed that data that comes from fossil plants had
19 become routine in this case. We did not accept that.
20 We used only the data from the nuclear power plants that
21 belonged to the same reliability constant, if you want.

22 Furthermore, the way that we have treated this
23 data statistically, if you wish, is not the one that
24 assumes that all the plants are identical, and whatever
25 information we get from each plant can be pooled

1 together and treated statistically. We have adopted the
2 approach that was introduced in the Indian Point-Zion
3 PRA.

4 I am not sure if I can be more specific
5 without getting into technical detail.

6 MR. KERR: That is specific enough. Thank
7 you. Please continue.

8 MR. CHELLIAH: Let's go on. This slide shows
9 a summary of some of the dominant sequences for Limerick
10 as well as for BNL's review. I would like to give you a
11 couple of comments.

12 The first two sequences are the same. I don't
13 know whether you can read this. This is loss of
14 off-site power, followed by the failure of high pressure
15 coolant injection as well as low pressure coolant
16 injection. This amounts to somewhere around 42 percent
17 of core damage frequency.

18 In the Limerick PRA, this is about 41 percent
19 of their total core damage frequency. It is almost the
20 same. Almost. The second dominant frequency that is in
21 MISD closed valve followed by the failure of high
22 pressure coolant injection, and the human failure of
23 timely initiation of the aerator system, which is the
24 same as here. There are about five other sequences.
25 They don't really line up in order, but they are about

1 the same, really.

2 If you add up all these seven sequences, it is
3 something like about 78 percent of the total core damage
4 frequency. One interesting observation here is, all
5 these seven dominant frequencies are of BNL's review.
6 At least the same two functions. Here you see the U
7 function and the other is the X function, here, here,
8 here, and also here (indicating).

9 BNL has identified about 40 sequences which
10 are less than about 1 percent, really. These are the
11 general comments that you can arrive at out of these
12 dominant accident sequences.

13 MR. MARK: Perhaps you made this clear, but I
14 didn't catch it. Some of what you have there is the 1.1
15 $\times 10^{-4}$ roughly.

16 MR. CHELLIAH: That is three-quarters, yes.

17 MR. MARK: That is three times larger,
18 approximately, than the estimates provided in the
19 Limerick report. Is that due to differences across the
20 board, a factor of ten on each, or is it mainly due to a
21 difference in that bottom term or the bottom two terms?

22 MR. KERR: Do you understand the question?

23 MR. CHELLIAH: Yes. I don't have a breakdown
24 on each sequence. All I can tell us that the U and the
25 X are contributors to each sequence substantially, so

1 since they appear in at least four sequences, I think
2 the uniformity is the same, yes. We haven't reviewed
3 this. Of course, we will review BNL's report.

4 MR. THADANI: I would request Dr. Papazoglou
5 to respond to that question.

6 MR. PAPAZOGLOU: The answer goes across the
7 board. It is more or less uniform for the accident
8 sequence, because of -- the main contributor, the main
9 factors that bring about this difference are, as you
10 said before, the initiating events which multiply all
11 the accident sequences, the dependencies that are
12 present in most of the accident sequences, and the
13 changes in the system availabilities that appear in most
14 of the frequencies.

15 So, without -- I don't want to say that it's
16 -- what I'm going to say is mathematically correct or
17 rigorous. Yes, it is across the board. It is a factor
18 of ten in every accident sequence.

19 MR. MARK: It clearly has to be in the bottom
20 event, because that bottom event by itself is four times
21 the other value.

22 MR. PAPAZOGLOU: I am sorry. What is the
23 bottom event?

24 MR. MARK: T UV.

25 MR. PAPAZOGLOU: Yes, it is more or less, if

1 we take each one of those sequences and we see how much
2 higher frequency we predict than the Limerick PRA
3 predicts, then I think this factor is more or less very
4 narrowly distributed around the overall factors by which
5 we overestimate the core melt frequency.

6 MR. KERR: This major Brookhaven error wasn't
7 a systematic factor of ten all throughout, was it?

8 (General laughter.)

9 MR. THADANI: No, it wasn't. We will come to
10 that later on.

11 MR. KERR: Was there something else?

12 MR. THADANI: Would you like to have some
13 clarification of that error?

14 MR. KERR: I like mystery. We will get to it
15 in due course.

16 MR. CHELLIAH: I will make a general comment
17 that most dominant accident sequences are loss of
18 off-site power followed by loss of coolant. The same in
19 BNL's review and the Limerick PRA.

20 (Slide.)

21 MR. EBERSCLE: Let me ask for a
22 clarification. You use core damage frequency and others
23 use IP. Are you meaning the same thing?

24 MR. CHELLIAH: This is one of BNL's terms.
25 Maybe Dr. Papazoglou can give you a better explanation

1 on this.

2 MR. PAPAZOGLU: I guess Mr. Thadani wants to
3 respond to that question.

4 (General laughter.)

5 MR. THADANI: At least based on our knowledge
6 to date, we really have not been able to distinguish
7 between core damage and core melt. In reality, the
8 distinction is there, but in terms of these
9 calculations, I would treat the term "core damage" as
10 the way we have been using other places the term "core
11 melt." It is the same sort of thing, recognizing that
12 there might be some cases -- in fact, we know of cases
13 where one could indeed have some core damage but prevent
14 a large-scale melt.

15 MR. KERR: As it is used here, maybe it is too
16 specialized. If so, say so. Would TMI 2 be core damage
17 or core melt? Or would one in effect using the criteria
18 used here call it a core melt?

19 MR. THADANI: I would give you my
20 interpretation. Then perhaps Brookhaven can give you
21 their thoughts on how they use the term. If indeed this
22 were a PWR looking at a TMI 2 type of event, I would
23 suspect it would be called core melt.

24 MR. PAPAZOGLU: I agree.

25 MR. KERR: Thank you. Please continue.

1 MR. CHELLIAH: Dr. Kerr, my interpretation of
2 core damage is more like a core vulnerable condition.
3 If you want to go maybe probabilistically, maybe a core
4 vulnerable to a core melt, you may be able to assign an
5 additional probability.

6 MR. EBERSOLE: Could the distinguishing
7 difference be that the core damage doesn't imply loss of
8 the vessel? That is, it doesn't run off as a liquid and
9 threaten the primary vessel?

10 MR. THADANI: Mr. Ebersole, I missed your
11 point.

12 MR. EBERSOLE: Is the implication here that
13 core damage is not a molten core that runs off and
14 threatens the primary vessel and a core melt is?

15 MR. THADANI: As I indicated, the way these
16 calculations are done, the criteria that are utilized,
17 there really isn't any distinction.

18 MR. EBERSOLE: No distinction.

19 MR. CHELLIAH: Let's move on. This relative
20 contribution of various initiating events to total core
21 damage frequency, the dominant contributor is loss of
22 off-site power, which is about 51 percent on BNL's
23 review, and about 46 percent in the Limerick study. In
24 this case, it is an isolation event. The LOCA
25 contributes about less than 2 percent really.

1 (Slide.)

2 MR. KERR: Let's see. That says that in both
3 cases, loss of off-site power contributed almost 50
4 percent of the total, so that if you did use different
5 numbers for the frequency of loss of off-site power,
6 that could represent a rather major difference, and then
7 you said that you did use different loss of off-site
8 power numbers than Limerick did. Continue, please.

9 MR. MARK: Could I ask, Bill --

10 MR. KERR: Yes, sir.

11 MR. MARK: -- in connection with loss of
12 off-site power, one may follow that, and obviously the
13 consequences could be great as to whether the diesels
14 would start or not. Let's say the diesels start when
15 you have lost off-site power. So what? If they don't
16 start, you've lost off-site power and things are in a
17 different state. We have heard that we have numbers for
18 the failure to start diesels like 1 percent, 2 percent.
19 That is failure to start in some specified time like ten
20 seconds, but it really isn't necessary that they start
21 in ten seconds in all cases of loss of off-site power.

22 How was that handled?

23 MR. KERR: Do you understand the question?

24 MR. CHELLIAH: Yes. If I understand your
25 question, you would like to know what is the scenario

1 behind the particular accident sequence.

2 MR. MARK: Well, you have lost off-site
3 power. That can be bad if the diesels don't start. It
4 doesn't matter very much if they do. What criterion do
5 you use to decide whether they are likely to start? You
6 have a probability number you plug into your product to
7 decide if the core melts or not.

8 MR. THADANI: Mr. Mark, I think if I
9 understand your question, what sorts of data base was
10 utilized in coming up with the unavailability of diesel
11 generators for a certain length of time is the key, I
12 think. That is what you are asking. Let me ask again
13 Brookhaven to respond to your question by telling you
14 about what sorts of data they looked at and how we
15 utilized that information in these sequences.

16 MR. MARK: That gets to my question.

17 MR. PAPAZOGLU: The way the loss of off-site
18 power is handled is, you say one assumes that such an
19 event occurs, that we lose off-site power. Then the
20 next question is whether the diesels start or not.
21 Then, if they start, there is no problem as far as the
22 electric power is concerned. All the engineered safety
23 features have to work, of course.

24 So, what we do then, when we are at the point
25 where we have lost off-site power and the diesels do not

1 start, then we examine whether we can recover off-site
2 power or the diesels. This part of the analysis has
3 been time-phased, if you want, according to the
4 requirements that are put on the engineered safety
5 features. There is a whole event tree that treats this
6 particular initiating event, loss of off-site power,
7 that distinguishes between various design periods and
8 whether some sort of power has been restored during each
9 space.

10 MR. MARK: The requirements on the diesels, as
11 I understand it, this may not be correct, is that if
12 they fail to start in ten seconds, they are dead.

13 MR. KERR: Carson, I think he is saying he
14 didn't treat that simplistically.

15 MR. PAPAZAGLOU: That's right.

16 MR. KERR: You treated it according to a
17 specific sequence, I think.

18 MR. PAPAZOGLOU: It is not very much
19 sequence-dependent, but there is a sequence of events
20 there. If the assumption is the diesels don't start,
21 the next question we ask is how soon they can start.
22 Does it take a half an hour, one hour? Does it take two
23 hours? What is the probability that they will start in
24 each of those time intervals? And from the existing
25 data, these probabilities have been assessed, and we

1 treat each particular sequence accordingly.

2 In other words, one sequence assumes the
3 diesels are recovered within a half an hour. The other
4 assumes the diesels are not recovered, but we think of
5 an arbitrary number, one hour, and so on.

6 MR. MARK: Thank you.

7 MR. EBERSOLE: May I ask a question? Can you
8 recall the first critical failure which was irreversible
9 that led to core damage, at what point in time it
10 occurred, and what it was? Did you lose core coolant,
11 or did you lose ambient control, or what happened?

12 MR. PAPAIOGLOU: Well, for core damage, one
13 has to lose the capability of injecting coolant into the
14 core. That means that one has to lose both the high
15 pressure injection system and the low pressure injection
16 system. If -- the way that these two things were
17 treated was -- there was no time allowed for recovery,
18 if you want. At a certain point, we have lost all
19 coolant injection capability. Then the assumption was
20 that the core melt has been achieved. It is there.

21 MR. EBERSOLE: Yes. But high pressure
22 injection is not dependent on AC power.

23 MR. PAPAIOGLOU: High pressure injection is
24 not dependent, but the cooling of the high pressure
25 injection pumps is dependent, at least two hours after

1 that.

2 MR. EBERSOLE: Thank you.

3 MR. CHELLIAH: I will add to that, if you
4 don't have loss of off-site power, if you have lost all
5 the diesel maybe due to some common mode failure, what
6 happens is, you still have turbine-driven HPSI AC which
7 will give you high pressure coolant injection. What
8 happens in the Limerick plant, the HPSI room is cooled
9 provided by non-class 1E power supplies, so you have
10 lost that. Now the room is getting the heater up. The
11 Limerick predicts it is about three to four hours. The
12 pump may not be operational. That is the scenario
13 really behind that sequence.

14 MR. EBERSOLE: Okay. I have got it. Thank
15 you.

16 MR. OKRENT: With regard to loss of all AC
17 power, is it the off-site power or the on-site power
18 that one expects might be restored sooner, and whose
19 restoration time then ends up being the driving force?

20 MR. CHELLIAH: Well, probabilistically, the
21 Limerick PRA says you should be able to get power within
22 four hours. Otherwise, you have some other battery you
23 need for some other start and control --

24 MR. OKRENT: You are answering a different
25 question. Let's say you have four hours. Do you have a

1 better chance of getting off-site power and on-site
2 power back in the four hours, assuming you lost both in
3 the beginning?

4 MR. THADANI: Dr. Okrent, at least based on
5 some of the generic studies, I don't know specifically
6 for Limerick, the data seems to indicate that there is a
7 much greater likelihood of recovering off-site power
8 than on-site power.

9 MR. OKRENT: Okay. That leads, then, to a
10 second question.

11 MR. KERR: The other answer would have, too,
12 wouldn't it?

13 MR. OKRENT: No.

14 (General laughter.)

15 MR. OKRENT: Your estimates of the likelihood
16 of restoring off-site power are based on experience with
17 the loss of off-site power and the time to restoration
18 in the past, I assume.

19 MR. THADANI: That is correct.

20 MR. OKRENT: To what extent does the
21 experience depend on the rolling reserve or the backup
22 capability? Is that an important factor, in your
23 opinion?

24 MR. THADANI: Dr. Okrent, again, I believe
25 that that does play a major part, but I don't recollect

1 various estimates, but I do know that for different
2 regions, the likelihood of recovering off-site power to
3 the pump as a function of time, there are some
4 differences, and in some cases the differences are quite
5 significant.

6 MR. DKRENT: Let me get to the question then.
7 I read that in the future utilities may for one reason
8 or another be running with less reserve capacity than
9 they have had in past years, partly because public
10 utility commissions might want to keep rates down and
11 say, do this, don't kill the plants, or whatever.

12 I am just wondering whether that has been
13 factored into your estimates. At least let me leave it
14 as a thought for the experts on off-site power
15 restoration frequency, okay? It does not have to be
16 answered today.

17 MR. CHELLIAH: Well, a general comment is, BNL
18 may use PJM reliability data.

19
20
21
22
23
24
25

1 MR. EBERSOLE: Mr. Chairman, let me ask a
2 question. The revelation that it was ambient
3 temperatures in the HPCI and RCI rooms that shut them
4 down and caused trouble leads to the next question.
5 This is an old boiler, and these are steam turbine
6 pumps, steam turbine-driven pumps. There are trip
7 circuits based on rising ambient temperature which are
8 anxious to close off steam flow as ambients rise on the
9 thesis that they have broken pipes.

10 This is an old topic. I hate to bring it up
11 again. But rising ambients automatically produce a
12 short-term effect right away of closing steam flow to
13 the turbines in a common-mode way. Did you find that
14 this plant had been cleansed of its deficiency and that
15 that did not hurt?

16 MR. CHELLIAH: I am not aware of such, Dr.
17 Ebersole.

18 MR. EBERSOLE: Is there anybody here that
19 knows that?

20 MR. PAPAZOGLU: We are not ready to answer
21 this question specifically, but I would like to make a
22 comment on that. There is in the context of the PRA a
23 whole issue of cooling the high-pressure injection
24 pumps. It is treated as a required action by the
25 operator. There is a point in, I think, 2 hours after

1 the loss of off-site power, loss of cooling, if you
2 want, in which the operator has to go down and open a
3 couple of doors to provide some alternative natural
4 circulation cooling.

5 Now, although this particular problem that you
6 raised -- and unfortunately, we do not have the right
7 person here; we may not have that included in the fault
8 tree -- I am sure that that quantitatively is somehow
9 included in the probability that the operator will
10 perform whatever actions are necessary to establish some
11 alternative for these high-pressure --

12 MR. EBERSOLE: He can override the closing
13 function; is that what you are telling me?

14 MR. PAPAIOGLU: I am not sure. I would also
15 like to comment on Dr. Okrent's question on the loss of
16 off-site power. The loss-of-off-site power event, as it
17 appears up in these charts and elsewhere in the study,
18 is mainly due to events that result in loss of off-site
19 power for the particular plant because of some sort of
20 circuit breaker opening or a line loss. It's not really
21 loss of the grid in such a situation, as the question as
22 the spinning reserve and the grid stability would be
23 pertinent.

24 We have treated that in a different way.
25 Given every and each initiator or initiating event, we

1 have assumed that the charge to this grid stability and
2 there is a chance that due to this charging we lose the
3 grid and that would result in a loss of off-site power,
4 which we think is somehow qualitatively different than
5 the other losses of off-site power and would take much
6 more time to restore and would be a much more severe
7 event.

8 Now, the probability of losing the grid
9 because of getting out the grid was 10^{-3} that was also
10 assumed in WASH-1400. Whether this is coupled to the
11 present state of the particular grid or whether it will
12 be still applicable 5 years from now when the grid
13 reserve is going to be much less, is a very valid
14 question.

15 MR. EBERSOLE: Bill, may I ask one more? Is
16 this plant not characterized by minimum tie-up to
17 off-site? How many lines are outgoing and incoming?

18 MR. PAPAZOGLU: They have, I believe, a total
19 of five lines.

20 MR. EBERSOLE: It's well intertied?

21 MR. PAPAZOGLU: Yes.

22 MR. KERR: Please continue. By the way, my
23 plans are to recess for lunch at 12:30.

24 (Slide.)

25 MR. CHELLIAH: This slide shows the

1 distribution of core damage frequency among various
2 classes of accident. According to the Limerick PRA,
3 each class is a group of accident sequences which are
4 characterized by the containment's physical condition
5 and how rapidly the core is damaged.

6 Class I is some of the transients that you get
7 involved: loss of coolant inventory, this involves loss
8 of heat removal capability from the containment
9 (indicating). Here the containment fails before the
10 core melt, this particular one.

11 The Class III and IV, they are the same as
12 Class I and II except it is initiated by no scram
13 event. The BNL review indicated that even though this
14 Class I is dominant in core damage frequency, this
15 particular one and this one (indicating) are very high
16 risk contributors.

17 Also, this particular slide shows how it
18 compares with the WASH-1400 value. They estimate the
19 mean value that's the Limerick total value. As you see
20 here, the increase in each class due to the BNL's review
21 is also an order of magnitude.

22 MR. KERR: Question. If I recall correctly,
23 in the Limerick PRA they included a feature whereby if
24 you got into a situation where you were starting to
25 overheat the containment, you could vent, assuming there

1 had been no fuel failure; that then reduced the
2 likelihood of getting into difficulty from your Class II
3 event there.

4 MR. CHELLIAH: If I recall, Dr. Okrent, the
5 Limerick PRA Revision 2 had a containment water pressure
6 relief system. The applicant removed that system in
7 quantifying these sequences.

8 MR. KERR: I see.

9 MR. CHELLIAH: That system doesn't exist in
10 Revision 4.

11 MR. KERR: That was my question. So these
12 would be the results if they did not have this
13 containment vent feature, whatever it was called?

14 MR. CHELLIAH: Yes.

15 MR. KERR: Has the Staff reviewed that
16 containment vent feature at all? And why did they
17 remove it in Revision 4?

18 MR. CHELLIAH: BNL reviewed the impact of the
19 removal of the system. They tell you what is the impact
20 on risk.

21 MR. THADANI: Dr. Okrent, while Mr. Chelliah
22 is looking --

23 MR. CHELLIAH: I have the result.

24 MR. THADANI: The Staff has not reviewed the
25 Limerick PRA. The Staff has not arrived at any

1 conclusions at all regarding the Limerick PRA and the
2 role of the containment overpressure recirc system. The
3 applicant initially considered the system; subsequently,
4 he reanalyzed without the overpressure relief system,
5 and Mr. Chelliah can tell you what the applicant said in
6 terms of the effect of removing that system on their
7 study.

8 MR. CHELLIAH: Yes. BNL reviewed this
9 particular assumption regarding the removal of the
10 overpressure relief system. They performed some
11 sensitivity studies. The result is if you include the
12 containment overpressure relief system, the total core
13 damage frequency will drop by 13 percent. That is
14 primarily due to this particular Class II sequence
15 frequency.

16 The fatality goes down 18 percent. The latent
17 fatality goes down by 6 percent. This particular
18 sensitivity is based on the Limerick PRA normalized mean
19 fatality values.

20 MR. KERR: Let me assume for purposes of
21 discussion that those are good numbers and everybody who
22 reviewed it would arrive at the same numbers. Are those
23 significant changes or not? How do you decide?

24 MR. CHELLIAH: Oh, as Mr. Thadani said, we are
25 in the process of reviewing this, and we will report our

1 evaluation of this particular BNL review.

2 MR. KERR: Do you not decide whether a number
3 is significant until you completed your review? It
4 seems to me you need to have some preconception of what
5 is important and what is not before you start the review.

6 MR. THADANI: Dr. Okrent -- pardon me, Dr.
7 Kerr. Clearly, the process one has to go through is to
8 look at when is containment overpressure relief systems
9 are important in their other aspects. I think there are
10 several other aspects to see what the impact of various
11 considerations might be on the estimated core melt
12 frequency and public risk. This is one feature which
13 makes the 10 percent or so impact on core melt frequency
14 or an 18 percent impact.

15 This does seem fairly important. But I think
16 one cannot just look at it in isolation. One has to
17 look at what else one might consider in the implications
18 of the other things to be considered.

19 As I indicated earlier to you, once we get to
20 a point where we have a reasonable degree of confidence
21 that the study is fairly complete and so on, we would be
22 looking at what the dominating risk is, how does the
23 risk compare with the risks at other sites. In this
24 case the earlier management decision was to compare it
25 to Peach Bottom and then to also bring in thoughts on

1 value impact. 10 percent at this stage seems reasonably
2 important. I don't know that it is very significant,
3 but it seems reasonably important.

4 MR. KERR: Well, if one follows what I
5 understand to be the safety goal, 10 percent or 18
6 percent would be significant only if it were near to or
7 bigger than the fatalities early or late which are goals
8 or quantitative guidelines. If 18 percent were below
9 that, one might eliminate it, but one would now go on to
10 an ALARA calculation to determine what to do about it.

11 MR. THADANI: That's what I was saying.
12 That's what I meant when I said value impact, that it
13 would be that kind of a consideration.

14 MR. KERR: But value impact consideration
15 arises only if you were below the quantitative
16 guidelines for risk, I think.

17 MR. THADANI: Are you saying that if it is
18 10^{-4} versus 1.1×10^{-4} ?

19 MR. KERR: I am saying all we have said is an
20 18 percent contribution, whatever the probability of
21 coremelt is, I don't know what relationship there is
22 with coremelt and risk which are part of the guidelines
23 if one finally adopts that approach.

24 Let's suppose that the ultimate risk is below
25 the guidelines and is 18 percent of something that is

1 within the guidelines. My interpretation of the
2 approach of the safety goal is that one would not
3 automatically correct the 18 percent even though it's a
4 big fraction of the total, the total below those
5 guidelines. One would now look and say, does it fall
6 within the ALARA criteria, whatever they finally are.
7 Either we will do something about it or we won't do
8 something about it, based on that determination and not
9 on the fact that it's 18 percent.

10 MR. THADANI: That's exactly what I am saying
11 also, that if you're below the guideline, indeed we
12 would look at it with that perspective.

13 MR. KERR: Okay.

14 MR. OKRENT: May I ask a couple of questions
15 related to this? I think you used the term something
16 like -- I am probably paraphrasing -- when you decide
17 that this PRA is adequate, then you will complete your
18 decision-making process. Am I correct?

19 MR. THADANI: I am saying that unless
20 something just sticks out there that says we should take
21 some action.

22 MR. OKRENT: Oh, yes. As was noted earlier,
23 there were several initiators not included in the
24 original PRA. Do they need to be included before you
25 can do your decision making or so-called external events

1 and perhaps other things?

2 MR. THADANI: My reaction would be that at
3 least in the short term that is unavoidable. If that's
4 the information we have.

5 MR. OKRENT: What is unavoidable?

6 MR. THADANI: We do not have quantitative risk
7 assessments of external events for this site. So
8 whatever decisions the Staff is going to make are going
9 to have to be based on -- that is, whatever decisions
10 the Staff makes which are influenced by the PRA would
11 have to be limited in this case to the internal events.

12 MR. OKRENT: Let me explore that a bit.
13 Assuming you found a terrible outlier and something came
14 out so large that Mr. Denton had to act one way or the
15 other, that would occur. So let's put those aside. All
16 right. Now, for example, a moment ago there was a
17 question raised in a discussion between you and Dr.
18 Kerr, well, suppose you are below the safety goal and
19 there is an initiator which could be reduced by a
20 certain amount, what does one do or not? How do you
21 know if you are below the safety goal and you are
22 missing several, let's say, well-identified initiators?

23 Furthermore, there are various things that are
24 not included in any of the current PRAs. So how do you
25 make your decisions unless there are these clear

1 outliers on which you know you have to act?

2 MR. THADANI: I think you have to make
3 decisions and recognize that your knowledge is not as
4 complete as you would like it to be.

5 MR. CKRENT: Well, what are we going to tell
6 the people in Pennsylvania? We have an incomplete study
7 and the risk is, after they make this change in the
8 procedure and they have recalculated this, we now come
9 out with these initial initiators at 9×10^{-5} , this is
10 less than 10^{-4} , we are going to apply ALARA, use
11 \$1,000 per man-rem, everything else, or just what?

12 If you don't do that, then how do you allow
13 for the missing initiators, the missing contributors in
14 the middle?

15 MR. THADANI: No. I think I would perhaps
16 change the emphasis somewhat. The emphasis has got to
17 be placed on the determining of the licensing basis and
18 the regulations and the criteria that are developed.
19 All you have here is yet some more information which is
20 helping you identify potential vulnerabilities at the
21 plant which may be well beyond what the plant was
22 designed for. Similar factors would indeed apply in
23 terms of external events.

24 But as you yourself pointed out earlier,
25 Sandia's report was pretty strong in the sense that they

1 didn't say what the risk from external events were for
2 Indian Point. They said, if we take the licensee's
3 analysis and their estimates, we would revise those
4 estimates by the following factors. There is a
5 considerable amount of controversy, of which you are
6 familiar, as to how reliable these estimates are,
7 especially when they come to these external events.

8 As far as Limerick is concerned, it was the
9 Staff's judgment that these methods were just not mature
10 enough, that it is more useful to try to learn about the
11 plant, and from that judgment obviously we got the
12 results from the reactor safety study.

13 Here the intent was to see, well, is there
14 something that we can analyze with the methods that we
15 know of today and are there any reasonable actions one
16 could take to improve the safety of the plant? But I
17 don't think one can say that there isn't a potential of
18 the external events being dominant in terms of their
19 contribution. It's the question of reliance on
20 deterministic criteria.

21 MR. OKRENT: Well, I must say that it is a
22 little bit bizarre that had the applicant at Indian
23 Point chosen to follow the path that the Staff in its
24 infinite wisdom was the right path for doing the PRA;
25 namely, analyzing for external events.

1 MR. KERR: Is it all right if we strike
2 "infinite wisdom"?

3 MR. OKRENT: He would have been computing
4 numbers smaller than 10⁻⁴, if I remember correctly for
5 the internal events, and it would be a rather different
6 ballgame. I guess I am trying to understand whether the
7 Staff proposes to proceed with Limerick and not bring in
8 external events or just what it is and why the Staff
9 thinks this is the right way to proceed?

10 MR. KERR: That's not a question. He said he
11 is wondering.

12 Is that a question?

13 MR. OKRENT: Are they going to include
14 external events? If not, why?

15 MR. KERR: We have a question. Are you going
16 to include external events?

17 MR. THADANI: At this stage, there is no
18 intent to include external events.

19 MR. OKRENT: Well, I will offer an opinion. I
20 won't be able myself to understand how you are going to
21 arrive at a judgment concerning a whole host of things
22 except for something that just stands out that must be
23 corrected.

24 MR. EBERSOLE: What is the basis for that, may
25 I ask? Is it that it is too nasty a thing to consider

1 or it's not important?

2 MR. THADANI: Mr. Ebersole, I hope it is
3 clear, and I will speak for myself, but the question is
4 not that it's too nasty to consider. I think the
5 question is that of methodology, whether one can
6 reasonably estimate risks from these external hazards
7 where the information base is very limited. As I said,
8 at this stage, I know of no Staff plans to require
9 treatment of external events.

10 MR. EBERSOLE: Is there a reason for that?

11 MR. THADANI: It's conceivable that once the
12 Staff develops some level of confidence that these
13 techniques can reasonably be defined and develop some
14 methods essential assumptions and so on that could well
15 be applied, the decision might well be quite different.
16 I am talking about today, at this stage, we just have
17 more questions about how to analyze these events than we
18 have answers.

19 MR. KERR: Let me say I think we ought to be a
20 little careful about the nomenclature we are using.
21 It's not quite accurate to say that the Staff is not
22 considering external events. They certainly are in the
23 licensing process. They are not analyzing external
24 events using the PRA. But even if they did, it is not
25 clear what they could do about it with existing

1 regulation.

2 MR. EBERSOLE: Well, the Indian Point analysis
3 included it.

4 MR. KERR: The Indian Point analysis included
5 it, but I asked the question: Suppose that the Indian
6 Point analysis shows that the risk is unacceptably high
7 but the plant meets all existing regulations? And the
8 answer I got was: The Staff didn't know what it was
9 going to do if that was the circumstance that turned out
10 to be the case.

11 Now, suppose you do this for Limerick, you do
12 the PRA, and it turns out the risk is high. I don't
13 know on what basis. But the plant meets all existing
14 licensing criteria. What do you do? You meet the
15 existing regulations, you follow the regulations? Or do
16 you change your regulations so that they include PRA?
17 The existing regulations do not include PRA.

18 MR. EBERSOLE: I guess this is the first PRA I
19 have heard of that has studiously excluded external
20 events.

21 MR. GKRENT: No. To the contrary, only really
22 Zion and Indian Point made a fairly systematic attempt,
23 although there have been some minor attempts by others.

24 MR. EBERSOLE: At Zion it was a predominant
25 factor, wasn't it, the seismic aspect?

1 MR. OKRENT: As estimated in the licensee's
2 submittal. There are other submittals that find other
3 contributors.

4 MR. SCHWENCER: Al Schwencer from the Staff.
5 I would like to make a comment on how the scheduling of
6 the PRA is going for Limerick in terms of the overall
7 Staff review. There have been a couple of items
8 identified, the potential for a temperature in a room
9 adversely affecting components and the question of being
10 able to vent to prevent an overpressure. Earlier at
11 Indian Point the comment was raised related to these
12 various matters. So as we identify items that could
13 potentially impact these, these could be candidates for
14 a more in-depth review by the Staff in its complete
15 licensing review.

16 I would fully expect that I have got some
17 notes on this temperature problem. It's similar to
18 Brunswick and other areas. So we would want to check
19 and see whether this can reasonably be done in the case
20 of taking a concern to the applicant, not necessarily
21 waiting for an answer.

22 MR. KERR: I would point out that if this is
23 what you are using it for, you certainly do not have to
24 use a full-fledged PRA. You can identify things that if
25 they got too hot wouldn't operate, without doing a PRA.

1 This may be a fallout of PRA.

2 MR. SCWENCER: I would expect that the
3 temperature problem in Appendix R would have been picked
4 up in the normal course of the review. The
5 overpressurization, the Staff is already looking at that
6 in terms of emergency procedures for Staff. So that is
7 being picked up. I just pick them as examples. The
8 Staff is going to catch those specific things anyway.

9 MR. KERR: I didn't say "would." I said
10 "could." It certainly is no criticism of the Staff, I
11 think, to say it cannot review everything, every item in
12 detail. My point was that one does not have to go
13 through a full-fledged PRA to catch that sort of thing.

14 Mr. Okrent.

15 MR. OKRENT: I think Mr. Thadani indicated a
16 problem with the availability of methodology for
17 analyzing the so-called external events, and that was
18 the basis for not doing it at Limerick. While I
19 certainly would not by any means argue that there exists
20 a very good methodology, nevertheless there is a
21 methodology that has been applied to Zion and Indian
22 Point for fires, for earthquakes, and for wind. In
23 fact, if I can recall the discussion earlier this
24 morning, the Staff thinks as a result of some of these
25 things it should take some steps or at least it is

1 talking to the licensee about some steps on seismic and
2 it has gotten Mr. Denton thinking about should it do
3 something about things and when.

4 So I have this curious situation on the one
5 hand where there is no methodology for Limerick, on the
6 other hand we have some results for Indian Point that
7 are the basis for not just more studies but really
8 short-term kinds of action.

9 Am I missing something?

10 MR. KERR: We could carry on our debate later
11 on. But I would certainly, if I were the applicant,
12 like to have some idea of what the Staff is going to do
13 with the results of one of these things before I spent
14 the manpower and effort that is necessary.

15 It is one thing to carry out a study to look
16 at some criteria that have been established you know
17 what you are trying to determine; it's another thing to
18 say, go carry out a study, we will certainly decide what
19 to do with it after we have got it. That is sort of
20 what Limerick was faced with, it seems to me. It sort
21 of makes it an experimental thing, and maybe one or two
22 of these things isn't bad, but at some point somebody
23 needs to decide what are the criteria that are going to
24 be used in the decision-making mode once we have gone
25 through this exercise.

1 MR. OKRENT: I agree with that. In fact, the
2 study of a kind has been done for Limerick, and there is
3 a lot of effort being spent to review it, and we are in
4 the middle of this. And the Staff seems to think it's
5 going to somehow make decisions with what I would call
6 an incomplete perspective. As just one example, the
7 design-basis earthquake for Limerick, if I recall, is
8 .15 g. Now, it may turn out that there is lots of
9 capacity everywhere in that plant to take less frequent
10 earthquakes than that but --

11 MR. KERR: On the other hand, we have to
12 remember that something cracked the Liberty Bell at some
13 point.

14 MR. BENDER: It was quality assurance.

15 MR. OKRENT: I am not sure --

16 MR. KERR: Would you agree to a 1-hour recess
17 for lunch at this point?

18 MR. OKRENT: That would be fine.

19 MR. KERR: I declare a 1-hour recess.

20 (Whereupon, at 12:40 p.m., the meeting was
21 recessed, to reconvene at 1:40 p.m., this same day.)

22

23

24

25

1 This slide gives some of the --

2 MR. KERR: Excuse me. If I try to draw a
3 conclusion from the graph presentation --

4 MR. CHELLIAH: The previous one?

5 MR. KERR: -- should I conclude that ATWS is
6 no longer a concern or that ATWS is still a concern
7 because of conclusions that have been reached?

8 MR. CHELLIAH: Well, by looking into BNL's
9 latent fatality calculation, although you have an
10 alternate fix, still this particular sequence gives a
11 higher contribution to the early fatalities. You will
12 see that in BNL's draft NUREG report.

13 MR. THADANI: Dr. Kerr, what Mr. Chelliah is
14 doing is presenting to you results of the assessment.
15 Whether that is necessary or sufficient as far as ATWS
16 is concerned is being considered separately. The point
17 of Mr. Chelliah's presentation here really is that on
18 Limerick they have implemented what used to be
19 characterized as Alternate III-A and with that system in
20 place here is how the risk might look like from ATWS.

21 MR. CHELLIAH: That's right.

22 MR. KERR: Well, that says frequency of
23 coremelt per reactor-year. He also mentioned comments
24 about risk. And one could conclude, I think, that the
25 contribution to frequency of coremelt is, what, 10⁻⁷ ,

1 thereabouts?

2 MR. THADANI: No. About 10⁻⁵, Dr. Kerr.

3 MR. KERR: Is the whole thing ATWS? I thought
4 ATWS was -- well, tell me what fraction ATWS is.

5 MR. THADANI: Essentially all of it is ATWS in
6 those two classes.

7 MR. CHELLIAH: We have these two alternates
8 that come to 1.1 x 10⁻⁵.

9 MR. KERR: Then I don't understand that.

10 MR. THADANI: If I may just simplify, the
11 total coremelt frequency as estimated by BNL is about
12 10⁻⁴ for Limerick, and their estimate of ATWS
13 frequency leading to coremelt is about 10⁻⁵. And the
14 distinction is that there are different classes of
15 releases and the ATWS events happen to fall in what we
16 will call Class III and Class IV types of releases.

17 MR. KERR: Does the bar graph there represent
18 the Limerick calculation or the BNL calculation?

19 MR. CHELLIAH: This represents the PRA. The
20 whole thing represents BNL's review. So the unshaded
21 area is really the increase due to three major items
22 which I pointed out in the first slide. The support
23 system redundancy --

24 MR. KERR: BNL would conclude that within
25 Class III there is 10⁻⁵ contribution. And how much of

1 that was ATWS? All of it?

2 MR. CHELLIAH: This increase --

3 MR. THADANI: The answer is yes, Dr. Kerr.

4 MR. KERR: Since the other is less than
5 10^{-6} , the contribution is about 10^{-5} .

6 MR. SEIDENSTICKER: It is 10 percent either
7 way.

8 MR. CHELLIAH: I would note this Class IV
9 combined with the three containment failure modes gives
10 a significant risk.

11 MR. KERR: Gives what?

12 MR. CHELLIAH: I will repeat this. The Class
13 IV sequence when it combines with the three containment
14 failure modes will give you a higher release and thus a
15 consequence.

16 MR. KERR: Okay. I understand that.

17 Continue, please.

18 (Slide.)

19 MR. EBERSOLE: Just one second. Before you
20 get away, is that because ATWS is likely to be a sudden
21 thing?

22 MR. CHELLIAH: Are you referring to this?

23 MR. EBERSOLE: Right. And therefore,
24 evacuation procedures are not effective?

25 MR. CHELLIAH: This particular sequence, the

1 pool temperature rises very quickly, so you have a
2 containment failure, so there is rapid core damage.

3 MR. EBERSOLE: What I am saying is, does it
4 account for the fact that evacuation procedures are not
5 effective for that kind of containment failure since it
6 is so sudden?

7 MR. THADANI: Yes, Mr. Ebersole. That is an
8 important consideration.

9 MR. OKREFF: But how early is early?

10 MR. THADANI: I will ask Dr. Pratt to respond
11 to that. I don't recall the time.

12 (Pause.)

13 MR. PRATT: My name is Pratt from Brookhaven.
14 This kind of accident sequence we are talking about
15 failing the containment building in about .7 of an
16 hour. The core melt occurs after failure of the
17 containment building in about 1.2 hours. And that does
18 not give you much time for evacuation; that is correct.
19 The correct calculations would reflect that lack of time.

20 MR. EBERSOLE: When you weight this result
21 against this probabilistic arrangement here, does it not
22 turn out that the ATWS is the predominant hazard?

23 MR. PRATT: It is extremely important. It
24 dominates the acute fatalities simply because for the
25 Class I sequence we don't predict any acute fatalities.

1 So although the probability is much lower, it is the
2 major contributor too. To the latent fatalities it has
3 a greater impact.

4 MR. MARK: You make a reference to the CRAC
5 calculation. Is that the same ridiculous thing that was
6 used in the reactor safety study?

7 MR. PRATT: Yes.

8 (Laughter.)

9 MR. MARK: They had them evacuating downwind
10 along with the cloud so they could keep up with it and
11 so forth.

12 MR. ACHARYA: My name is Sarbes Acharya, from
13 NRR. The Staff is using the CRAC Code for the
14 site-specific application. This was different from that
15 that was used in the RSS. We can account for the delay
16 time before evacuation and also the speed, each of which
17 would have been assessed by considering the road network.

18 MR. MARK: I am particularly anxious that such
19 a code should allow for the possibility that if a cloud
20 is coming from the west that a person might have enough
21 sense to walk north instead of east.

22 MR. ACHARYA: What we say doesn't assume that
23 the individual is following a cloud. However, it does
24 assume that the trajectory of the individual moving
25 might pass an active segment of the cloud movement.

1 MR. KERR: Please continue.

2 (Slide.)

3 MR. CHELLIAH: Moving on to the containment
4 response analysis areas. BNL includes some sensitivity
5 analysis of some of these items. In performing the
6 sensitivity analyses, BNL used Limerick PRA frequency
7 and Limerick PRA normalized to the mean fatality
8 values. Using those two, BNL started reviewing the
9 appropriate containment event trees. They quantified
10 the risk against a value of a factor of 2 increase and a
11 1.7 percent increase in the mean. This turns out to be,
12 according to BNL, very conservative. Also, this one
13 (indicating).

14 MR. KERR: How does one remove pool flashing
15 at containment failure?

16 MR. CHELLIAH: Dr. Pratt will explain that.

17 MR. PRATT: Let me explain a little bit what
18 we did up here. Case 1 there, the first item is really
19 a sensitivity study that we carried out looking simply
20 at the containment event trees. What we did, we
21 accepted the frequency of the damage dates in the PRA
22 and also the consequence analysis in the PRA and just
23 simply looked at the appropriateness of the branch point
24 split fractions in the event trees.

25 So those are the type of value changes you

1 will get resulting from some of our concerns with the
2 trees. The main contributor there was that we felt that
3 the containment event trees were applied to all classes
4 of accident sequences where two of the classes, Class II
5 and Class IV, were actually a failed containment prior
6 to core meltdown.

7 We felt that the probability of the steam
8 explosion, which was given as being the combined
9 probability of not only the steam explosion occurring
10 but also failing the containment building as well, was
11 somewhat low because the building was already failed and
12 one only had to consider the probability of the steam
13 explosion occurring. It was not necessary for that
14 explosion also to fail the containment building.

15 So that increase is a mixture of a number of
16 things. That is one of the concerns that we had, and
17 that impacted acute fatalities significantly.

18 We were also concerned that the trees gave a
19 50-50 split to a leakage of the containment building as
20 opposed to an overpressurization value. So what we did
21 was we looked at the sensitivity, assuming that there
22 was a catastrophic failure 100 percent of the time
23 rather than 50 percent of the time. That had an impact
24 mostly on the mean latent fatalities because it impacted
25 the category that was dominated by the latent fatalities

1 and it didn't have any acute fatalities, so there was
2 very little impact on acute in that assumption.

3 We also looked at the appropriateness of
4 assuming the various failure positions. In the PRA there
5 were assumptions made about where the crack would occur
6 in the wall, whether it would be in the drywell, whether
7 it was in the wetwell; if it was in the wetwell, would
8 the suppression pool drain. So we did some pretty bad
9 things there in moving around those probabilities.
10 Again, we got an impact mostly on the acute fatalities
11 and some impact on the mean acutes.

12 Now, in the actual report we have listed the
13 limiting -- excuse me -- the limiting value of those
14 assumptions. What is up there is a compound value which
15 is our, if you like, best shot. So we looked at each of
16 those concerns individually and measured the impact on
17 risk individually; then we put the whole thing together
18 as what we have considered to be a best estimate, if you
19 like. And those are the changes we would get.

20 MR. KERR: Let me repeat my question. How
21 does one remove pool flashing at containment failure?

22 MR. PRATT: That is number 2, I guess. Number
23 2 for Class I sequences, the assumption was made that at
24 containment failure the suppression pool would flash.
25 This is in spite of the fact that the pool was

1 calculated to be subcooled, not only by ourselves but
2 in the Limerick PRA. We didn't see how by
3 depressurizing the containment building and bringing the
4 pressure down from 144 to atmosphere when the pool was
5 way subcooled, that it would flash. So we felt that was
6 a very large conservatism in the calculation.

7 We only did it for Class I sequences because
8 that's the only one where the pool was subcooled. The
9 reason why it only impacts latent fatalities and not
10 acute fatalities is because for Class I sequences there
11 are no acute fatalities predicted for the class. So it
12 impacts latents only.

13 MR. MARK: I have what I think are two
14 questions. You have factors of 2 and 3 in the estimates
15 of fatalities. You have a factor of 10 very nearly, 7
16 anyway, in the estimate of core damage frequency. Is
17 the BNL study then using a different set of assumptions
18 about the effects of a given release or the amount of
19 the release or what? Because if you had the same
20 release versus effects, you would have a factor of 10
21 showing up here instead of 2 or 3.

22

23

24

25

1 MR. PRATT: No. Ten is the frequency of the
2 occurrence of the accident sequence. This is then just
3 the probability, if you like, of a certain containment
4 failure mode occurring given their consequence
5 analysis. We then went on and did our estimate of what
6 the release fractions would look like in certain cases,
7 and that is Item 2 there. We actually got a reduction
8 in consequences by a factor of 3, so that you stop and
9 multiply the thing throughout, you get an increase of a
10 factor of 10 for the probability, perhaps an increase of
11 a factor of 2 for latent fatalities due to the changing
12 of the containment event trees, but then you divide by 3
13 because of the conservatisms in the source term.

14 MR. MARK: So you really change the approach
15 at that point instead of following the Limerick or the
16 RSS approaches.

17 The other question, what are you using to
18 correlate exposure and latent fatalities? Are you doing
19 BEIR-II, BEIR-III or some 1945 estimate?

20 MR. PRATT: No.

21 MR. ACHARYA: This is the central estimate for
22 RSS in the CRAC. The central model is not applied to
23 the breast cancer.

24 MR. MARK: So you pay no attention to the BEIR
25 report?

1 MR. ACHARYA: We have calculated -- some
2 sensitivity analysis has been done by the Staff. If one
3 does calculate it on the organ basis, as is done in RSS,
4 the total latent cancer fatality resulting therefrom is
5 almost the same as using the BEIR.

6 MR. MARK: The same as using BEIR-III?

7 MR. ACHARYA: Yes.

8 MR. MARK: There is no possible way of using
9 BEIR-III. There are six different estimates in there.
10 There is the majority report, the Chairman's report, the
11 minority report, and there are two other ways of reading
12 them, on either an absolute or relative basis. There
13 isn't a number you can get out of that.

14 MR. KERR: That is not a question; it's a
15 statement.

16 MR. MARK: You said they use BEIR-III.

17 MR. ACHARYA: I didn't say we used BEIR-III.
18 If one would do some sensitivity analyses -- let me
19 repeat this again. In the central estimate model of
20 WASH-1400, which was some adjustment to the BEIR-II on
21 the basis of a low dose rate and low delivered dose,
22 this model doesn't have the cancers. They are in
23 WASH-1400. This is a plateau of the plateaus used, and
24 besides that, the risk calculations were on the organ
25 basis instead of the whole body basis of BEIR-II.

1 Now, if one uses the model that has already
2 been calculated into the CRAC, then one won't get the
3 same number from the latent cancer fatality; by using --
4 some study has been done, some calculations have been
5 done by our research contracts that are going on at
6 Harvard University, and the equivalent results resulting
7 from here, the CRAC model and the BEIR-III, I cannot
8 provide more details.

9 MR. MARK: In effect, the numbers come from --

10 MR. KERR: Did you hear Harvard? You can't
11 argue with that.

12 MR. MARK: In effect, the numbers coming from
13 using the RSS calculation you have compared with
14 BEIR-III or at least one of the six options you have in
15 BEIR-III and find that it fits one of those.

16 MR. KERR: That is not a question; that is a
17 statement.

18 Other questions? Mr. Ebersole?

19 MR. EBERSOLE: Yes. May I ask a question
20 about Item 2 up there. I guess I didn't understand what
21 it meant. But the thing I am curious about, when you
22 experienced containment failure in this design, was it
23 automatic that you lost pump suction and therefore
24 proceeded to core melt at that point if you hadn't
25 already?

1 MR. KERR: Do you understand the question?

2 MR. CHELLIAH: Could you repeat the question?

3 MR. EBERSOLE: On containment failure, was

4 this design so configured that you needed the
5 containment overpressure of the uncondensable? The

6 early BWR designs had to have that. I don't know

7 whether this vintage had fixed it or not.

8 MR. CHELLIAH: This particular item, we are

9 talking about core melt in a containment. In other
10 words --

11 MR. KERR: I think his question is more
12 specific.

13 MR. EBERSOLE: My question is merely: When you
14 fail the containment, do you assume pump suction?

15 MR. PAPAIOGLOU: Yes. The assumption for the
16 PRA calculations was once you lose containment, that
17 means core melt.

18 MR. EBERSOLE: Thank you.

19 MR. KERR: Other questions before he proceeds?

20 [No response.]

21 MR. KERR: Please proceed.

22 MR. CHELLIAH: The important point of this
23 presentation of the slide is BNL review of containment
24 response analysis included many areas grouped into four
25 categories here, four major items. You can see that it

1 nullifies the effect. This is the observation one can
2 get, really, out of BNL's view of containment response
3 analysis.

4 MR. KERR: What does one observe? You say the
5 conservatism cancels out the nonconservatism?

6 MR. CHELLIAH: Yes.

7 MR. KERR: I wouldn't know that from the
8 slide. How would one conclude that from the slide? I
9 will accept your word that that is true, but I don't
10 understand how one concludes that from the slide.

11 MR. CHELLIAH: Maybe Dr. Pratt can explain the
12 conservatism in Item 2 and 4.

13 MR. KERR: Just from that slide you couldn't
14 conclude that, could you?

15 MR. PRATT: I think the slide is a little bit
16 busy. Perhaps it should be broken up and gone through
17 in somewhat steps, which would have shown it a little
18 better. I think Case 1 is really something that we did
19 in the report in Chapter 6 of our draft report. The
20 other items there, 2, 3 and 4, were developed in Chapter
21 7. There we are really talking about the way that the
22 core meltdown phenomenology, containment failure would
23 impact the release fractions and what impact that would
24 have on the consequence analysis.

25 I think Point 2 is really the important one in

1 the sense that our best shot, if you like, would be that
2 we would reduce the consequences because of this
3 nonconservatism by a factor of 3. Then what we did was
4 to say that, all right, there is uncertainty about that,
5 and the other analysis we did in the rest of Chapter 7
6 was really summarizing the last two points, which was an
7 assessment of the upper and lower bounds.

8 Point number 3, if you like, represents an
9 upper bound because there we are looking at the
10 sensitivity of the deposition model in CORRAL in terms
11 of plate-out of the aerosols and so forth. And also it
12 is not just that but it is looking at alternative core
13 meltdown sequences that might result in early failure of
14 the containment building. We considered that that would
15 increase the latent fatalities by about a factor of 3,
16 and that tended to be our upper bound in terms of
17 uncertainty in terms of direction.

18 In the downward direction, PICO came in with a
19 somewhat different picture as to how the core melt might
20 progress rather late into our review of the PRA, and
21 what I tried to do in Chapter 7 was to paraphrase their
22 new position. It was essentially something that would
23 replace Appendix H of the PRA and it would be a new
24 sequence of how the core would melt down.

25 If you go with this new description, it would

1 reduce risk on the Category 1 latent fatalities by about
2 a factor of 300. So there is an extremely large
3 potential for risk reduction.

4 MR. KERR: You said that modal walked in off
5 the street or something?

6 MR. PRATT: It rather late in the review
7 at a meeting between the staff and --

8 MR. KERR: Does it have any basis in physical
9 reality?

10 MR. PRATT: It is another Bob Henry special, I
11 guess. What they are postulating is that instead of the
12 core material being distributed across the diaphragm
13 floor, remaining there producing a lot of noncondensable
14 gases and failing the containment building after two or
15 three hours, after it gets through the vessel, that
16 indeed a good portion of it would get through holes in
17 the floor, would drop into the suppression pool, would
18 quench in the suppression pool, form a coolable debris
19 bed with particles of just the right size so that they
20 would not dry out. So there is no potential at that
21 time for overpressurization. Steam explosions are a
22 real possibility, so you have to sit around and wait
23 until the heat is generated. That is an extremely long
24 time.

25 Our calculations indicated --

1 MR. KERR: Did you try this model just because
2 it was new, or did you have some reason to think it was
3 superior to earlier models, or is that in the report?

4 MR. PRATT: It is in the report, and indeed,
5 that forms our lower bound calculation. It remains, I
6 believe -- the documentation is now in, and correct me
7 if I am wrong, which does document that new position.

8 MR. KERR: Does document mean describe?

9 MR. PRATT: Yes.

10 MR. KERR: Or justify?

11 MR. PRATT: Justify and describe, I would
12 hope. We have to review that. As I say, that has just
13 arrived. What I did in that PRA was my understanding of
14 what I thought they were talking about in the meeting.
15 In the final report, we will have the benefit of
16 studying that documentation and, I hope, doing a better
17 analysis.

18 MR. KERR: Thank you.

19 MR. CHELLIAH: This PRA is Revision 4.
20 Recently we have received Revision 5. We haven't looked
21 into it but we are going to.

22 [Slide]

23 Now I would like to give a summary of BNL's
24 findings on the core damage frequencies higher than
25 Limerick PRA, higher than WASH-1400 by a factor of about

1 3 higher. The most dominant accident sequence is loss
2 of offsite power, followed by the failure of high
3 pressure and low pressure coolant injection. The
4 contribution to the total core damage frequency is about
5 42 percent.

6 These (indicating) are the two items which are
7 common to all those seven dominant sequences that I
8 previously showed you. The risk statement says -- in
9 your handout I have put it down. I would like to say
10 here recently, about yesterday, we received some comment
11 regarding the BNL review. Perhaps I would like to get
12 Dr. Trevor Pratt to comment on that.

13 MR. PRATT: Trevor Pratt from Brookhaven.

14 I guess this is where your suspense is all
15 broken in terms of the major BNL error. The error crept
16 into the site model, to the CRAC calculation. In order
17 to compare our results with the Limerick PRA, what comes
18 out of the CRAC code for the latent fatalities is
19 integrated over 30 years, and to put it on a 30-year
20 basis, one divides by 30. We unfortunately also did
21 that with the acutes, which is incorrect. So that the
22 acutes that are reported in our report are a factor of
23 30 low.

24 The reason we did not pick up this error is
25 that I think when we were comparing the results with the

1 Limerick PRA, the comparison was fairly good between our
2 CRAC analysis and theirs. We were about a factor of 3
3 higher on latent fatalities. We had about the same
4 ratio on acutes. What we are really saying now is there
5 is a significant difference, factors of between 10 and
6 100, between our prediction of acute fatalities relative
7 to theirs.

8 Now, in terms of the impact that that has on
9 the report, let me put it into perspective. We did not
10 review the site model. The site model will be reviewed
11 and is the responsibility of the Accident Evaluation
12 Branch at NRC. We tended to use the CRAC Code really as
13 a way of giving us a measure of how our changes or our
14 perception of how the containment may fail, the
15 phenomenology of core melt would impact risk. So we
16 have tended to talk in terms of relative changes, which
17 is what we talked about on the previous Vu-graph. That
18 remains unchanged.

19 The latent fatality calculations in the report
20 are correct. The containment evaluation is fine. The
21 only thing that is of concern is when we come to the
22 bottom line risk, and when we do compare directly the
23 estimate of acute fatalities with those in the Limerick
24 PRA, there are now significant differences. This is
25 under very close review at the NRC, and as part of our

1 final report, we would have the benefit, I believe, of
2 that review, so that the bottom line risk calculations
3 that we come up with should reflect that review in the
4 final report. So that there will be some changes.

5 What we have attempted to do in the BNL report
6 is to normalize the calculations so that we are looking
7 at the relative change. Once a siting model is
8 established, we would still expect that these relative
9 changes would then be superimposed on the new values.

10 MR. MARK: When you estimate latent fatalities
11 from the CRAC Code, do they penetrate out to 50 miles or
12 500 miles or 1 rem or 1 millirem or what?

13 MR. ACHARYA: It goes out to 2000 miles.

14 MR. MARK: At that radius you are getting a
15 millirem or something per person?

16 MR. ACHARYA: Yes.

17 MR. MARK: Then you multiply that by man rem
18 times 10⁻¹⁴ for those effects or something?

19 MR. ACHARYA: Yes.

20 MR. MARK: That is a number that one could
21 develop, all right. It doesn't seem to have that much
22 meaning.

23 MR. KERR: Mr. Okrent.

24 MR. OKRENT: Could I understand on page Roman
25 XXII, where you give a table of results and you report

1 average latent fatalities per year --

2 MR. KERR: Excuse me. This document to which
3 you refer is?

4 MR. OKRENT: The document to which I am
5 referring is attached to a letter from Mr Papazoglou to
6 Mr. Chelliah, dated October 15, 1982.

7 MR. CHELLIAH: That is our draft NUREG report,
8 yes.

9 MR. OKRENT: This table, which gives average
10 latent fatalities and then says "(per year)," is this
11 per year of reactor operator or is it per year that
12 these things occur?

13 MR. MARK: Year 49.

14 MR. ACHARYA: Maybe BNL staff should answer
15 that. What the CRAC code out-propels, it is the latent
16 cancer fatality per reactor year of operation over the
17 lifetime of the exposed populace. In fact, in the CRAC
18 model the plateau --

19 MR. KERR: Would you repeat that? It is the
20 number of fatalities averaged over the life of the
21 population divided by the number of --

22 MR. ACHARYA: A different practice is used by
23 different analysts. In NRR we don't divide that. So I
24 said earlier it should be up to the BNL staff to respond
25 to this.

1 MR. KERR: Does the BNL staff have in mind
2 what the original question was?

3 MR. PAPAZOGLU: Papazoglou from BNL.

4 The third row of the statement represents the
5 fatalities per year and per reactor year of operation.
6 In other words, it is divided by 30.

7 MR. OKRENT: Well, I thought that that was a
8 practice that people would stop using in discussing
9 latent effects. In the first place, as the table has
10 shown, it is completely unclear to the reader, and it
11 could easily be interpreted as per reactor year just as
12 is the executive summary in the report from WASH-1400,
13 and I must say I am surprised that the practice
14 continues.

15 I will just leave that as a comment, not a
16 question.

17 Could I ask where in this report you discuss
18 this question of flashing or not of the containment and
19 where you discuss what you assumed about the effect of
20 containment failure on core melt?

21 MR. CHELLIAH: I believe Section 6, the
22 beginning of accident sequences. Maybe Dr. Trevor can
23 specify exactly.

24 MR. PRATT: Dr. Okrent, your first question
25 was where we talked about flashing?

1 MR. OKRENT: Yes, in the report.

2 MR. PRATT: That is described in the
3 quantification of uncertainties in Chapter 7.3, and
4 specifically it is under 73.4 where we talk about the
5 early -- I'm sorry, no, no, no. That is the new
6 scenario one. You are talking about the flashing
7 calculation. That is discussed in 7.2, the audit
8 calculations.

9 MR. OKRENT: And that is where I will find
10 what assumption you made concerning the relationship
11 between early containment failure and core melt?

12 MR. KERR: You could reword the question by
13 saying where will I find the relationship between
14 fatalities and early --

15 MR. OKRENT: Not fatalities. Containment
16 failure and its subsequent effect on core melt. Mr.
17 Ebersole had asked the question earlier to which an
18 answer was given, and I just wanted to see whether the
19 words here conformed with my recollection from a hurried
20 scanning of this report on the airplane.

21 MR. KERR: Do you understand the question?

22 MR. PRATT: Are you talking about those
23 classes in which we get overpressurization failure of
24 the containment, failure first which leads to the core
25 damage and failure of the pumps?

1 MR. OKRENT: Yes, sir.

2 MR. PRATT: That is discussed in Chapter 7.2,
3 the audit calculations, and again, if you are looking at
4 the table of contents, we do the MARCH, the CCRRAL and
5 the CRAC analysis, and we follow the Class 1, 2, 3 and 4
6 subparagraphs there. So if you look at Class 2 and
7 Class 4 descriptions, if you look at those descriptions,
8 that whole section, the way we divided it up, in Chapter
9 7.2 we really looked at what they had done in the PRA
10 and we tried to give, if you like, our calculations
11 independently using our codes and our understanding of
12 -- you know, eliminating things like flashing, which we
13 thought it was a great upper conservatism. Then in
14 Chapter 7.3 we went in and looked at certain areas where
15 we thought perhaps they may not have been conservative
16 and other areas where they may have been overly
17 conservative and tried to establish an uncertainty bound.

18 MR. OKRENT: Well, perhaps if while we are
19 talking about something else you can identify within one
20 or two pages where you discuss this flashing statement
21 and also where you discuss --

22 MR. PRATT: 7-44.

23 MR. OKRENT: Thank you. Is that the same place
24 where I will find the effect of containment failure on
25 core melt?

1 MR. PRATT: No. Again, if you want the bottom
2 line calculations, that would be done -- you would find
3 that in Section 7-23, which is the consequence
4 analysis. But the development of the MARCH-CORRAL
5 analysis, which gives you the release fractions, is
6 really discussed in several places there.

7 MR. OKRENT: It seems to me it is not a
8 MARCH-CORRAL kind of thing because I can conceive of
9 situations where the containment failed and you kept the
10 core from melting if you could get at it with water into
11 the reactor vessel.

12 MR. PAPAZOGLU: If I may, the assumption for
13 the calculations conservatively was that given
14 containment failure, core melt is inevitable. So there
15 was no credit taken for the situation that you described.

16 MR. OKRENT: Is this discussed in your report
17 or is it just something that is assumed?

18 MR. PAPAZOGLU: That was an assumption that
19 was made by Limerick and that is something that we
20 accepted as given.

21 MR. OKRENT: Okay.

22 MR. PRATT: If I may further add also, we did
23 recognize that as being a conservatism, and in Chapter 6
24 we do describe that point. We also mention that that
25 was a conservatism, and when we looked at the upper end

1 lower bounds in Chapter 6, we looked at specifically
2 that effect.

3 For instance, an interesting point from the
4 work is they have the Classes 2 and 4 in which you see
5 failure of the containment building leads to core melt,
6 50 percent of that probability, if you believe the
7 trees, have got a very good percent. They have got a 50
8 percent chance that there will be sufficient containment
9 leakage to prevent overpressurization failure.
10 Nevertheless, they did assume that that 50 percent did
11 fail and put it into that release category.

12 So again, that was a conservatism in the
13 calculation. If you have enough leakage to prevent
14 overpressurization failure, then you really don't have
15 any mechanism to calculate the point.

16 MR. EBERSOLE: What was that last statement
17 you made?

18 MR. KERR: You don't have any --

19 MR. PRATT: In order to progress to a core
20 meltdown, one assumes a catastrophic failure from 144
21 psi at a very rapid reduction in pressure. It is
22 assumed that that event, for a number of reasons, fails
23 the pumps, which stops coolant into the vessel and leads
24 to core melt. If you have a significant containment
25 leakage, which they assume in that containment event

1 trees would prevent such a catastrophic failure of the
2 containment building, it seems appropriate that it would
3 assume that that would lead on to core damage.

4 MR. EBERSOLE: Let me see if I can straighten
5 out that matter. Early on there were no standards for
6 NPHS requirements, so the Safety Guide No. 1, before
7 regulatory guides, were on NPHS. They confirmed at that
8 time that the retention of the noncondensable fraction
9 in the containment was essential to maintenance of NPHS,
10 which implied that even if you had a small containment
11 leak and lost the fraction of containment pressure due
12 to atmosphere, you lost pump suction. So even a modest
13 leak in the containment would ruin your pumping
14 function. Is this reactor designed that way? It is
15 just about at the vintage at which it just may be.

16 MR. PRATT: [Nods in the affirmative.]

17 MR. EBERSOLE: It means you don't have to have
18 anything catastrophic; all you need is a stuck valve.
19 You lose the atmospheric fraction and you have it.

20 MR. PRATT: So it may not be quite as
21 conservative as we thought.

22 MR. OKRENT: On page 2-2, it says, for
23 example, the low pressure core spray pumps can pump
24 saturated water. The RSS BWR requirement may not always
25 be met. So the implication here is that in fact it is

1 designed to meet that particular reg guide, which is
2 number 1, and furthermore, it is not completely clearly
3 to me just what all has been assumed in the analysis.
4 It is because of this early statement that I was trying
5 to find out why you gave the answer you did to Mr.
6 Ebersole. It may be correct, but I didn't get to that
7 conclusion from this early statement in your report.

8 MR. EBERSOLE: That last pair of lines up
9 there about core damage contributors. Could you qualify
10 something? Loss of high pressure coolant injection. In
11 the first place, this vintage of design was turbine
12 drive high pressure injection single train and was not
13 especially reliable, so the faith was placed in
14 automatic initiation of ADS, not human initiation of
15 it. There was a 90 second time delay where human
16 intervention was possible.

17 Does this mean that you are saying out there
18 that operators will inappropriately insert themselves in
19 an automated mode of operation and stop ADS?

20 MR. CHELLIAH: For this particular dominant
21 sequences --

22 MR. EBERSOLE: The bottom two lines, under
23 dominant core damage contributors.

24 MR. CHELLIAH: What is your question?

25 MR. EBERSOLE: The question is: There is only

1 a single train of high pressure coolant injection. It
2 is turbine driven in that vintage plant. I thought they
3 were all timed out to blow down after expiration of
4 about a 90-second time element. They were not dependent
5 on human function. Does this mean this design is
6 different?

7 MR. CHELLIAH: Well, as you may have seen, all
8 accident sequences here are induced by transients. For
9 transients this is not automatic.

10 MR. KERR: Excuse me. I don't think you
11 understood the question.

12 MR. EBERSOLE: Let me go through it again.
13 Failure of high pressure core injection, if I recall it,
14 was registered by the fact that one had double low level
15 in the boiler. That automatically triggered ADS. There
16 was a waiting interval of approximately 90 seconds
17 during which the operator could insert himself and
18 forbid ADS, but the ADS process was not dependent on
19 human response. Is this plant different and one must
20 manually initiate ADS if you get to double low level?

21 MR. CHELLIAH: For transients, yes, you need
22 human action to initiate this timely. Maybe Dr.
23 Papazoglou can explain how he selected the conditional
24 failure probability value of .002, I guess.

25 MR. PAPAZOGLOU: If I may try to answer the

1 question, in the particular design that was analyzed for
2 this revision of the PRA, the ADS does not start
3 automatically for transient events. It does start
4 automatically for LOCAS. But the second signal that is
5 necessary for initiating ADS is not necessary in
6 transient events. Therefore, the operator has to
7 manually initiate the pressurization for transient
8 events. He has to realize what is going on and take the
9 appropriate steps.

10 MR. EBERSOLE: The critical one is containment
11 pressure. So you are talking about transients which
12 amount to throughline loss of coolant. That is a
13 discrete step of transients. Any other loss is into the
14 containment and you get the secondary signal anyway.

15 MR. OKRENT: It goes into the suppression pool.

16 MR. EBERSOLE: It goes into the drywell. Oh,
17 no, you are right, it doesn't. Right.

18 MR. OKRENT: It will lose water but into the
19 suppression pool.

20 MR. KERR: Any other questions?

21 MR. EBERSOLE: You are right.

22 MR. CHELLIAH: Also, just one comment I wanted
23 to add, Dr. Ebersole. For Class 2 and 4 sequences, the
24 containment failing prior to core melt, the temperature
25 is rising up. BNL identified another effect so the HPSI

1 pump will fail.

2 MR. EBERSOLE: Can I, to better understand
3 this -- I think this throws it into the following. A
4 significant dominant core damage contributor is loss of
5 coolant through the PORVs, which doesn't create
6 containment pressure, therefore it loses inventory, and
7 although you may get to a double or a triple low level,
8 you don't get ADS, which you need.

9 MR. GKRENT: Is that correct?

10 MR. PRATT: Correct.

11 [Slide]

12 MR. CHELLIAH: Moving on. Now, given the
13 limited PRA --

14 MR. KERR: Just a minute, please. You
15 concluded that this was an important contributor on the
16 basis of your evaluation? Your evaluation was different
17 in Limerick, is that correct?

18 MR. PAPAZOGLU: It is significant in both
19 evaluations, both if one accepts Limerick quantification
20 and our quantification. In both cases it is
21 significant. Not absolutely at the same level, but it
22 is significant.

23 MR. EBERSOLE: Before we leave this, this is
24 an important point. There was quite a hassle about
25 whether containment pressure was needed and required

1 input into the ADS function. Did you look at the aspect
2 of not requiring that but just reading triple low level
3 as the sole signal?

4 MR. KERR: Do you understand the question?

5 MR. PAPAZOGLU: I think.

6 MR. EBERSOLE: In short, did you look at the
7 reasonability of having the containment pressure as a
8 necessary input to ADS?

9 MR. PAPAZOGLU: Yes. Right now we are in the
10 process of doing exactly that. There is a problem with
11 the ATWS situation. If one assumes that they make a
12 design limitation that you will have in transients
13 automatic initiation of the ADS system, then that
14 creates some problem in the ATWS. We want to see what
15 it would create.

16 MR. EBERSOLE: Thank you.

17

18

19

20

21

22

23

24

25

1 MR. KERR: Would you be willing to cut that
2 last slide back just briefly? I wanted to ask one more
3 question. Your last transparency. The one that had
4 the --

5 (Slide.)

6 MR. KERR: What is the difference between a
7 dominant accident sequence and a dominant core damage
8 contributor?

9 MR. CHELLIAH: Maybe going back --

10 MR. KERR: Is the first one a contributor to
11 risk and the second one a contributor to core damage?
12 You have one called accident sequence.

13 MR. CHELLIAH: These two are the dominant core
14 damage contributors.

15 MR. KERR: What are the other two just above
16 it?

17 MR. CHELLIAH: Are you referring to these
18 two?

19 MR. KERR: Yes.

20 MR. CHELLIAH: These are just the most
21 predominant accident sequence.

22 MR. KERR: What does it dominate?

23 MR. CHELLIAH: It is dominated by this
24 particular high pressure coolant injection.

25 MR. KERR: I am not making my question clear.

1 MR. KAUFMANN: Frank Kaufmann, reliability
2 risk. Ashok Thadani has sort of asked me to help broker
3 these questions. The middle part of the slide that says
4 dominant accident sequences is correct. Dominant core
5 damage contributors really is referring to functions.
6 Among the sequences, the most frequently occurring
7 functions are those two functions.

8 MR. CHELLIAH: That's correct.

9 (Slide.)

10 MR. CHELLIAH: I indicated the same fact. If
11 you look at the seven predominant sequences --

12 MR. KERR: That is enough. Thank you.

13 (Slide.)

14 MR. CHELLIAH: Moving on, given the Limerick
15 Revision 4, you may be interested in what I am going to
16 do. The Staff -- these are the three items we are going
17 to move on. The Staff will review BNL's draft NUREG
18 report. We will incorporate comments as appropriate,
19 and we will issue a final NUREG CR report. Then beyond
20 that we will focus our attention to some of the dominant
21 accident sequences and determine and recommend any other
22 additional actions are needed to reduce risk at high
23 population density sites, such as Limerick. Yes?

24 MR. OKRENT: The Staff has some research
25 efforts going on at Sandia to look at various reactor

1 designs, including, I think, the Mark II, to see what
2 are the pros and cons and the cost-benefit tradeoffs for
3 various features, whether they are preventive or
4 mitigative. Is that somehow incorporated in what you
5 have got there, or is that something not connected with
6 this activity?

7 MR. CHELLIAH: Before we answer that question,
8 are you referring to the IDCOR Sandia review?

9 MR. OKRENT: I don't think IDCOR is under the
10 auspices of the staff.

11 MR. CHELLIAH: This doesn't come under Sandia
12 review at all. This we plan to do --

13 MR. MEYER: Mr. Okrent, I will answer that
14 question. My name is Jim Meyer, NRR Staff. As part of
15 the staff evaluation, there is a program under way to
16 consider the safety benefit of preventive and mitigation
17 type features as related to the Limerick site. The
18 Sandia work that you refer to has considered every type
19 of containment but the Mark II, unfortunately, but we
20 are proceeding with consideration of both certain
21 mitigation features and through RAB certain prevention
22 features which offer the potential for significant risk
23 reduction.

24 This study is under way and will be part of
25 the Staff evaluation that you have been told earlier

1 will be presented this summer.

2 MR. OKRENT: Okay. I guess at some future
3 time we should have Mr. Minogue explain why the work at
4 Sandia does not include a Mark II containment. I am
5 sure there is some logic, although it escapes me at the
6 moment. I will get back to the point I was raising
7 somewhat earlier with Mr. Thadani, namely, that it may
8 be difficult to go through a decision-making process
9 when you have an incomplete assessment, an incomplete
10 set of initiators. Are you doing things outside of this
11 review of the PRA that you think will give you enough
12 information on the other initiators that you can factor
13 them in? Or are you going to make your decisions with
14 this limited set of initiators?

15 MR. CHELLIAH: I am sort of --

16 MR. MEYER: Presently, we are working under
17 the basic guidelines that we will be excluding external
18 events. I certainly agree with your point that it will
19 be an incomplete assessment if external events are
20 excluded.

21 MR. OKRENT: What would it take to get you to
22 do it? Does it take an ACRS letter to the Commission or
23 additional remarks appended to a safety research report,
24 or what?

25 (Pause.)

1 MR. MEYER: I am looking for somebody else to
2 answer that question.

3 MR. KERR: I suggest you think on that
4 question.

5 MR. OKRENT: Why don't you suggest to somebody
6 that maybe the technical assistants to the Commissioners
7 read the appropriate pages of the transcript?

8 MR. KERR: It still concerns me, though, that
9 we are putting requirements on plants outside of
10 existing regulations, if we are. It seems to me if the
11 regulations are inadequate, we should change them so
12 that one doesn't have to do a PRA or something and then
13 back into this.

14 MR. OKRENT: You didn't hear me say
15 requirements. I am suggesting that if they are going to
16 make decisions, that they should be made in the light of
17 an appropriate --

18 MR. KERR: I have not heard anybody here today
19 say they are going to make a decision on the basis of a
20 PRA. I have tried to get somebody to say that. What I
21 heard is that this is going to be information available
22 to the people who make decisions.

23 MR. OKRENT: I am sorry. I think we heard
24 this morning that they made some decisions based on the
25 PRA, namely, that they have talked to the licensee at

1 Indian Point about some modifications.

2 MR. KERR: That is right. They made a
3 decision to talk to the licensee. That is a different
4 kind of decision than the one I was talking about, which
5 is to make a requirement. Maybe these are implicit
6 nowadays. You don't have to make requirements
7 nowadays. All you have to do is talk to licensees. But
8 it seems to me that that is a somewhat informal way to
9 run the licensing process.

10 MR. OKRENT: In this case, licensing may
11 prefer the informal method.

12 MR. CHELLIAH: Could I comment, Dr. Okrent?
13 The Limerick applicant has held off their PRA
14 activities. They assumed a certain fix, and as I
15 indicated, one is 3A. They have got other options which
16 maybe I can mention to you. One is, they have some
17 additional features to achieve alternative room cooling
18 for the HPSI and RCSI rooms.

19 MR. KERR: I believe Professor Okrent is not
20 too unhappy with the analysis of the internal behavior
21 of the system, but he has some concern about external
22 events, if I interpret his comment correctly.

23 MR. OKRENT: I don't want to sign off
24 completely on the internal part.

25 MR. KERR: I said, not too unhappy. I didn't

1 say happy.

2 MR. OKRENT: By the way, one other question
3 with regard to internal events. My impression from
4 listening to some other presentations on other BWR's was
5 that a leading if not the leading contributor to core
6 melt frequency estimates was the unavailability of
7 containment cooling. In other words, it was your class
8 2 category. In this particular study, using here either
9 Limerick or the BNL results, this is not the case. Do
10 we understand why there is a difference, assuming my
11 memory is correct?

12 MR. CHELLIAH: I think you are correct, Dr.
13 Okrent. If I recall WASH-1400 BWR, some of the other
14 sequences are more dominant. Here it is not. Yes.

15 MR. KERR: Did you want to add something?

16 MR. PAPAZOGLU: We are still trying to make a
17 full assessment, but I can give you the present answer.
18 The design of the containment heat removal systems
19 includes a high degree of redundancy and also in the
20 calculations the potential for recovering the
21 containment heat removal systems that might be available
22 at the initiation of an accident has been quantified and
23 has been included in the calculations, and that results
24 in a significant reduction of the failure probability of
25 the failure of the containment function. It assumes 20

1 hours before the containment heat removal systems -- I'm
2 sorry, containment heat removal function is actually
3 necessary, and taking into consideration the high degree
4 of redundancy and the potential for recovery, the
5 failure probability is significantly lower than at other
6 sites.

7 MR. KERR: Does that conclude your
8 presentation?

9 MR. CHELLIAH: Yes.

10 MR. KERR: There are other questions?

11 (No response.)

12 MR. KERR: I am going to suggest a ten-minute
13 break until we get on to the next part of this.

14 MR. CHELLIAH: Thank you, Dr. Kerr.

15 (Whereupon, a brief recess was taken.)

16 MR. KERR: According to information collected
17 by Mr. Savio, there are two consultants, Mr. Davis and
18 Mr. Power, who need to leave here by 4:00 o'clock. Is
19 that correct?

20 MR. DAVIS: My plane is at 4:15 out of
21 National.

22 MR. KERR: Yours is a little later?

23 MR. POWER: Yes.

24 MR. KERR: We will then probably call on Mr.
25 Davis first and Mr. Power second. What I would like for

1 you to attempt to do in addition to other comments you
2 may feel appropriate is to summarize the information
3 that I find in both interesting and voluminous
4 quantities in some of the reports.

5 I have read the reports and learned something,
6 but at the end I found I had all this information and I
7 had to make a decision, and what I wanted somebody to do
8 was tell me what decision I should make. So if you can
9 help me a bit in saying this report I reviewed after
10 having said all this, it is either no damn good or it's
11 a great report or whatever. Then that would be
12 interesting. It would also be helpful if you could give
13 us some advice, now that we have gotten this far, on
14 what things need to be done next with some priority, not
15 necessarily by the NRC Staff or the ACRS consultants,
16 but what is it that now needs to be done next to get us
17 closer to where we would like to be, and any additional
18 comments you may want to make, especially in light of
19 what you have heard today.

20 So, if you could at least keep those things in
21 mind, I would appreciate it.

22 MR. MARK: You didn't suggest, Mr. Chairman,
23 that they be totally uninhibited by the fact that there
24 are some of the Staff still here. It seems to me they
25 ought to be.

1 MR. KERR: I am always willing to accept
2 comments from elder statesmen. Mr. Davis, are you
3 willing to begin the process?

4 MR. DAVIS: Yes. Your questions require quite
5 a bit of thinking, and I would prefer, I think, to send
6 you a letter with a more in-depth assessment of those
7 questions. What I would like to do is give you a couple
8 of my reactions to what has been presented today, and to
9 the extent that that may contribute to an answer to your
10 questions, consider that part of the answer.

11 One of the things that concerns me a little
12 bit about what we have heard is that -- is the use that
13 is being put to the PRA's. As I understood it, and this
14 is especially true for Indian Point, the PRA was done to
15 try to establish some bound to the risk from the plant.
16 That would then be used to make some sort of decisions
17 about whether any action needed to be taken, but what I
18 find is being done now with the study is an attempt to
19 try to reduce the risk dominant sequences by some
20 measures.

21 The problem I have with that is that in the
22 Indian Point study there are a substantial number of
23 what I might call pessimistic assumptions. Some people
24 call them conservatisms. This, of course, applies to
25 some sequences and not others, but what it does is, it

1 makes some sequences more upper bound estimates while
2 others are best estimate.

3 The risk then is that if you take one of the
4 upper bound sequences because it happens to be risk
5 dominant, then you are really reducing something that
6 should in fact be lower if it were done on a realistic
7 basis. I could give you a couple of examples of
8 pessimistic examples in the Indian Point study. One was
9 the assumption that recovery of feedwater or condensate
10 injection was not assumed as a viable option to
11 auxiliary feedwater failure.

12 Another assumption they made was there was no
13 equipment repair ability for six hours. This is
14 according to the report. If now one uses the results of
15 individual accident sequences to try to reduce the risk,
16 he may very well pick up a sequence which has made a
17 pessimistic assumption and it is not really a best
18 estimate of the risk.

19 I think a corollary to that comment is that
20 almost every review of a PRA seems to increase the
21 probability of core melt. I think one of the main
22 reasons that happens is that people look for things that
23 they do not agree with in the pessimistic direction.
24 Then, when the accident sequence is recalculated, only
25 those factors are changed. Things which people agree

1 are conservative or pessimistic are not changed, and
2 what you end up with is a review that is guaranteed to
3 increase the estimated probability of core melt.

4 I must confess I do this myself, but I think
5 it is a bad habit to get into. I think that we have to
6 take these reviews with the proper perspective. I get
7 the impression from the Sandia review that they
8 concentrated on the probability of the initiating event,
9 and did not do too much with the rest of the sequence,
10 so that when they found an initiating event they felt
11 should be higher, the probability of it, that is, they
12 would repeat the sequence using the other numbers pretty
13 much the same, and obviously, you will end up with a
14 higher melt probability than the sequences in which the
15 factors should be higher.

16 I might give you just a very brief rundown
17 with some of the problems I had with the Indian Point
18 study. One that has been around with us for a long
19 time, and I still have not seen properly addressed, is
20 taking account for degradation in the evacuation model
21 for accidents which are initiated by external events.
22 In other words, if an earthquake or a high wind causes
23 the accident, it seems to me some adjustment needs to be
24 made to the evacuation model. Basically, it would be
25 less effective because of communications problems, the

1 possibility of disruptions of roads, and so forth.

2 The Indian Point model does not consider
3 that. I think by the same token for external events
4 perhaps the NRC should consider a new basis for risk
5 criteria, because I think it is almost assured that
6 external events that are of such magnitude to cause a
7 plant accident is also going to cause quite a few
8 consequences just by its very nature from other
9 accidents outside the plant.

10 I had and continue to have a lot of problem
11 with the evaluation of the V sequence probabilities. I
12 won't go into that now, but they were in the letter I
13 sent to you earlier. I am not sure what to do about
14 that, but all PRA's I think have a built-in conservatism
15 there in that they assume that if a double check valve
16 failure occurs, you get a rupture of the low pressure
17 piping with a probability of one. Most systems I am
18 aware of have relief valves in that piping. They may or
19 may not be sufficient to handle the abrupt overpressure
20 problem.

21 Furthermore, that piping, even though it is
22 designed for a lower pressure, has a substantial design
23 pressure in it just because of the code requirements.
24 Another thing that I found in the Indian Point study
25 that bothered me a little bit was the failure

1 probability assigned to the auxiliary feed turbine
2 pump. It is considerably lower than I have seen in
3 other evaluations, and also lower than an assessment I
4 did on a specific pump at another reactor.

5 I think those are the main comments I had, Mr.
6 Chairman, on the Indian Point study. With respect to
7 Limerick, of course, we heard about the problem already
8 with the exclusion of external events. I guess the only
9 thing I would add to that is, I did not see that
10 qualification predominantly displayed in the study. In
11 fact, as I recall, the study starts out by saying, this
12 -- these aren't the exact words -- but it starts out by
13 saying, this is our estimate of the risk from the
14 Limerick plant. They are much lower than other risks,
15 period. It is not until some time later in the study
16 that the qualification is made that external events have
17 not been included. I think there is a potential for
18 misleading results from the way that is organized.

19 There were a couple of other problems I have.
20 The LOCA loss of coolant accident pipe break size
21 criteria does not correspond with the break size
22 probability table that's in the report. I am not sure
23 how that got sorted out when the event trees were
24 eventually compiled. It doesn't turn out to be too
25 important, since LOCA's were not a big contributor.

1 Another problem I had was on the automatic
2 depressurization system. The report says that any break
3 size smaller than .08 square feet requires ADS operation
4 to get the pressure down such that low pressure
5 injection can be effective. Any size larger than that
6 does not require ADS. However, the ADS throat area is
7 .11 square feet, quite a bit larger than that, and as I
8 pointed out in my letter, there is an apparent
9 discrepancy here.

10 In other words, the report assumed that if you
11 had a stuck open relief valve, you also had to have ADS
12 to get the pressure down, and yet the stuck open relief
13 valve throat area is above the criteria for when ADS was
14 required.

15 MR. KERR: Does that have to do with the fact
16 that one possibly expects steam to be coming out of the
17 relief valve and water to be coming out of the break?

18 MR. DAVIS: That is a possibility, although
19 that distinction was not shown in the report.

20 My last comment, I think we have seen recently
21 quite a bit of discussion about decontamination factors
22 in suppression pools. The Limerick PRA tended to use
23 rather pessimistic decontamination factors. I realize
24 the returns are not all in on what decontamination
25 factors one might be able to justify, but it can make a

1 tremendous difference in the off-site consequences. It
2 seems to me like we now have at least the beginning of a
3 substantial -- what will become a substantial body of
4 information justifying much higher decontamination
5 factors for suppression pools. This could change
6 drastically the off-site consequences, at least the best
7 estimate off-site consequences for BWR's like Limerick.

8 I think that needs to be kept in mind as we
9 attempt to justify changes based on the current
10 calculated risks.

11 That is all I had, Mr. Chairman.

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. KERR: Thank you, Mr. Davis.

2 Mr. Okrent.

3 MR. OKRENT: I wonder if I could ask a couple
4 of questions and maybe make an observation. I might
5 note there have been times when a critique of a PRA led
6 to lower results. I think I am correct that some of the
7 studies initiated by the Staff which were then critiqued
8 by the utilities involved went that way.

9 (Laughter.)

10 MR. OKRENT: But that leads to a question I
11 will come to in a moment.

12 The comment about external events, I think,
13 where you mentioned that there may well be serious
14 off-site effects completely independent of whether there
15 is a reactor accident is something that will apply some
16 of the time for some of the people but not all of the
17 time for all of the people.

18 It is not too hard for me to envisage an
19 actual situation at an existing reactor where the
20 earthquake, let's say, caused a damaging event which had
21 little direct consequence on the population and region
22 of interest.

23 MR. KERR: It's not hard for you to imagine
24 that?

25 MR. OKRENT: I can envisage faults situated

1 with regard to reactors such that you might have a
2 severe earthquake and still not have many buildings.

3 MR. KERR: You Californians have more
4 imagination about earthquakes than I do.

5 MR. DAVIS: I think that's a good point,
6 except that there is an incentive not to site a reactor
7 on a fault. Of course, there are reg guides that
8 prevent that. Whether they are effective or not is
9 another question.

10 MR. OKRENT: I will stand with my statement.
11 In fact, there are lots of reactors in the eastern U.S.
12 that are quite consciously deliberately placed somewhat
13 away from population centers. So again, it is a tricky
14 bit. Let me just put it that way.

15 I guess if you could offer any comments at
16 this time on what you think might be done next to, I
17 will use the word --

18 MR. KERR: He is going to do that on the
19 airplane going home.

20 MR. OKRENT: I will say evaluate. I don't
21 know whether one can resolve differences that arise when
22 one group critiques another or add more differences
23 between the two groups and whatever. In fact, there is
24 a related question. If you got them to achieve
25 consensus, would it mean very much?

1 Do you have any comments now in that area?

2 MR. DAVIS: Nothing definitive. This goes
3 back to the problem that we have had all along in how to
4 handle peer review. I think this problem of resolving
5 differences is a similar type of difficulty. I know you
6 have had some ideas about setting up some supreme panel
7 to try to at least have the last word on the PRAs. I
8 guess I really don't have any definitive suggestions
9 beyond something like that. But I will think about it.

10 MR. KERR: Other comments, questions?

11 (No response.)

12 MR. KERR: Mr. Power, are you next to lead?

13 MR. POWER: In my report to you I think I
14 demonstrated that there are in these probabilistic risk
15 assessments tremendous uncertainties in the accident
16 phenomenology and the treatment of the source term, that
17 whereas today we have heard about the uncertainties on
18 the order of the factors of 2 between various reviewers
19 of the accident initiation sorts of things in the PRA.
20 In the area of phenomenology it is not hard to find
21 factors of differences of even 50 to 100.

22 That poses a problem in using the PRA for risk
23 evaluation, it seems to me, because how an accident
24 progresses after it has been initiated and just exactly
25 what are the radioactive releases associated with that

1 accident are what end up making the risk eventually.

2 So I guess in each presentation on the use of
3 the PRAs both for Indian Point and the Limerick reactor
4 have been on what the probability of the initiating
5 events are rather than on the emphasis on what is the
6 risk associated with the accidents.

7 This has been rather gratifying to me because
8 I think that is where PRA makes its biggest
9 contribution, identifying those things that can lead to
10 an accident without looking in great detail on how that
11 accident progresses, because I am not sure that in any
12 trackable effort one could create an analysis of the
13 progression of an accident which is initiated that you
14 could ever get people to agree to within a factor of 10,
15 given the current data base.

16 As far as a suggestion that the PRAs would
17 then be used not as a basis for making decisions but as
18 information for making those decisions, I guess I would
19 have to agree with that because the PRA seems to have
20 its strength in identifying what initiates in an
21 accident, what equipment fails. I think it would be a
22 mistake to say thou shalt reduce the initiators that are
23 on the top of this list and not pay attention to the ones
24 on the bottom of the list, because that may require a
25 judgment on the part of the people doing it. It may not

1 be wise to require Indian Point to build a structure
2 that would withstand the historical earthquake. There
3 may be other things that would be better and certainly
4 easier for them to do.

5 That would be the bulk of my comments on what
6 I have heard today.

7 MR. KERR: Thank you, sir.

8 Mr. Okrent.

9 MR. OKRENT: Let me explore your comments
10 about the range of uncertainties. Let's take them one
11 at a time, containment behavior and then source term,
12 although they obviously interrelate.

13 You mentioned factors like 100. Do you think
14 there are factors like 100 total difference in the
15 estimate of containment failure likelihood given a
16 coremelt sequence?

17 MR. POWER: I think factors of 100 certainly
18 have been bandied around with respect to the rather
19 strong containments like Zion and Indian Point. And
20 those factors of 100 generally seem to come up in
21 discussions where you are looking at the coupling
22 between the progression of the accident and the
23 performance of safety systems.

24 They have come up in a couple of contexts.
25 One has been whether to give credit for performance of

1 containment coolers under various accident sequences and
2 under the context of what happens as melt comes
3 ex-vessel, does that in fact damage containment coolers
4 via hydrogen burns of aerosol agglomeration or equipment
5 failure burning up equipment?

6 So I think there are certainly factors of 100
7 given that you have initiated an accident and does that
8 inevitably result and what probabilities have resulted
9 in a gross containment failure. They are factors of
10 100.

11 MR. OKRENT: I guess my impression from what I
12 have heard and read, let's say, in the last year or 15
13 months if I leave out now the reactor safety study and
14 its approach, it was not clear to me that there were
15 differences among the various people offering opinions
16 or theories that large on the likelihood of certainly,
17 let's say, if they were going to give what some people
18 call a best estimate. I will call it an overpressure
19 failure.

20 Let me take these one at a time. If that
21 difference exists -- I guess it has not been quite clear
22 to me; maybe it does -- and even then, in the question
23 of whether it will melt through again in terms of these
24 large dry containments or the specific ones looked at, I
25 haven't perceived the difference that I would get if I

1 were to poll experts on the likelihood to be a factor of
2 100 total difference. Am I wrong?

3 MR. PEDERSEN: Pedersen, Argonne. There are
4 and there aren't these differences. The differences
5 come in predominantly, you can look at Indian Point and
6 Zion. They come in those sequences that Indian Point
7 and Zion have defined with epsilon probability. They
8 have defined those epsilons to be on the order of 10^{-4} .

9 Now, the containment split fraction for those
10 two, in essence, winds up being 10^{-4} , but if you --

11 MR. OKRENT: We can get into big factors by
12 getting to very small numbers. But let me say that one
13 percent is already small. So I don't get an additional
14 factor of 100 by going to 1 in 10^{-4} . The chance of
15 failure is 1 in 100 compared to what WASH-1400 had said,
16 it's already a small thing.

17 MR. PEDERSEN: That's part of the point I
18 wanted to make. The containment split fraction for Zion
19 and Indian Point was on the order of 10^{-4} , and you
20 would have to have a considerable reduction in the
21 containment split fraction before those events would
22 come back and be a dominant contributor to risk.

23 So just because we do disagree strongly on
24 certain events by a factor of 100 does not necessarily
25 mean that those are dominant events.

1 MR. OKRENT: Again, you said by a factor of
2 100. Does that mean you think the factor should be
3 10 ⁻⁴ instead of 10 ?

4 MR. PEDERSEN: Yes, it does. And I recognize
5 that you would call that an insignificant event.

6 MR. OKRENT: Probably insignificant. When we
7 talk about a factor of 100, that was one of the reasons
8 I wanted to initiate this discussion. I think we have
9 to be careful in what ballpark are we talking when we
10 say a factor of 100, and the region that matters, is
11 there a difference of a factor of 100 or is it a much
12 lesser amount, even when you are talking about a limited
13 set of sequences and not trying to mix it into a
14 background?

15 In other words, I didn't read anyone as
16 saying, given a core melt, no matter what it is, 9 times
17 out of 10 you are going to have overpressurization.
18 That would have been a substantive difference, or, let's
19 say, 5 times out of 10, 1 times out of 10 I would say is
20 a factor of 10 difference roughly. Once you get below
21 the 1 percent, it wasn't going to matter.

22 MR. PEDERSEN: I agree with that.

23 MR. POWER: I think I appreciate your question.

24 MR. OKRENT: I don't want to put positions in
25 anybody's mouth. Usually, what I read were comments

1 which quite understandably were not quantified, but
2 nevertheless -- so I am getting to your point. You said
3 there are big uncertainties in the phenomenology. I
4 think we heard of a factor of 20 assigned to the
5 contribution to the hurricanes as an initiating event
6 today. That is really a shift in the best estimate.
7 That is not a difference between somebody's lower bound
8 and somebody else's upper bound. And it turned out in
9 fact to be a factor of something in a region where it
10 counts; namely, you are already at a substantially large
11 likelihood and this was a factor.

12 So I am not so sure that from what I have read
13 that at least for this class, for the couple of
14 containments, that the differences, when you look at
15 containment phenomenology and their impact, are larger
16 than the differences one gets from initiating events and
17 their impact.

18
19
20
21
22
23
24
25

1 The source term part, I think, is harder to
2 get a handle on because that will depend on combined
3 effects.

4 MR. POWER: By and large, people are, I think,
5 forced simply because they have no other good choice to
6 adopt the reactor safety source term.

7 MR. KERR: Do you have a microphone near you?

8 MR. POWER: The problem when they hypothesize
9 new phenomenology, as was done in both the Indian Point
10 and the Zion PRAs, is by adopting that source term, that
11 they are in some sense decoupling the release from the
12 progression of the accident. There is not a clear-cut
13 relationship between the two.

14 Failures of vessels at high pressures was not
15 something the reactor source term can handle, but I am
16 not sure they have a choice on what else to use because
17 the current thinking is that in most cases that is a
18 conservative selection and the releases are never going
19 to be greater at the reactor safety source term studies
20 for fission product release.

21 It does pose a problem for you if you are
22 looking at risk-dominant sequences because you may be
23 choosing the multiplier. If you multiply probability of
24 an event times the amount of release associated with
25 that event, if that multiplier there is wrong, then the

1 risk produced by that is going to be wrong by whatever
2 fraction you have there. That is a problem I don't see
3 any way around. I cannot fault somebody doing a PRA
4 with a reactor safety source term. The reactor safety
5 source term is, if nothing else, consistent. It's
6 consistently conservative. If you start messing around
7 with it, you lose whatever merit it has.

8 MR. KERR: Other questions? Do you have any
9 more comments?

10 (No response.)

11 MR. KERR: In order of leaving time, I think
12 Mr. Trifunac on my schedule is about 4:30. Would you be
13 willing to comment?

14 MR. TRIFUNAC: I can comment only about Indian
15 Point because that is the only report I really read. I
16 won't go through the details on what I have written. I
17 would comment in more general terms.

18 MR. KERR: Hold that microphone as close as
19 you can without swallowing it.

20 (Laughter.)

21 MR. TRIFUNAC: The general comments are, I
22 think we need some kind of accountability for these
23 reports. I am getting a feeling where a massive report
24 is written, it is loaded with assumptions which are
25 really not accounted for. And I don't want to get into

1 details.

2 But the Indian Point report that I saw has a
3 lot of statements in there that are just opinions of the
4 people who wrote it. They are not supported opinions
5 necessarily, and they are certainly not generally
6 accepted procedures for that sort of work.

7 Rather than trying to do another probabilistic
8 risk assessment study, it seems to me we would do well
9 to go back to those we have done and try to see what
10 credence we can put on the work that has been done.

11 This gets me to my next comment, which I think
12 was not a high-level review. We have inadequate
13 high-level review. We have review which essentially
14 consists of reading what is there and trying to decide
15 whether we do or do not like it. But the quality of the
16 information and the quality of the conclusions that we
17 get out of the functions of what good quality went into
18 what is done there, I think we would benefit
19 tremendously by increasing the quality of the review of
20 these reports technically in detail.

21 You asked what I should like you to conclude
22 from that report. I think the only thing I could
23 venture a guess on is what you should not: It's that
24 the seismic risk estimates are too low, that they are
25 higher based on the assumptions in the report, but I

1 could not tell you how much.

2 I think the other question you had was what is
3 next. It seems to me that it would be very beneficial
4 to have several -- I don't mean two -- several, maybe
5 three, maybe four, small but high-quality parallel
6 efforts, efforts aiming at the same objective and answer
7 in the end, but independent in their entirety.

8 I am getting more and more pessimistic about
9 this massive, large-scale efforts which basically take
10 the complex physical problem, chop it up into black
11 boxes, subcontract each box, couple of boxes, to
12 different groups, and then 2 years later putting all the
13 boxes together and hope for the best.

14 I am not knowledgable on many aspects of
15 reactor design, but when I look at the considerations in
16 nuclear power plants, I think there is evidence in many
17 examples where very complex and intricate feedbacks
18 within one discipline and across total disciplines are
19 eliminated by this procedure.

20 We have a group of seismologists and
21 geologists making decisions that should be made by
22 engineers, we have civil engineers making decisions that
23 should be made by mechanical and electrical engineers
24 simply because the procedural organization is such that
25 the black boxes are separate and independent and there

1 is no feedback loop. The feedback loops should be
2 procedural and should be physical and judgmental.

3 There are too many levels of intricate
4 interrelationships in various decisions that have to be
5 looked at altogether at the same time. The procedure
6 and methodology of design should also be much more
7 interdisciplinary than it is and so on.

8 I could go on for a long time like this, but I
9 think those are general comments. I perhaps should stop
10 right there.

11 MR. OKRENT: Well, you mentioned giving more
12 credence to the reviews. I wonder if you could
13 elaborate a bit on that respect.

14 MR. TRIFUNAC: Well, I have seen quite a few
15 of these reports now. I haven't seen a single very
16 detailed, very physical critique of what has gone into
17 that particular report. Occasionally, we have heard in
18 meetings such as this or similar meetings commentary on
19 the adequacy/inadequacy of certain procedures in a
20 certain way. But I have not seen any response to that.

21 I think there is too much inertia in simply
22 forging ahead and doing some of these calculations and
23 hoping for the best, that something meaningful comes
24 out. If you have a particular group, you get a
25 particular set of assumptions which are far from

1 generally accepted in the profession.

2 And I think that the quality of all these
3 calculations and the decisions that come out of there
4 would significantly improve if we had much more
5 detailed, much more technical controversial, if you
6 will, review of the procedures that should go into a PRA
7 or related calculations.

8 MR. KERR: Without going into detail on the
9 organization or the results, we heard today of a review
10 done by Brookhaven and at least -- I don't know about
11 the depth of the report, but the thickness is
12 impressive. Is it this kind of thing that you have in
13 mind or something more elaborate? I am not asking you
14 now to comment on the competence of Brookhaven staff,
15 which I am sure we all recognize is very high. But is
16 the sort of thing you have in mind or something
17 completely different?

18 MR. TRIFUNAC: Not at all, because I haven't
19 seen that. I am having in mind a variety of reviews and
20 reports I have seen. I have in mind the PRA that I have
21 read in detail for Indian Point. What I am suggesting
22 is that a very detailed, very voluminous work was done
23 which in the end did present certain graphs, numbers,
24 tables from which you were able to draw conclusions if
25 you were to believe everything in between.

1 Rather than taking that report and the
2 Brookhaven report and maybe another voluminous report
3 and drawing a bar chart diagram and say, well, they come
4 up to this number, that number, and trying to compromise
5 perhaps between the two, I wish we could see much more
6 detail, technical and more demanding review of what is
7 done in these reports.

8 MR. GKRENT: May I try something on you to see
9 whether it fits? Some time back we asked a few of the
10 consultants who come in from the accident initiator kind
11 of background, the probability of this occurring, to
12 offer some suggestions on how one might go about
13 improving quality of peer review for PRAs. And Dr.
14 Mueller, who is sitting here, if I remember correctly,
15 mentioned something that goes like this: There are
16 going to be areas in the PRAs where there is controversy
17 concerning the methodology and the phenomenology, and
18 there may be such areas that one has the words of
19 experts or whatever you want to call them who presumably
20 do give this a very critical review and come up with, I
21 suppose, judgments and bases thereof or recommendations
22 or something.

23 I am putting some words into his mouth. But I
24 believe my recollection is approximately correct. Is
25 this something similar to what you are saying is a way

1 of giving credence, or is it something different?

2 MR. TRIFUNAC: Yes. This is one way. I
3 believe that more detail, more serious review of certain
4 procedures is in place and proper. We cannot avoid
5 controversy and many variations of this. But I see too
6 much inertia, large machine inertia-type of thing, just
7 going ahead and doing it the way we have been doing it
8 for some time. I think there is a lot of room for
9 improvement at selected places.

10 Now, I cannot speak for all the accidents. I
11 do not know about all the accidents. I can only speak
12 about the area I am familiar with. There are certain
13 obvious uncertainties that everybody agrees on. There
14 are certain controversies on what should and should not
15 be done. And I think more critical and more in-depth
16 review and more in the way of accountability by those
17 who do these reports in the broad scientific and
18 professional community would help in eliminating
19 arbitrary and unnecessary assumptions and perhaps
20 reducing the uncertainties to those aspects which have
21 to be considered that way.

22 MR. CKRENT: You used the term
23 "accountability." I guess there is a kind of
24 accountability that is considered, let's say, in what is
25 called the academic world. A person submits too many

1 papers that, let's say, have proven to be wrong, or at
2 least they are doubted for reasonably good reasons by
3 much of the community. Unless he happens to be some
4 historic figure in the past who is above everybody, he
5 loses some credibility.

6 But do you think you have that kind of
7 mechanism that can work here? It seems to me there is
8 at least one complicating factor, in that the people who
9 do these reports now have a client and he has certain
10 interests, and I know that they can influence the output
11 of the person doing the study. How would you get
12 accountability in this somewhat different world?

13 MR. TRIFUNAC: That would be very difficult.

14 MR. EBERSOLE: May I ask a question? Dr.
15 Trifunac, you mentioned about the need for
16 interdisciplinary work and the complex ways we can get
17 in trouble. Of course, if you are doing that, you must
18 have occasionally thought how desirable it would be to
19 have, if possible, a hopefully simplified and dedicated
20 function to achieve the ultimate objective, which is to
21 keep the core cooled. And we don't have that now. We
22 are doing these PRAs based on complex systems that are
23 in situ now. I would like to think that following your
24 line of thinking we might hopefully look ahead to the
25 time when we won't have to look at such complex

1 relationships and we can achieve a redesign for this
2 complex purpose. You see the complexities in that?

3 MR. TRIFUNAC: I see the complexities, but I
4 also see the problems that are sometimes not necessary.
5 I don't think I can even think about looking at the
6 core melt. This is not my discipline.

7 But I see a lot of unnecessary problems that
8 appear to me at least to be unnecessary with respect to
9 earthquake-resistant designs, not introducing
10 interdisciplinary reactions imposes the discipline of
11 one on the discipline of the other, and these were
12 problems it seems to me could have been avoided in the
13 first place, maybe not altogether avoided, but it seems
14 to me certainly they would be reduced.

15 MR. EBERSOLE: I see the designs as being an
16 unnecessary waste with interdependencies which could be
17 reduced.

18 MR. KERR: I don't think that is a question,
19 is it?

20 MR. EBERSOLE: Well, I will put it as a
21 question: Do you think that's the case in the seismic
22 context? I might say now the designs are distributed
23 and susceptible to failures all over the place. You can
24 look in any direction and find a way to stop cooling
25 functions. I think there are ways to consolidate the

1 critical functions.

2 MR. TRIFUNAC: I think that in the seismic
3 area there are ways very much simplified to what we are
4 doing now in a very large percentage of case. Now, I
5 would hate to make a guess on what is a large
6 percentage, but I think on many eastern sites there are
7 simpler ways of going at the whole business.

8 On the other hand, I see a hesitancy on the
9 part of the applicants and on the NRC to accept more
10 detailed, more advanced, perhaps more recent methods of
11 analyses which perhaps could mitigate some of the
12 problems. Some difficult cases I see we find too much
13 concern about complying with the rules and regulations
14 because these are what the rules and regulations are and
15 thereby getting into trouble.

16 So I do think that there should be a way, not
17 a complicated one really, of simplifying all of the
18 problems we get into for many cases, not all of them.

19 MR. KERR: Thank you, sir.

20 Any other questions, comments?

21 (No response.)

22 MR. KERR: Mr. Epler does not have to leave
23 until 8:00 o'clock, I gather, so I am going to save the
24 best for the last anyway and begin with Mr. Pedersen.

25 MR. PEDERSEN: Thank you. We have submitted a

1 review of both Indian Point and Zion -- or Indian Point
2 and Limerick.

3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 I will not go into any details of the review
2 because that would involve too much time, but I did want
3 to see that with respect to Indian Point and Zion, they
4 are very similar reports, they were done by the same PRA
5 organization. The methodology is nearly identical
6 between the two reports.

7 MR. KERR: Which one was done first?

8 MR. PEDERSEN: You guys are a better reference
9 to that, but I assume since the order in which we
10 received them was Zion and Indian Point --

11 MR. KERR: Had they learned anything by the
12 time they did Indian Point?

13 MR. PEDERSEN: I am not sure that they weren't
14 done at the same time. In fact, the same MARCH
15 calculations are used in both reports, so I actually
16 think they were done at nearly the identical time. That
17 is only an assumption.

18 MR. MUELLER: One of the consultants was Dave
19 Aldridge and had cited some improvement from going to
20 Indian Point to Zion, but I can't be more specific than
21 that.

22 MR. PEDERSEN: One of the comments on Zion
23 related to the source term multiplier. It is an effect
24 of order of magnitude or two in reduction of risk, with
25 very little justification. That is an important area.

1 There is certainly the potential payoff in the area of
2 source term reduction, but as yet we are not in a
3 position to absolutely know. One of the questions I
4 think we have to address ourselves to in preparing a PRA
5 is how do you handle these phenomenological areas where
6 the phenomenology stage. How do you -- and there is
7 consensus, at least among several people, that you will
8 have considerable reduction in the source term. When you
9 are preparing a PRA, how do you handle that? Do you
10 handle that in the uncertainty, do you handle that in
11 the mean value?

12 MR. OKRENT: Have you received a copy of the
13 response from the Zion licensee to questions from the
14 ACRS?

15 MR. PEDERSEN: I don't believe so.

16 MR. OKRENT: That may have fallen into a crack
17 in the transition. Dr. Savio will make a note. You
18 will not find an answer to the question you just
19 mentioned. That is what reminded me.

20 [Laughter.]

21 MR. BENDER: Before you go on, let me explore
22 that matter of the source term versus other kinds of
23 information that are addressed in the PRA. We know with
24 certainty that the statistics on reliability are not
25 know very well, but yet we use them in the PRA and make

1 judgments about them, and we consider the spread. I
2 wondered whether you didn't have some similar way of
3 dealing with source terms.

4 MR. PEDERSEN: I am not an expert in the
5 methodology.

6 MR. BENDER: It seems to me the same kind of
7 question; you can deal with it essentially the same way.
8 Do you think there is a range of values that might be
9 used? You can take the extremes and look for a best
10 estimate value. And I don't see a need to have a lot of
11 experimental information before I do that.

12 MR. KERR: What I am saying is it has to be
13 between zero and 100 percent.

14 MR. PEDERSEN: Yes, but you shouldn't make a
15 bias. It appears as though Indian Point made a bias in
16 uncertainties.

17 MR. BENDER: I am not trying to judge Indian
18 Point. I am just looking for a principle.

19 MR. MUELLER: I guess I am missing your point
20 because that is what we did with the Zion and Indian
21 Point, giant containment event trees and they simply
22 made a judgment; every time there was a need to go the
23 safe way or unsafe way, they made a judgment.

24 MR. MARCHATERRE: You are saying there are
25 large uncertainties. I think indeed that should be

1 done. Our comments simply related to the fact that how
2 they made the judgment was not clear. It wa a document
3 that was an important issue. We are saying we should
4 look at the justification.

5 MR. KERR: If you were going to document
6 something or if you were looking for documentation, what
7 would you be looking for, a reference to another PRA
8 that said we did it the way PRA number 3 did it?
9 Because you see, enough of these are coming into
10 existence that pretty soon there is going to be a lot of
11 reference available. If that is what you mean by
12 documentation, that doesn't give me a lot of confidence.

13 MR. PEDERSEN: No, I am not sure of what is
14 out there in the field, but I believe that somebody
15 could put together a reasonable case for there being a
16 considerable reduction, if no other than the words from
17 the reactor in Africa, the pseudoreactor. But I think
18 it is possible to put together a reasonable case that
19 would give you some satisfaction. It is the same case
20 if you are going into try to convince you to do a lot of
21 research in that area. You could at least go through a
22 literature review and develop the best position you have.

23 One point that has come out in the review of
24 Indian Point and Zion and Limerick is that there are two
25 mechanisms of containment failure. The two mechanisms

1 are structural failure and excessive leakage. We have
2 in the past concentrated on structural failure because
3 that seems a little bit easier to come up with a number
4 on structural failure, but we do have lots of
5 penetrations in these reactors that we have to worry
6 about, just leakage of penetrations.

7 MR. KERR: Are you referring to the fact that
8 penetrations may be leaky before the accident starts?

9 MR. PEDERSEN: That's right. Well, partly
10 leakage before the accident starts, and then the
11 pressure that you are inducing on them can cause some of
12 the seals to open up and you can have excessive leakage.

13 MR. SEIDENSTICKER: The accident can also make
14 it worse. It could induce further leakages.

15 MR. PEDERSEN: In the area of fire risk that
16 we reviewed for Indian Point, really most of the
17 concerns we had relative to fire risk we saw in the
18 Sandia review. The only potential uncertainty along
19 that line, the potential for convection heat transfers
20 to cables of the gas layer building up, that was a
21 concern that we had. The definition of the control room
22 as a potential critical area.

23 The one area which we didn't see with respect
24 to the fire treatment data, in trying to decide whether
25 a fire is suppressed in a certain time after initiation

1 or whether it leads to cable failure, the authors of
2 Indian Point referred to the data of Flemming, which is
3 one of the references both in ours and in theirs. In
4 reviewing that and another similar reference, which was
5 Tserian -- is that the correct pronunciation?

6 MR. KERR: We will accept that.

7 MR. PEDERSEN: Both of them have reviewed the
8 same data, and it appears as though they have two
9 interpretations of the same data. The question in this
10 is whether -- when you are trying to decide whether you
11 can put out a fire, you have three times to consider.
12 You have detection time, which is the time between
13 initiation of the fire and when you found out the fire
14 occurred. You have application time, which is basically
15 the time between after you figure out there is a fire
16 and the time you get down to the room. And you have
17 suppression time, which is the time that after you get
18 there, it is time to put the fire out.

19 The one reference implies that the data of
20 Flemming is only the suppression time, where -- that is
21 the reference by Tserian, and -- I'm not used to
22 pronouncing these non-Swedish names.

23 MR. WARD: Pastolakas.

24 MR. PEDERSEN: In the Indian Point study they
25 seem to refer to the data of Flemming as strictly

1 suppression times. Our interpretation is not clear. We
2 would like to ask the authors to do a little more in
3 that area. With respect to -- that is really about all
4 I have to say about Indian Point.

5 With respect to Limerick, we again reviewed
6 only the containment response. There is a very limited
7 containment response here. The comments basically speak
8 for themselves. The one comment we have is a summary
9 comment with respect to the event tree that was chosen,
10 the top level event tree. In several of the events
11 there are several phenomenologies. There are several
12 events that occur where you have to integrate the
13 effects of each one of these to make a decision as to
14 the probability that you assign in the end.

15 In one case there may be up to six
16 phenomenologies, with things occurring at different
17 times that you have to include. It appears to me as
18 though if we were to improve the event tree a little bit
19 to not have as many phenomena involved in each event, it
20 would help us in the assessment of the review of the
21 probabilities assigned.

22 I did want to make one other comment relative
23 to external events. One is the title "external
24 events." Fire has been lumped in the external events
25 and really belongs back in the internal events.

1 Seismic, hurricane, tornado come close to my
2 representation of external.

3 MR. KERR: My impression was that the
4 classification of external event was based on an
5 assumption that internal meant equipment malfunction,
6 component malfunction, this sort of thing. In that
7 sense, a fire is external to the system. It is not
8 outside it, but it is not a normal part. But that may
9 not be the way the classification occurred.

10 MR. BENDER: Excuse me. Do you have a feeling
11 for the basis for deciding the frequency of fire
12 initiation?

13 MR. PEDERSEN: The source term?

14 MR. BENDER: The source term.

15 MR. PEDERSEN: It is based on this data of
16 Flemming and -- they reviewed all the reactors'
17 experience up to May 1978 and looked at the fires in
18 each of the various rooms. The one I am familiar with
19 is the cable spreading room, in which there were just
20 two fires during that time.

21 MR. BENDER: Isn't that the kind of data you
22 ought to have as a basis for estimating the likelihood
23 of future fires, recognizing that these fire protection
24 criteria have been promulgated, including the limiting
25 causes of fire that were not in existence when the data

1 was generated?

2 MR. PEDERSEN: I would like Chuck to answer
3 that question.

4 MR. MUELLER: Are you done?

5 MR. PEDERSEN: Yes.

6 MR. MUELLER: I will just slide in. I think
7 one --

8 MR. KERR: Would you identify yourself for the
9 lady?

10 MR. MUELLER: Chuck Mueller from Argonne.

11 One of the problems we have in all of these
12 reviews and fire data is the mix between best estimate
13 and conservatism. For Indian Point we had two fires in
14 300 reactor room years. It was that type of data base.
15 The question is, if you don't use that, what do you
16 use? "Pastalokus and some of us decided to use that as
17 a base. How one can defend taking credit for criteria,
18 I don't know.

19 MR. EBERSOLE: Could I ask a question just a
20 minute? You are at the moment on the question of the
21 probability of having a fire. Did you have any
22 groundrules as to what is the susceptibility of the
23 plant to fire? Would it have been modified to include
24 Appendix R? There is a gross difference as to whether
25 it was, on the one hand, as a minimum Reg Guide 1.75 or

1 had been altered to comply with Appendix R. Were you
2 told?

3 MR. PEDERSEN: We weren't told, but I think I
4 can partially answer that.

5 MR. KERR: We raised that question with
6 respect to Indian Point, and it was evaluated.

7 MR. EBERSOLE: This is one inch separation.

8 MR. MUELLER: I didn't do the fire evaluation.

9 MR. PEDERSEN: What they do is basically
10 compare the propagation times to the fire.

11 MR. EBERSOLE: Reg Guide 1.75 permits the
12 convergence of critical wiring down to a one-inch
13 separation. Therefore, it can carry fires.

14 MR. PEDERSEN: I am not familiar with that
15 level of detail.

16 MR. BENDER: Let me tell you why I am raising
17 this. On the one hand, we are using data which does not
18 account for the regulatory modifications, and on the
19 other hand, we are defending the improvements in the
20 fire resistance by taking credit for regulations in
21 Appendix R, which essentially does the very thing which
22 you didn't do when you used the data initially. There
23 is something funny about that. Either you don't take a
24 credit for Appendix R, or if you want to take credit for
25 Appendix R, take credit for the reduction in initiators

1 as well. I guess I am not comfortable with what I know
2 about what is going on right now, but it doesn't make
3 much sense to me.

4 MR. MARCHATERRE: I would just like to make
5 one point, that I wholeheartedly agree. As a matter of
6 fact, this is a subject which myself and Carl Ott at
7 Purdue pursue, taking credit for learning from past
8 experiences and for changes in regulations. Carl, I
9 might add, is quite an exponent of doing just that in
10 these assessments, or attempting it, at least, on the
11 basis that some attempt is better than none.

12 MR. BENDER: Well, I think any exercise in
13 learning is bound to teach us something.

14 MR. KERR: In the process of considering other
15 kinds of data, there is a table on page 3.7 of the
16 Limerick review which gives what is called a summary of
17 the frequency of transient initiators and the categories
18 into which they have been consolidated. Among those
19 that caught my eye was pressure regulator failure, which
20 was said to occur .67 times per year, and loss of
21 feedwater, which was said to occur .7 times per year.

22 Now, I do not understand why that sort of a
23 failure has to occur so frequently. Is that really a
24 valid set of data? Are these systems so poorly designed
25 that that frequently one has a failure of the pressure

1 regulator and that frequently one loses feedwater? I
2 mean when you see numbers like that, do you go back and
3 make sure that somebody has not made a typo?

4 MR. EBERSOLE: I don't find anything horrible,
5 Bill. That sounds like commercial grade equipment.

6 MR. KERR: Well, this shouldn't be commercial
7 grade equipment if it fails that frequently, Jesse.

8 MR. EBERSOLE: But it is traditional to have
9 it.

10 MR. KERR: Well, I guess I don't see why one
11 does PRAs when one has such lousy equipment. It seems
12 to me the obvious thing is to fix up something like
13 that. I'm a front man for Epler.

14 MR. EBERSOLE: You are setting the stage.

15 MR. KERR: Those are valid numbers as far as
16 you know?

17 MR. MUELLER: I don't know. I don't have any
18 familiarity with that.

19 MR. KERR: Well, someone who is in the review
20 process is on the lookout for these and says, aha, this
21 number must be a typo or something? They don't just
22 take these numbers and say -- I hope. Marchaterre, you
23 worry about this sort of thing.

24 MR. MARCHATERRE: I think we do, but you also
25 have to remember that at least in our case, the review

1 was looked at in certain critical items and was not
2 attempted to be looked at in its totality.

3 MR. KERR: You were answering Mr. Bender's
4 question, I guess, when I interrupted you.

5 MR. MUELLER: One thought that struck my
6 mind. Pete Davis had mentioned the fact that a review
7 is almost bound to guarantee an increase in risk. It
8 would seem to me that if each reviewer, especially in a
9 full-scale review, were chartered, if you will, to make
10 a real best estimate assumption where one goes through
11 and actually comes up with his best value, that may be
12 one way of introducing what Dr. Trifunac, I think, would
13 refer to as accountability. It is obvious, as Pete
14 mentions, it is very easy to go through and accept all
15 the conservatisms because, again, these are blends of
16 best estimates and conservatisms, it is easier, if you
17 will, to attack those things that you know about that
18 are perhaps not quite so conservative. So that is at
19 least one suggestion.

20

21

22

23

24

25

1 Conclusions, where do we go next? I guess I
2 would like to see a reassessment of the key sequences
3 for Indian Point and Limerick using true best estimate
4 guesses on all the different branch points to get out to
5 both the core melt and the peak fatalities. One thing
6 Dr. Okrent mentioned concerning source terms, how
7 important are these uncertainties, well, they are part
8 and parcel of getting from core melt frequency to acute
9 fatalities.

10 Looking at some of the results, Limerick has a
11 core melt frequency of 1.5 minus 5. One out of every
12 six core melts kills 100 people. My gut feeling is that
13 that is not true. Okay?

14 For Zion, the published values were 4.2 minus
15 5 for core melt frequency and 4 minus 9 for a factor of
16 10,000 in the same transition. Obviously, that is --
17 Dean mentioned it before. It included both containment
18 assumptions and the assumptions on how one lumps all the
19 conservatisms put into the analysis before that.

20 Certainly source term uncertainties are a key
21 part of that, so I think it is a very critical issue.

22 The last thing on documentation of accident
23 scenario assumptions, I don't know, other than simply
24 listing the applicable experiments, applicable analytic
25 tools, what one can do beyond that. I guess I would

1 like to see a little bit more of the latest Henry
2 scenario or whatever, because it seems that everybody is
3 looking at things and thinking about all the terrible
4 things that can happen. At least there is one guy who
5 is looking at it from the optimistic view, saying, if
6 this scenario takes place, we can get reductions rather
7 than worst case episodes or scenarios.

8 That concludes my remarks.

9 MR. KERR: Mr. Marchaterre, did you have
10 anything to add?

11 MR. MARCHATERRE: I would like to make just
12 one comment, following up on some of the previous
13 discussion. From the complex phenomenology and perhaps
14 the need for peer review, I think that in my own opinion
15 there are enough people that have thought about degraded
16 core phenomenology now that one could begin to -- I am
17 not optimistic enough to say we will reach a consensus
18 opinion. You may well have a minority-majority report.
19 But I think one could get a reasonably respectable group
20 of people together who would benefit from interchange
21 and questions that people have about, for instance, some
22 of the phenomenology that was in the Zion and Indian
23 Point study.

24 We raised some issues. We tended to raise
25 them as questions. I think there are -- I guess my

1 opinion would be that there are answers to these, that
2 in many cases at least some of the differences could be
3 ironed out. As I said, I am not optimistic enough to
4 think we would reach a consensus opinion on
5 probabilities of things, but we might narrow -- it might
6 be possible to narrow the range. I think that is
7 probably a worthwhile exercise to undertake.

8 MR. OKRENT: Can I pursue that? Suppose one
9 were to try the exercise you just suggested. About how
10 many people overall would you envisage being involved,
11 and about how many five-day weeks would you envisage
12 each had to devote to this to accomplish the review and
13 the writing of the report and so forth?

14 MR. MARCHATERRE: I guess I would say -- I am
15 just mentally going through names in my mind of who
16 might be involved that would give you a spectrum of
17 opinion. I would say it would be probably in the range
18 of six to ten people. In terms of time, I think it
19 would probably be a substantial effort.

20 MR. OKRENT: I can't quantify substantial.

21 MR. MARCHATERRE: I would say you would
22 probably wind up with each of the persons having, in
23 total, I would say, would wind up spending a couple of
24 man months between the meetings, negotiating back and
25 forth, probably spread out over a long period of time.

1 MR. BENDER: I am not sure just what kind of
2 subject matter that group might address.

3 MR. MARCHATERRE: I was addressing my perhaps
4 seismic. I was just addressing my effort to the one
5 area I am most familiar with, which would be degraded
6 core phenomenology.

7 MR. BENDER: I understood that is what you
8 were talking about.

9 MR. MARCHATERRE: I would say an example would
10 be, for instance, pick one of the tough ones. What
11 would the consensus opinion be on probabilities of steam
12 explosions for some of the various scenarios, some of
13 the various accident sequences? The questions that have
14 been raised, for instance, on crest stability. What are
15 your estimates that that is -- I am raising these as
16 questions. I have no opinions.

17 I generally would say that the material we
18 have seen, I would say I generally agree with. We have
19 some differences of opinion, but that's the kind of
20 thing I am talking about.

21 MR. KERR: Dr. Trifunac?

22 MR. TRIFUNAC: This is a comment. We do a
23 PRA. We get a list. This could happen, this could
24 happen, this could happen, and so forth. And we add
25 some numbers to those. We look at how this was arrived

1 at. Basically, we have a one-way full tree sequence
2 which has branches, usually two or more branches at each
3 level.

4 Now, I think what would be very useful for
5 those people who want to use the results in their
6 decision process to examine at what locations of the
7 branching we are not justified in assigning the 100
8 percent probability of having covered all of the
9 branches, because I think the past experience with
10 accidents suggests that we can predict, what, 70
11 percent, some such percentage of accidents, maybe 20 or
12 30 percent that come from those branches with surprises
13 we didn't expect, and I would expect that at certain
14 places we do the branching, we should be able to say
15 that there is another scenario that is conceivable that
16 we have not considered because we have an educated
17 judgment that it has perhaps a 2 percent chance of
18 taking place.

19 So that in the end, when we get the total
20 answer that we have a proviso saying that we believe in
21 a judgmental way that we have covered maybe 80, 90, 60
22 percent of the cases that we should have covered, and
23 that is something that would be helpful for those people
24 who are not in the probability business, but who want to
25 use these numbers as a contribution to their thoughts.

1 Also, in all the fault trees I have seen, the
2 branching is forward, multiple branching. I just have
3 difficulty seeing that there are no feedback loops that
4 go from one side of the tree to another because some
5 things may have happened simultaneously, but that is a
6 more complex subject.

7 MR. KERR: Did you have anything further?

8 MR. MARCHATERRE: No, I am finished.

9 MR. SEIDENSTICKER: They have covered my major
10 comments with regard to containments. I don't know if
11 you mentioned anything about the reactor vessel. I
12 guess in all three of the things we looked at, Argonne,
13 Zion, Indian Point, and Limerick, not very much was
14 given in the way of discussion, let alone documentation
15 of the reactor vessel. I saw interesting sentences
16 about control rod tubes melt. It blows out, and that's
17 it. I'm not very convinced about that, and I can't
18 convince anybody else when I do a job on that, and I
19 think that ought to be certainly done with a lot more
20 detail to convince -- if it's important, and I
21 understand it has a reasonable amount of influence as to
22 the amount of core melt that would come out and how fast
23 it would come out; that certainly ought to be looked
24 at.

25 I find that that is --

1 MR. KERR: When you say looked at, do you
2 mean, have you given it enough thought so that it would
3 take experimental work, or is it analytical work?

4 MR. SEIDENSTICKER: I think it is primarily
5 analytical work. It might very well be one of the
6 things that John has mentioned. I don't think it is the
7 kind of thing that you have to embark on a four-year
8 program. I think if you get three or four or five or
9 six people together that know about these things,
10 including the reactor manufacturer, I wasn't too clear
11 that was the one that was involved. I would go back to
12 him first. I don't know if he was the one that made
13 those estimates, but he may give you a different idea of
14 where it failed, but I think if you could get closer to
15 a consensus on that, I don't think you need any
16 experimental work.

17 Just a comment on the difference between
18 Limerick as compared to Zion and Indian Point, Zion and
19 Indian Point being a package, the depth of the
20 structural work on Limerick was far less for, I think, a
21 more complex structure. The types of failures and the
22 types of diaphragms and connections and things that
23 could happen in that kind of containment I think
24 deserved a little bit more attention. If they spent as
25 much time as they had on Zion and Indian Point, there

1 might have been more things we could have commented on.
2 It just simply didn't have it.

3 We made a few comments, I believe, on melt
4 through or partial melt through of some of these
5 horizontal diaphragms and what effect that might have on
6 the containment capacity. I think the thing, if I
7 understand what you had asked earlier of what might be
8 some bottom line things to glean, Number One, of course,
9 the reactor vessel failure mode is somewhat up in the
10 air. The other one has to do with -- this is
11 self-serving to some extent, because we just recently
12 made a submittal along with others to the NRC for
13 research in the containment leakage characteristics for
14 -- at the request of the NRC, and it is to be inputted
15 into the whole program for containment safety margins.

16 That is, to get a much better balance between
17 both structural failure and the leakage rate failure in
18 containments. I attended, as I think many -- I know
19 Chet Siess was there, and I know others were -- in June
20 at the workshop of Sandia in Washington, that there was
21 not a crisp definition of containment. The answer was
22 pretty clear. It sort of touches on what Dr. Trifunac
23 said. Virtually everyone there was a structural
24 engineer except Bob Henry, and he talked about steam
25 explosions. Everybody else was there to explain how

1 their structure was behaving, whereas in fact I think
2 you have to attack it as a structure and leakage rate
3 failure.

4 You need a systems approach, if that is the
5 right way to use the word "systems." I do not mean
6 pushing that by saying we should downgrade the
7 structural work that the NRC has in place. We still
8 don't know much about the way in which containments will
9 fail. There is an awful lot of disagreement. It is
10 very sensitive as to location and perhaps even the mode
11 of failure.

12 MR. BENDER: It is not uncommon practice to
13 design structures so they are predicted to fail in a
14 certain mode.

15 MR. SEIDENSTICKER: Right.

16 MR. BENDER: And if you want to build
17 containments that way, you certainly could. Do you have
18 in mind trying to look at that aspect of the question?

19 MR. SEIDENSTICKER: Yes. In fact, I think at
20 some of the information meetings a year or two ago in
21 Washington that Jim Meyers was at, we made the comment
22 that people were concerned why Zion, for example, didn't
23 show weakness at the penetrations, and as you and I
24 served -- I don't want to say how long ago it was -- on
25 some of the concrete code committees, they were

1 deliberately designed so that they would not fail there,
2 so that you would get ductile failure elsewhere.

3 Then, when I went back home and started
4 looking at some of the FSAR's that we had on hand, I
5 found that some people put penetrations where Zion
6 wouldn't have. In other words, what was good for one
7 reactor you couldn't generalize. It wouldn't have been
8 a good argument for the next prestressed concrete or
9 reinforced concrete.

10 So, I agree with you, Mike. I think that is
11 one of the advantages that, for example, concrete had,
12 to put the failure mode where you wanted it, but
13 apparently it got lost in the shuffle.

14 MR. BENDER: Well, we have sort of got a
15 one-horse shay out there right now. There is a question
16 as to whether that is the right way to engineer these
17 structures.

18 MR. SEIDENSTICKER: And of course the question
19 on containment is, it is all based on strength, and now
20 we are trying to analyze it not only using more
21 sophisticated PRA type analyses, but going way out in
22 the plastic range, where we are talking about
23 deformations of inches and not fractions of an inch,
24 where everybody gets excited when they see a small crack
25 around an opening.

1 So, I really think that growth structure
2 behavior should be continued. I just want to make the
3 pitch that I think the NRC's recent request for work
4 from four or five organizations on penetrations
5 definitely needs the ACRS's support, and I am sure from
6 what I have heard from Dr. Siess this has been pushed
7 very hard in the past before the ACRS, and I am glad to
8 see it coming along.

9 The future thing, I just wanted to make a
10 couple of comments. One is, I agree very strongly with
11 Dr. Trifunac on this idea of trying to split things into
12 pieces for the review. I think one of the advantages we
13 may have had at Argonne was that there were four or five
14 or six of us, that we may have worked independently, but
15 we had the opportunity to get together at times, and we
16 brought different disciplines to bear.

17 It would have been pretty helpful to have
18 heard the writer of the PRA give a two to five-hour
19 presentation as to what he is trying to do. That would
20 have been very helpful, and maybe that is very hard to
21 do. I suspect it is not easy to make a short
22 presentation of a 13-volume document.

23
24
25

1 On the other hand, it is pretty hard to find
2 it. I don't know what question Dave was asking earlier,
3 but you were looking at 7.2 or 7.3? I have a lot of
4 those. A road map would have helped. And I think they
5 are definitely needed. But that is just because these
6 things are new, and I would not want to push for
7 uniformity.

8 I think the last thing is this idea of
9 separation. Again, I want to re-emphasize that I think
10 the review process can be greatly emphasized not only by
11 attacking specific problems, but by bringing together
12 different people, just as you would for a site
13 selection. You really ought to send out a seismologist,
14 geologist, structural engineer, and probably lawyer, and
15 someone else.

16 MR. BENDER: You lost brownie points right
17 there.

18 (General laughter.)

19 MR. SEIDENSTICKER: Well, at least a
20 politician at any rate. That is the sum and substance
21 of my comments.

22 MR. EBERSOLE: Can I ask a question? You
23 touched on something that sounded mightly like it
24 related to control rod drive ejection, the thimble
25 failure. Is that what you were talking about?

1 MR. SEIDENSTICKER: As I understand it, when
2 we read the reviews of how the reactor vessel, the
3 bottom head was to fail, that is, how the core melt was
4 to get out, it was on the basis of a nozzle for the
5 control rods. There was a partial penetration weld. I
6 don't know if this is true for all the reactors, but one
7 that I know for sure --

8 MR. EBERSOLE: The reactor is shut down at
9 this time.

10 MR. SEIDENSTICKER: What is happening is that
11 the molten material is getting at that weld. It is
12 weakening it, and it ejects it in the sense that it
13 comes out. We question that on the basis that that may
14 not be credible, because by that time you may jam the
15 nozzle.

16 MR. EBERSOLE: You are not worried about a
17 reactivity accident, are you?

18 MR. SEIDENSTICKER: No, just the structural
19 failure.

20 MR. KERR: Anything else?

21 (No response.)

22 MR. KERR: Mr. Epler, we come to you.

23 MR. EPLER: I guess everybody knows that I
24 don't know anything about PRA. I am not an analyst, and
25 the things I have to say, if they are shocking to

1 anybody, please believe me, I don't intend to be
2 offensive. But I observed that having a PRA and having
3 identified some major contributors, there is an enormous
4 pressure to fix those specific items and no
5 corresponding pressure to fix those that have not been
6 made apparent.

7 I could illustrate what I mean by this
8 example. We have events that occur frequently, like
9 loss of load turbine trip and reactor shutdown. We have
10 some that are very rare events, but you see a great deal
11 of attention because they are spectacular. These would
12 include large break LOCA, an airplane crash into
13 containment, pipe whip, turbine missiles, and a lot of
14 other highly improbable events that receive rather
15 extensive attention. Let's call that Group 1.

16 Group 2 would be those events having similar
17 probabilities, but we haven't thought of them yet. I
18 don't know how many of those there are. I know a few.
19 Group 3 would be those that we can't do anything about,
20 like sabotage or acts of war. So, if you look at the
21 ratio of those events that we spend a lot of effort on
22 compared to those that we cannot fix, then we wonder if
23 that isn't just about a factor of two.

24 I don't want to suggest that it is a factor of
25 two. I am saying we simply don't know.

1 Now, what I am paying attention to is those
2 events that we have not thought of, or having thought of
3 them, we cannot do much about them. Let me first remind
4 you that Bill Stratton, about 1960, wrote a paper in
5 which he described between two and three dozen events
6 where critical assemblies shut themselves down by the
7 mechanism of violent disassembly.

8 If you look at it, the designs were completely
9 inept. They were thrown together by people who had done
10 them extremely informally, and today we are very careful
11 in our designs. We have learned a great deal, but we
12 still have some errors, some we even recognize as not
13 very good, but we can't do much about them because they
14 are engraved in stone. They have been approved, they
15 have been licensed, and we still do them that way.

16 I could give some examples, but I want to get
17 through. We would expect to reduce the frequency of
18 design errors, although it has been a large contributor
19 to the spectacular events. Component failure has
20 received a lot of attention. It is not much of a
21 problem. It is easily fixed. Redundancy does it very
22 well, but redundancy brings in no problems.

23 If you have two and one breaks, you fix the
24 other one. Now they are both broken. This has happened
25 many times. We have lost turbines, turbine bearings,

1 and other rather spectacular equipment failure just by
2 the mechanism of servicing the wrong unit. We have
3 another mechanism of testing which is essential. When
4 you have redundancy, you have to test to find that the
5 first one has not failed. Testing has been a very large
6 contributor to rather serious systemic failures. I
7 could give a dozen examples.

8 MR. CKRENT: Up until now it sounds like we
9 should have one system that we should not test.

10 MR. EPLER: No, we have to be able to accept
11 the consequences of this mechanism, because we are going
12 to have it.

13 MR. CKRENT: I am only kidding.

14 MR. EPLER: I know it. Now, having
15 redundancy, now we have a new mechanism. Having
16 multiple unit sites, we now service the wrong unit. And
17 we have had some rather spectacular consequences there,
18 like losing the turbine bearings and other things. Then
19 we have, strangely enough, another mechanism for
20 failure. That is directions from the front office that
21 are inappropriate.

22 I could give several examples of where people
23 have been constrained to do things by directives from
24 the front office that were just plain wrong, and
25 resulted in some rather disagreeable consequences. Then

1 there is one that is really shocking, directions from
2 the bureaucracy in Washington, and this could be either
3 from the NRC or the DOE, and I have examples of both
4 that are entirely inappropriate.

5 Now, these don't appear in published
6 accounts. They have been troublesome in the past. I
7 don't think we are going to fix any of those. So what
8 do we do? Well, I think to me it is obvious that there
9 is only one thing that can be done, and it must be
10 done. We have got to increase the on-site capability,
11 because those guys are in the best position to fix all
12 of these. We can't sit here in Washington and do it.

13 I am not sure they can, but only they can.

14 MR. KERR: What is the probability?

15 MR. EPLER: Ask these people.

16 MR. KERR: Are there questions? Comment?

17 (No response.)

18 MR. KERR: Do you have anything to add to the
19 proceedings? Mr. Okrent? Mr. Ward? Mr. Bender? Mr.
20 Ebersole?

21 (No response.)

22 MR. KERR: What is your view of the utility of
23 the type of PRA's that you are seeing now in the
24 decision-making process? How comfortable do you feel
25 with using them?

1 MR. PEDERSEN: We brought along John to answer
2 that.

3 (General laughter.)

4 MR. MARCHATERRE: By that, do you mean I have
5 reached the age that I am expected to be the only
6 philosopher?

7 (General laughter.)

8 MR. MARCHATERRE: I haven't really thought
9 about that question a great deal, but from the
10 standpoint of my normal answer, top of the head answer,
11 it is that it is very useful if I was in a position of
12 having to make decisions on plants or changes in
13 plants. For all their imperfections, I think I would
14 find a PRA on the plant very, very useful.

15 MR. KERR: Which part of it, the quantitative
16 or the qualitative part?

17 MR. MARCHATERRE: I am not terribly interested
18 whether the numbers are 10⁻⁴ or 10⁻⁶, but it is
19 really qualitative. What are the dominant contributors
20 to risk?

21 MR. KERR: We are sort of now talking about a
22 failure modes and effects analysis, aren't we?

23 MR. MARCHATERRE: Not really. I am adding one
24 more comment to it. At least while I am not interested
25 in the absolute value of the numbers, I am interested in

1 the comparative, in comparative numbers, in the sense of
2 what are the dominant contributors to risk, and what
3 might be done to reduce this.

4 MR. KERR: But why aren't you interested in
5 the absolute numbers? As Paul Davis pointed out, I
6 think it is an extremely important point. You go
7 through these things. Let's say you are very
8 conservative in one sequence, so you compare other
9 sequences and have ten plants using the same
10 conservatisms, and you have a relative number. Now you
11 have to make a decision, do I spend resources to fix
12 that sequence, and really, the conservatism is such that
13 I should be putting the resources on some other
14 sequence, which has been a best estimate analysis, which
15 on paper looks like it is much less contributing to
16 risk, but actually it might be more.

17 MR. MARCHATERRE: I think that is a good
18 point.

19 MR. KERR: If you are assuming absolute
20 numbers, you have to worry about it, perhaps a good
21 bit.

22 MR. MARCHATERRE: I guess implicit in my
23 comment was, the sequences were all done with the same
24 degree of conservatism or lack of it.

25 MR. KERR: Well, we know they are not.

1 MR. MARCHATERRE: I think that has to be an
2 input into the thinking as to what we are looking at in
3 the PRA and what degree of conservatism has been applied
4 to the various sequences. I think your point is well
5 taken.

6 MR. KERR: There is one other question which
7 has to do, I think, with how one uses it and what one
8 does. What have you seen so far if you had to assess
9 the conservative and individual PRA of a specific plant
10 and compare that with the differences that one might
11 find between a generic and a specific analysis? Which
12 would you say is likely to be greater? What I am really
13 getting at is, shouldn't one do a good generic analysis
14 and assume that at least in a general sense one can use
15 that for making decisions, and does one have to get to
16 the specific plant in order to accomplish something?

17 It seems to me the answer to my question does
18 not settle that, but I think it has something to do with
19 an answer to that question.

20 MR. MARCHATERRE: I would like to see what the
21 other people think, but just in view of looking at these
22 three that we have reviewed, it seems to me that you
23 really have to be specific to the specific plant. Let
24 me qualify that by saying there are big chunks that
25 could be generic in nature. The phenomena are basically

1 the same. I think the example there was, the things
2 that were done for Zion were particular to Indian
3 Point.

4 If you had those kinds of things agreed to and
5 ironed out, then you could concentrate on the specific
6 things, but I think that the answer is, you have to look
7 at the specific plant, when we use it in a
8 decision-making mode. That is my view.

9 MR. KERR: Suppose what you are trying to
10 decide is whether the risk posed by plant in some
11 location is too great or greater than some other plant,
12 and you are not at this point yet trying to fix up, you
13 are just trying to decide what is the risk. It seems to
14 me that unless you can convince yourself that the
15 difference among the plants is greater than the
16 uncertainty in the individual analysis, you do not gain
17 anything by doing a specific analysis. If you go to the
18 next step and say I am going to try to reduce risk, then
19 you may have to look at the individual plant in order to
20 know where to allocate your resources, but many of the
21 studies that have been asked for presumably have been
22 asked for not to fix up, although apparently now they
23 are being used that way, but rather to decide, is the
24 risk comparable to or too great or something of that
25 sort.

1 And there it seems you are asking an overall
2 question and not asking how the individual system or
3 subsystem has performed, and for that there is a real
4 question in my mind as to whether you buy anything by
5 going to the individual plants.

6 MR. MARCHATERRE: I think that is a valid
7 point. I would just make one comment which is, I think,
8 that at least my view in looking at Zion, for instance,
9 because in fact at the time Zion was licensed there were
10 questions about the site being a populace area, and in
11 fact it has a strong containment. That kind of plant
12 specifics has to be added, I think, to what you are
13 suggesting.

14 MR. KERR: I don't hold the answer to the
15 question I am raising, and I don't pretend to, but it
16 seems to me it has an influence on how one allocates
17 resources.

18 MR. BENDER: If I were to accept the premise
19 as you stated it, it would not be a lot different from
20 saying, when WASH-1400 picked four representative plants
21 and made their judgments on the basis of that, you would
22 be able to take that judgment and apply it to all of the
23 plants that have been engineered.

24 MR. KERR: If the answer is the uncertainty in
25 an individual is bigger than the difference between

1 members of a class, it seems to me one could draw that
2 conclusion.

3 MR. BENDER: That is an important premise that
4 maybe didn't come out too well. Maybe we don't know.

5 MR. KERR: I certainly don't know, and that's
6 the reason I'm asking the people who have looked at
7 these things.

8 MR. BENDER: If the 30 percent uncertainty
9 dominates the risk, then trying to fix the 50 percent
10 will not mean very much, but if that is the case, then
11 dealing with the plant specifically won't help either.

12 MR. CKRENT: I think there is a considerable
13 difference between a plant that has an estimated mean
14 value of core melt, let's say of 10^{-4} with 5 percent
15 and 95 percent numbers of 10^{-3} , 10^{-3} , and another
16 plant that has an estimated mean value of 9.5×10^{-5} ,
17 even though it falls inside the uncertainty band for the
18 first one. So, I have to be a little bit careful about
19 saying, well, something falls within the uncertainty
20 band, and therefore is not really different, and so
21 forth.

22 In other words, it seems to me the question is
23 fairly complicated.

24 MR. KERR: I don't pretend to know the
25 answer.

1 MR. OKRENT: The question isn't, but the
2 answer is.

3 MR. KERR: I agree. I have been asked it, as
4 a matter of fact, but we are now putting a lot of
5 emphasis on individual analyses, and what I have seen
6 come out of these in many cases are factors of two or
7 three difference. Once in a while, a factor of ten.
8 And I am not sure a factor of ten is significant, but I
9 am pretty well convinced that a factor of two or three
10 is not at all.

11 MR. BENDER: A lot depends on how many orders
12 of magnitude you are working with. If you are down in
13 the 10^{-6} range --

14 MR. KERR: Perhaps that is exactly where the
15 uncertainties lie. They don't like up in the higher
16 figures.

17 MR. OKRENT: No, but we have seen them in the
18 10^{-3} , 10^{-4} region as a factor of ten difference or
19 more between the two estimates just today, so that is a
20 big, big difference in a pretty big number.

21 MR. SEIDENSTICKER: Could I make one comment?
22 Certainly from the structural point of view of the
23 overall containment system, I think that it has begun a
24 movement at least for those who have made a significant
25 effort on the PRA's to look at the failure modes of

1 their containment system as a system. I think that has
2 not been true up until now. It has been codified and it
3 is the usual engineering demand to give me, what do you
4 want, one-tenth of 1 percent leakage rate per day,
5 design pressure, and that sort of thing.

6 And what we find, for example, in doing the
7 survey for the NRC on penetrations, and maybe that
8 partly answers your question on generic versus specific,
9 the variations in both types of containments in the
10 material used, the sizes, the locations, the types of
11 penetrations, some equipment air locks or hatches are on
12 the inside, some on the outside, by the time you get all
13 done, the variabilities between plant designs are very
14 great and very hard to pin down, and each turns out to
15 have strong points and weaknesses that are different,
16 that on the surface look very different.

17 So, I don't know if that sheds any light at
18 all on your question.

19 MR. KERR: What you say is very true. On the
20 other hand, I gather from what the staff has concluded
21 that if you pick an individual contention, that the
22 staff does not believe that they now know how to predict
23 the performance of that containment under serious
24 accident conditions, which leads me to believe that
25 there's a great deal of uncertainty in making

1 predictions.

2 MR. SEIDENSTICKER: I am always in favor of a
3 backup approach. The bottom line of our proposal, not a
4 proposal, but a proposed plan for containment
5 penetration is, there is no hope. There is not enough
6 resource money and time and people to test every
7 possible containment penetration. You will have to do
8 what amounts to a generic study both experimentally and
9 analytically.

10 MR. KERR: It is not a good analogy, but in a
11 way it seems to me that what we are sort of doing is
12 taking mortality statistics, which insurance companies
13 can use rather well, to predict populations and trying
14 to use them to predict how long I am going to live. I
15 don't think that is necessarily likely to be very
16 successful. That is an oversimplification, but does
17 anybody have any further questions or comments?

18 (No response.)

19 MR. KERR: This was scheduled to end at 3:00
20 p.m., and it is ending at 3:00 p.m. plus a few hours.
21 So, I declare the meeting to be adjourned, with thanks
22 to all of you who participated.

23 (Whereupon, at 4:55 p.m., the meeting was
24 adjourned.)

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/Subcommittee on Reliability and Probabilistic
Assessment

Date of Proceeding: November 3, 1982

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript
thereof for the file of the Commission.

Jane N. Beach

Official Reporter (Typed)

Jane N. Beach

Official Reporter (Signature)

SUMMARY OF BNL'S

MAJOR REVIEW RESULTS OF

LIMERICK PRA

BY

E. S. CHELLIAH

RRAB/DST/NRR

REVIEW RESULTS OF CORE DAMAGE FREQUENCY

o LIMERICK PRA, REV. 4	-	$1.5 \times 10^{-5}/\text{RY}$
BNL'S REVIEW	-	$1.1 \times 10^{-4}/\text{RY}$

o HIGHER ESTIMATE DUE TO:

(A) BNL ADDED SOME SUPPORT SYSTEM DEPENDENCIES


(B) BNL MODIFIED PRA EVENT TREES AND FAULT TREES

(C) BNL REVISED FREQUENCY VALUES OF INITIATING EVENTS

DOMINANT ACCIDENT SEQUENCES BY CORE DAMAGE FREQUENCY

- T_E - Loss of off-site power
- T_F - MSIV Closure
- T_T - Turbine trip
- T_I - Inadvertent open relief valve
- Q - Loss of feedwater and condensate system
- U - Loss of high pressure coolant injection
- V - Loss of low pressure coolant injection
- X - Human failure of timely initiation of ADS

T _I W	9.7×10^{-7}
T _T QUX	2.0×10^{-6}
T _E W	3.3×10^{-6}
T _I UX	5.0×10^{-6}
T _E UX	1.4×10^{-5}
T _F QUX	1.4×10^{-5}
T _E UV	4.6×10^{-5}




LIMERICK


BNL

85% of 1.5×10^{-5}

78% of 1.1×10^{-4}

RELATIVE CONTRIBUTION OF INITIATING EVENTS
TO TOTAL CORE DAMAGE FREQUENCY





Summary of the Accident Sequence Frequencies Leading to Degraded Core Conditions Summed Over All Accident Sequences within a Class

* Mean Frequency

**Applicant implemented ATWS alternate 3A fix as part of his PRA activities.

MAJOR REVIEW RESULTS
OF CONTAINMENT RESPONSE ANALYSIS

<u>CASE</u>	<u>REVIEW/RE-ASSESSMENT</u>	<u>IMPACT ON RIS'K</u>
(01)	MODIFIED CONTAINMENT EVENT TREES	(A) A FACTOR OF 2 INCREASE IN MEAN ACUTE FATALITIES (B) A FACTOR OF 1.7 INCREASE IN MEAN LATENT FATALITIES
(02)	REMOVED POOL FLASHING AT CONTAINMENT FAILURE	(A) A FACTOR OF 3 DECREASE IN LATENT FATALITIES
(03)	UPDATED PRA'S TREATMENT OF FISSION PRODUCT AEROSOL BEHAVIOR	(A) A FACTOR OF 3 INCREASE IN LATENT FATALITIES
(04)	ASSESSED EX-VESSEL CORE DEBRIS BEHAVIOR	(A) PRA POSITION IS CONSERVATIVE (B) REMOVAL OF THIS CONSERVATISM MAY RESULT IN SIGNIFICANT REDUCTION IN EARLY AND LATENT FATALITIES

OVERALL SUMMARY OF BNL'S REVIEW

CORE DAMAGE FREQUENCY:

- o HIGHER THAN LIMERICK PRA
(A FACTOR OF ABOUT 7 HIGHER)
- o HIGHER THAN WASH-1400 BWR
(A FACTOR OF ABOUT 3 HIGHER)

DOMINANT ACCIDENT SEQUENCE:

- o LOSS OF OFFSITE POWER FOLLOWED BY THE FAILURE OF HIGH PRESSURE AND LOW PRESSURE COOLANT INJECTION
- o CONTRIBUTION TO TOTAL CORE DAMAGE FREQUENCY 42%

DOMINANT CORE DAMAGE CONTRIBUTORS:

- o LOSS OF HIGH PRESSURE COOLANT INJECTION
- o HUMAN FAILURE OF TIMELY INITIATION OF ADS SYSTEM

RISK:

- ~~o MEAN EARLY AND LATENT FATALITIES OF LIMERICK ARE ALMOST SAME AS WASH-1400 BWR~~
- o ABOUT 60% OF EARLY FATALITIES IS DUE TO ATWS INDUCED CORE DAMAGE IN A FAILED CONTAINMENT
- o LIMERICK PRA APPEARS CONSERVATIVE IN ITS CONTAINMENT RESPONSE ANALYSIS

STAFF'S FUTURE PLAN

- (A) REVIEW BNL'S DRAFT NUREG/CR REPORT
- (B) INCORPORATE COMMENTS, AS APPROPRIATE AND ISSUE A FINAL NUREG/CR REPORT
- (C) FOCUS STAFF ATTENTION TO DOMINANT ACCIDENT SEQUENCES AND DETERMINE WHETHER ANY ADDITIONAL ACTIONS ARE NEEDED TO REDUCE RISK AT HIGH POPULATION DENSITY SITE SUCH AS LIMERICK

Isiac #1

CORE MELT
DOMINANT SEQUENCES

>80%

UNIT 2

IPPSS

SANDIA

SEISMIC

SEISMIC

FIRE

FIRE

HURRICANE

HURRICANE

TORNADO

LOCA-RECIRC.

LOCA-RECIRC.

CCW PIPE BREAK

STATION BLACKOUT (PARTIAL)

UNIT 3

FIRE

FIRE

LOCA-RECIRC.

LOCA-RECIRC.

CCW PIPE BREAK

CORE MELT FREQUENCIES

	IPPSS INTERNAL	REVISED INTERNAL	IPPSS EXTERNAL	REVISED EXTERNAL	IPPSS TOTAL	REVISED TOTAL
INDIAN PT 2	9 (-5)	1.9 (-4)	3.7 (-4)	1.3 (-3)	4.6 (-4)	1.5 (-3)
INDIAN PT 3	1.3 (-4)	2.7 (-4)	6.6 (-5)	2.6 (-4)	2 (-4)	5.3 (-4)

INDIAN PT 2

CONTAINMENT FAILURE PRIOR TO CORE MELT
INTERNAL EVENT SEQUENCES

IPPSS

REVISED

0 INTERFACING SYSTEMS LOCA
4.7 (-7)

0 INTERFACING SYSTEMS LOCA
3.4 (-7)

0 STEAM GENERATOR TUBE RUPTURE
AND STUCK OPEN SECONDARY
SAFETY VALVE
2.6 (-7)

INDIAN POINT 2

CORE MELT WITH NO CONTAINMENT COOLING

IPPSS (>95%)

REVISED (>95%)

- 0 SEISMIC 1.4 (-4)
- 0 FIRE IN ELECTRICAL TUNNEL
AND SWITCHGEAR ROOM
1.4 (-4)
- 0 HURRICANE 2.7 (-5)
- 0 TORNADO 1.6 (-5)

- 0 HURRICANE 5.4 (-4)
- 0 FIRE IN ELECTRICAL TUNNEL
AND SWITCHGEAR ROOM
4.2 (-4)
- 0 SEISMIC 2.8 (-4)
- 0 TORNADO 1.6 (-5)

INDIAN PT 2
CORE MELT WITH CONTAINMENT COOLING
INTERNAL EVENT SEQUENCES

IPPSS (~90%)

REVISED (~90%)

0 LOSS OF OFFSITE POWER, LOSS OF
2/3 DIESELS, RCP SEAL LOCA, AND
FAILURE TO RESTORE AC WITHIN 1 HR

3 (-5)

0 SMALL/MED/LARGE LOCA AND
FAILURE OF RECIRCULATION COOLING

3.5 (-5)

0 LOSS OF ALL AC, RCP SEAL LOCA,
AND FAILURE TO RESTORE AC
WITHIN 1 HR

6.5 (-6)

0 LARGE LOCA AND FAILURE OF LPIS

5.4 (-6)

0 SMALL/MED/LARGE LOCA AND FAILURE
OF RECIRCULATION COOLING

9.1 (-5)

0 CCW PIPE BREAK, RCP SEAL LOCA,
AND FAILURE OF HPIS

3.8 (-5)

0 LOSS OF OFFSITE POWER, LOSS OF 2
DIESELS, RCP SEAL LOCA, AND FAILURE
TO RESTORE AC WITHIN 1 HR

1.5 (-5)

0 LOSS OF MAIN FEEDWATER, FAILURE OF
AFWS AND F&B COOLING

1 (-5)

0 SMALL LOCA AND FAILURE OF HPIS

1 (-5)

INDIAN PT 3
CONTAINMENT FAILURE PRIOR TO CORE MELT
INTERNAL EVENT SEQUENCES

IPPSS

REVISED

0 INTERFACING SYSTEMS LOCA
4.8 (-7)

0 INTERFACING SYSTEMS LOCA
4.6 (-7)

0 STEAM GENERATOR TUBE RUPTURE
AND STUCK OPEN SECONDARY
SAFETY VALVE
2.4 (-7)

INDIAN POINT 3

CORE MELT WITH NO CONTAINMENT COOLING

IPPSS (>95%)

REVISED (>99%)

0 FIRE IN SWITCHGEAR ROOM AND
CABLE SPREADING ROOM

6.1 (-5)

0 SEISMIC 2.4 (-6)

0 TORNADO 9.2 (-7)

0 LOSS OF ALL AC 5 (-7)

0 FIRE IN SWITCHGEAR ROOM AND
CABLE SPREADING ROOM

2.1 (-4)

0 SEISMIC 2.4 (-5)

0 FIRES IN CABLE TUNNEL, CABLE
SPREADING ROOM, AND SWITCHGEAR ROOM
9 (-6)

0 TORNADO 9.2 (-7)

INDIAN PT 3

CORE MELT WITH CONTAINMENT COOLING
INTERNAL EVENT SEQUENCES

IPPSS (~90%)

REVISED (~90%)

0 SMALL LOCA AND FAILURE OF HPRS

8.2 (-5)

0 MED/LARGE LOCA AND FAILURE
OF LPRS

2.2 (-5)

0 LARGE LOCA AND FAILURE OF
SAFETY INJECTION

5.4 (-6)

0 SMALL LOCA AND FAILURE OF HPIS

2.8 (-6)

0 LOSS OF ALL AC, RCP SEAL LOCA,
AND FAILURE TO RESTORE AC
WITHIN 1 HOUR

2.7 (-6)

0 CCW PIPE BREAK, RCP SEAL LOCA, AND
FAILURE OF HPIS

1.4 (-4)

0 MED/LARGE LOCA AND FAILURE OF
LPRS

7.8 (-5)

0 SMALL LOCA AND FAILURE OF HPRS

1.5 (-5)

0 SMALL LOCA AND FAILURE OF HPIS

1 (-5)

0 ATWS AND FAILURE OF F&B COOLING

7.4 (-6)