LICENSEE E LINT REPORT

•
CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 W I L B R 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 57 CAT 58 5
CON'T O 1 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
DURING POWER ESCALATION FOLLOWING REFUELING OUTAGES, WATER LEVEL SAFETY
CHANNELS 1 AND 2 INDICATED APPROXIMATELY 5 INCHES BELOW ACTUAL REACTOR W
O 14 ATER LEVEL. THIS CONDITION WAS CONSERVATIVE WITH RESPECT TO A POSSIBLE
O TO LOW WATER LEVEL CONDITION, BUT NONCONSERVATIVE WITH RESPECT TO A POSSIBL
0 6 E HIGH WATER LEVEL CONDITION. NO WATER LEVEL TRANSIENT OCCURRED DURING
0 7 L 15 DAYS CONDITION EXISTED.
0 8 L 80 7 8 9 SYSTEM CAUSE CAUSE COMP. VALVE
SYSTEM CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCOD
17) REPORT 8 2
ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT NPRD-4 PRIME COMP. COMPONENT MANUFACTURER SUBMITTED FORM SUB. SUPPLIER MANUFACTURER MANUFACTURER PRIME COMP. COMPONENT MANUFACTURER MANUFACTURER PRIME COMP. COMPONENT PRIME
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
IT IS BELIEVED THAT NEW EQ WATER LEVEL TRANSMITTERS, FOXBORO, MODEL N-E1
3DH-HAMI-CHL, EXPERIENCED DRIFTING DURING BREAK-IN PERIOD. WATER LEVEL
CHANNELS 1 AND 2 WERE RECALIBRATED AND TESTED DURING UNPLANNED REACTOR S
HUTDOWN.
FACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32
7 8 9 10 12 13 44 45 46 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
1 6 Z 33 Z 34 NA
1 7 0 0 0 37 Z 38 NA NUMBER 137 Z 38 NA 1 1 12 13
PERSONNEL INJURIES NUMBER DESCRIPTION 41) 1 B 0 0 0 0 0 NA
1 8 9 11 12 80 LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION 43
7 8 9 10 NA 8211060206 821027 PDR ADDCK 05000409
PUBLICITY ISSUED DESCRIPTION 45 S PDR NRC USE ONLY ISSUED NA NA
L. S. GOODMAN 608-689-2331
NAME OF PREPARER L. S. GOODMAN PHONE: 000-009-2331