DCS No: 50-293/821102 Date: November 2, 1982

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-82-70

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility: Boston Edison Company

Pilgrim Nuclear Power Station

Plymouth, Massachusetts

(DN 50-293)

Licensee Emeryency Classification:

Notification of Unusual Event

Alert

Site Area Emergency General Emergency

X Not Applicable

Subject: INCORRECT SAFETY VALVE SETTING

At 10:47 a.m. on 11/2/82 the licensee commenced a controlled shutdown from 98% power in accordance with Technical Specification 3.6.D.2 because of information which indicated that at least one of the two installed safety valves has a nonconservative lift setting.

The licensee plans to place the plant in the cold shutdown condition and perform in-place testing to verify the correct setting.

The licensee identified the problem following the recent overhaul of a spare valve. Onsite testing revealed lift pressure at approximately 1240 psig instead of 1150 psig with nitrogen. Further questioning of installed valves prompted a review of maintenance records. Test data sheets for the 'A' valve currently installed indicates a setting of 1240 psig using nitrogen.

Nameplate information on safety valve:

Manufacturer: Dresser Industries, Inc.

No. installed - 2 Type: 3777 QA-RT-21

Set Pressure: 1240 psig (steam)

Capacity: 644,500 lb/hr Bore Diameter: 3.75 in.

Blowdown: 50 psig Valve Setting Pressure

STM Hi 1240

Lo 1235

N2 Hi 1150

Lo 1125

NRC was informed at 11:10 a.m., November 2, 1982 via ENS call from control room to HQDO. The resident inspectors are closely following licensee actions concerning this event. The Commonwealth of Massachusetts has been informed.

CONTACT:

Elsasser

Brunner

488-1235

488-1210

8211060212 821102 PDR I&E PNO-I-82-070 PDR

Region I Form 83 (Rev. June, 1982) IE34

DISTRIBUTION: H. St.	MNBB	Phillips 4:0-3	E/W	Willste	Mail: ADM:DM
Chairman Palladino DOT:Trans. Only	ED0	NRR	IE	NMSS	
Comm. Gilinsky	PA		OIA	RES	
Comm. Ahearne	MPA		AEOD		
Comm. Roberts	ELD				
Comm. Asselstine					
ACRS	Air F	Rights I	NPO		
SECY	SP	N	SAC		
CA					
PDR Regional	Offices			sident Section ident Office	
			License	ee:	
			(React)	or Licensees)	