

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N J S G S 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 _____ 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 REPORT SOURCE L 0 5 0 0 0 3 1 1 7 0 9 2 7 8 2 8 1 0 2 0 8 2 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 At 0956 hours, September 27, 1982, it was discovered that the Radiation Monitoring
03 System (RMS) APD filter drive unit was malfunctioning. The RMS channels R11A, R12A,
04 and R12B were declared inoperable and Action Statement 3.3.3.1 Actions 24 and 25 were
05 entered at 0956 hours.
06
07
08

09 SYSTEM CODE BA 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE X X X X X X X 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
17 LEP RO REPORT NUMBER 8 2 1 1 4 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN A 18 Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED Y 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 25
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 The pin attaching the solenoid arm to the ratchet cog had slipped out of position.
11 The pin had been installed through the bottom instead of the top of the connecting
12 sleeve. The pin was reinstalled through the top of the connecting sleeve and the
13 unit tested satisfactorily. At 1115 hours, September 27, 1982, RMS Channels R11A,
14 R12A and R12B were declared operable and Action Statement 3.3.3.1.b Actions 24 and
25 were terminated.

15 FACILITY STATUS E 28 % POWER 0 8 2 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Routine Maintenance 32
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT Z 33 Z 34 NA 35 AMOUNT OF ACTIVITY NA 36 LOCATION OF RELEASE
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 80

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 80

8211060222 821020
PDR ADOCK 05000311 PDR
S

NRC USE ONLY

NAME OF PREPARER R. Heller

PHONE: 609/935-6000 Ext 3078