

50-298



# Nebraska Public Power District

GENERAL OFFICE  
P.O. BOX 499, COLUMBUS, NEBRASKA 68601-0499  
TELEPHONE (402) 564-8561

LQA8200205

October 28, 1982

Office of Nuclear Reactor Regulation  
Attention: Mr. Domenic B. Vassallo, Chief  
Operating Reactors Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Revision to In-Service Testing Relief Requests -  
Pump Vibration Testing

Reference: 1) Letter from J. M. Pilant to D. B. Vassallo  
dated October 19, 1982, "Revision to In-Service  
Testing Relief Request"

Dear Mr. Vassallo:

Our letter of Reference 1 submitted replacement pages for two In-Service Testing Relief requests. After discussions with the Staff this date, the District is modifying relief request No. RP-04. Enclosed is the applicable revised page in accordance with the Staff's request.

Should you require additional information relating to this revision, please contact me.

Sincerely,

Jay M. Pilant  
Division Manager of Licensing  
and Quality Assurance

JMP:JDW:cmk

Enclosure

8211060238 821028  
PDR ADOCK 05000298  
P PDR

A047

TABLE 1  
ALLOWABLE RANGES OF VIBRATION QUANTITIES

V Reference ** (Vr)	Acceptable	Alert	Required Action
0-.1 in/sec	0-2Vr (100%)*	>2Vr-4Vr (300%)	>4Vr (>300%)
>.1-.2 in/sec	0-1.75Vr (75%)	>1.75Vr-2.5Vr (150%)	>2.5Vr (>150%)
>.2-.3 in/sec	0-1.25Vr (25%)	>1.25Vr-2.0Vr (100%)	>2.0Vr (>100%)
>.3 in/sec	0-1.10Vr (10%)	>1.1Vr-1.5Vr (50%)	>.623 in/sec

\*All percentages shown in parentheses are the maximum allowable percents over the original reference value for that particular range.

\*\*These values are unfiltered.