

CONTROL BLOCK: [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | S | C | V | C | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 0 | 0 | 0 | 4 | 5

CONT

0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 0 | 3 | 9 | 5 | 7 | 1 | 0 | 0 | 1 | 8 | 2 | 8 | 1 | 0 | 2 | 8 | 8 | 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing Hot Shutdown Testing (HST-2), "Reactor Vessel O-Ring Leak Test," |
0 3 | the Reactor Coolant System pressure is required to be increased to 2350 psig. |
0 4 | The pressurizer PORV's lift at 2335 psig. The PORV Block Valves were shut to |
0 5 | isolate the PORV's. At the conclusion of the test, one block valve (MVG-8000A) |
0 6 | would not reopen. No adverse consequences since two block valves remained |
0 7 | OPERABLE. Also, there are three pressurizer code safeties that back up the |
0 8 | PORV's for overpressure protection.

0 9 | SYSTEM CODE | C | B | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | F | 13 | COMPONENT CODE | V | A | L | V | E | X | 14 | COMP. SUBCODE | E | 15 | VALVE SUBCODE | D | 16 |
17 | LER/RO REPORT NUMBER | 8 | 2 | 21 | SEQUENTIAL REPORT NO. | 0 | 1 | 1 | 0 | 24 | OCCURRENCE CODE | / | 0 | 3 | 27 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32 |
ACTION TAKEN | B | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 | ATTACHMENT SUBMITTED | Y | 23 | NRPD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | W | 1 | 2 | 0 | 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause was due to the natural end of the valve stem packing life. Packing was |
1 1 | adjusted due to wear which subsequently contributed to an overtorque condition in |
1 2 | the opening mode by the valve operator. The stem packing was replaced. The |
1 3 | valve was tested satisfactory per applicable Surveillance Test Procedure. PORV |
1 4 | Block Valves will be added to the Station Preventive Maintenance Program.

1 5 | FACILITY STATUS | Z | 28 | % POWER | 0 | 0 | 0 | 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Routine Testing/Observation | 32

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36

1 7 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39

1 8 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43

2 0 | PUBLICITY ISSUED DESCRIPTION | N | 44 | DESCRIPTION | N/A | 45

8211060300 821028 PDR ADOCK 05000395 S PDR

NRC USE ONLY

NAME OF PREPARER Curtis Fields PHONE: (803) 345-5209