	LICENSEE EVENT REPORT
	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N J S G S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 6 5 6 5 CAT 58
0 1 7 8	REPORT L 6 0 5 0 0 0 2 7 2 7 0 1 10 9 8 2 8 1 0 2 0 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
0 2	On January 8, 1982, at 1500 hours, the No. 13 Charging Pump was declared inoperable
0 3	due to the Component Cooling Water System being tagged out for planned maintenance.
0 4	With Nos. 11 and 12 Charging Pumps being previously tagged out for planned maintenance,
0 5	Action Statements 3.1.2.1 and 3.1.2.3 were entered. At Ollo hours, January 9, a sample
0 6	of the primary coolant indicated a boron concentration of 1991 PPM. This change in
0 7	boron concentration constituted a positive reactivity change. At 0110 hours,
0 8	January 9, Action Statement 3.0.3 was entered.
0 9 7 8	SYSTEM CAUSE CAUSE SUBCODE SUB
	17 REPORT NUMBER 2 23 24 26 27 28 29 30 31 32
	ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT SUBMITTED FORM SUB. PRIME COMP. COMPONENT MANUFACTURER SUBMITTED FORM SUB. PRIME COMP. SUPPLIER MANUFACTURER WANUFACTURER
1101	Upon detection of the addition of positive reactivity, the operators initiated rapid
11	boration of the Reactor Coolant System by temporarily operating the No. 13 Charging
1 2	Pump. At 2240 hours, January 9, 1982, Action Statements 3.1.2.1, 3.1.2.3, and 3.0.3
1 3	were terminated. An on the spot change has been written to ensure Reactor Coolant
1 4	System boration has been completed prior to stopping the last Reactor Coolant Pump.
7 8	STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 DISCOVERY DESCRIPTION 32
	CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35 Z 33 Z 34 N/A L N/A N/A L N/A
1 7 7 8	NUMBER TYPE DESCRIPTION 39 N/A
1 8	PERSONNEL INJURIES NUMBER DESCRIPTION 41 N/A
1 9	LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION N/A B211060344 B21020 PDR ADOCK 05000272 PDR ADOCK 05000272
2 0	POBLICITY SSUED DESCRIPTION 45 N/A N/A
100	R. Heller 609/935-6000 Ext 3078 0