

NUREG/CR-5584
ORNL/TM-11575

Results of Crack-Arrest Tests on Two Irradiated High-Copper Welds

Prepared by
S. K. Iskander, W. R. Corwin, R. K. Nanstead

Oak Ridge National Laboratory

Prepared for
U.S. Nuclear Regulatory Commission

AVAILABILITY NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW, Lower Level, Washington, DC 20585
2. The Superintendent of Documents, U.S. Government Printing Office, P.O. Box 87082, Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC Office of Inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and transcripts, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Information Resources Management, Distribution Section, U.S. Nuclear Regulatory Commission, Washington, DC 20585.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7020 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

DISCLAIMER NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

NUREG/CR-5584
ORNL/TM-11575
RF

Results of Crack-Arrest Tests on Two Irradiated High-Copper Welds

Manuscript Completed: October 1990

Date Published: December 1990

Prepared by
S. K. Iskander, W. R. Corwin, R. K. Nanstead

Oak Ridge National Laboratory
Operated by Martin Marietta Energy Systems, Inc.

Oak Ridge National Laboratory
Oak Ridge, TN 37831-6285

Prepared for
Division of Engineering
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555
NRC FIN L1098
Under Contract No. DE-AC05-84OR21400

CONTENTS

LIST OF TABLES	v
LIST OF FIGURES	vii
NOMENCLATURE	ix
FOREWORD	xi
ABSTRACT	1
1. INTRODUCTION	2
2. DESCRIPTION OF MATERIALS AND PROCEDURES	3
2.1 Testing Procedures	3
2.2 Analysis Procedures	12
3. RESULTS AND DISCUSSION	18
4. COMPARISON WITH OTHER DATA	36
5. SUMMARY	37
6. ACKNOWLEDGMENTS	38
REFERENCES	39
APPENDIX A. Detailed Crack-Arrest Specimen Data and Test Results	41
APPENDIX B. Listing of Basic Computer Code CA_TEST	63
APPENDIX C. Young's Modulus used in the Evaluation of the Crack-Arrest Data	77
APPENDIX D. Typical Output From CA_TEST for a Weld-embrittled and Duplex Specimen	81
APPENDIX E. Strip Charts and Fracture Surfaces	87

LIST OF TABLES

	Page
1. Chemical composition of the two submerged-arc welds in the HSSI Fifth and Sixth Irradiation Series	5
2. Irradiated crack-arrest specimen complement for each of the 72W and 73W weldments	5
3. Nominal dimensions of weld-embrittled crack-arrest specimens used in the Sixth Irradiation Series	7
4. Estimate of the average relative error in $f(x)$ (and thus in K_t) due to errors in the determination of initial and final crack lengths $x = a_0/W = 0.33$ and $x = a_s/W = 0.85$, respectively, for the various specimen sizes	16
5. Summary of the irradiation temperature and fluence for Series 72W and 73W crack-arrest specimens	19
6. Initial, adjusted, and normalized reference temperatures RT_{NDT} for the 72W and 73W weldments	22
7. Unirradiated crack-arrest toughness data obtained from testing weldment 72W ($RT_{NDT} = -23^\circ C$)	25
8. Unirradiated crack-arrest toughness data obtained from testing weldment 73W ($RT_{NDT} = -34^\circ C$)	27
9. Irradiated crack-arrest toughness data for the weld-embrittled type specimens from weld 72W (normalized $RT_{NDT} = 57^\circ C$)	29
10. Irradiated crack-arrest toughness data for the weld-embrittled type specimens from weld 73W (normalized $RT_{NDT} = 59^\circ C$)	30
A.1. Measured dimensions in millimeters of the unirradiated crack-arrest specimens from the 72W and 73W weldments	47
A.2. Measured dimensions in millimeters of the irradiated weld-embrittled crack-arrest specimens from the 72W and 73W weldments	50
A.3. Posttest values measured for unirradiated crack-arrest specimens from the 72W and 73W weldments	52

A.4.	Posttest values measured for <i>irradiated</i> crack-arrest specimens from the 72W and 73W weldments	55
A.5.	Values measured during crack-arrest testing of the unirradiated weldments 72W and 73W	56
A.6.	Values measured during crack-arrest testing of <i>irradiated</i> weldments 72W and 73W	59
C.1.	Comparison of Young's modulus calculated using values given in the ASME Code and Eq. (C.1)	71

LIST OF FIGURES

	Page
1. Cross section of typical submerged-arc weld used in the 72W and 73W welds used in the Fifth and Sixth Irradiation Series	4
2. Nominal dimensions in millimeters of weld-embrittled crack-arrest specimens used in the Sixth Irradiation Series	6
3. Schematic drawing of equipment used to perform crack-arrest testing of irradiated specimens before set-up in the hot-cell 500-kN testing machine	8
4. Photograph of equipment used to perform crack-arrest testing of irradiated specimens before set-up in the hot-cell 500-kN testing machine	9
5. Closeup view of the environmental chamber used for temperature conditioning of the crack-arrest specimens after installation in the hot-cell 500-kN tensile testing machine	11
6. General view of the test system as it is being prepared for a crack-arrest test	11
7. Chart produced on an X-Y plotter during a typical crack-arrest test of an irradiated specimen	13
8. Photograph taken through a Kollmorgen periscope of the fracture surfaces of two typical crack-arrest specimens after heat-tinting and splitting them open. The 2- or 3-mm, darker, transverse strips near the initial crack front are the brittle crack-starter weld beads	14
9. Calibration function for crack arrest specimens as given in ASTM E 1221-88	17
10. Distribution of fluence in the 18 irradiated weld-embrittled-type crack specimens tested from the 72W weld	19
11. Distribution of fluence in the 17 irradiated crack specimens of the 73W weld that were tested successfully	19

12. Yield and ultimate strengths vs test temperature for weld 72W (a) unirradiated and (b) irradiated at a nominal temperature of 288°C to 1.57×10^{19} neutrons/cm ² (>1 MeV)	20
13. Yield and ultimate strengths vs test temperature for weld 73W (a) unirradiated and (b) irradiated at a nominal temperature of 288°C to 1.56×10^{19} neutrons/cm ² (>1 MeV)	21
14. Charpy V-notch-impact energy vs test temperature for welds 72W and 73W (a) unirradiated (b) irradiated at a nominal temperature of 288°C to 1.51×10^{19} neutrons/cm ² (>1 MeV)	23
15. Detailed crack-arrest toughness K_a vs test temperature for the unirradiated 72W weld showing the different specimen sizes and types used	32
16. Detailed crack-arrest toughness K_a vs test temperature for the unirradiated 73W weld showing the different specimen sizes and types used	32
17. Detailed crack-arrest toughness K_a vs test temperature for the irradiated 72W weld showing the different specimen sizes and types used	33
18. Detailed crack-arrest toughness K_a vs test temperature for the irradiated 73W weld showing the different specimen sizes and types used	33
19. Unirradiated and irradiated crack-arrest toughness K_a vs test temperature for the 72W weld	34
20. Unirradiated and irradiated crack-arrest toughness K_a vs test temperature for the 73W weld	34
21. All crack-arrest toughness K_a data for welds 72W and 73W plotted as a function of $(T \cdot RT_{NDT})$	35
A.1. Comparison of values of Young's moduli as calculated from an American Society of Mechanical Engineers table and an Electric Power Research Institute expression	61

NOMENCLATURE

ACRONYMS

ASME	American Society of Mechanical Engineers
CMOD	crack mouth opening displacement
CVN	Charpy V-notch
dpa	displacements per atom
DX	duplex
EPRI	Electric Power Research Institute
HSSI	Heavy-Section Steel Irradiation
ORNL	Oak Ridge National Laboratory
NDT	nil-ductility-transition temperature, as determined by the drop-weight test according to ASTM E 208
NRC	U.S. Nuclear Regulatory Commission
RPVs	reactor pressure vessels
RT _{NDT}	reference nil-ductility-transition temperature, determined in accordance with Subarticle NB-2330 of ASME Boiler and Pressure Vessel Code, Sect. III
WE	weld-embrittled

SYMBOLS

a	initial slot length a_0 or final crack length a_s
a_b	arrested crack length
a_0	initial slot length
B	specimen thickness (Fig. 2)
B_N	specimen thickness at crack plane (Fig. 2)
D	split-pin hole diameter (Fig. 2)
δ	crack mouth opening displacement
ΔTT_{41-J}	shift in the 41-J CVN-impact energy level
E	Young's modulus
f(x)	crack-arrest specimen calibration function [Eq. (2)]
ϕ	fluence, neutrons/cm ²
2H	specimen height (Fig. 2)
K_a	value of the stress intensity factor shortly after arrest*
K_o	value of the stress intensity factor at crack initiation
K_I	stress intensity factor
K_{Ia}	value of the crack-arrest fracture toughness K_a for a crack that arrests under conditions of crack front plane-strain*
K_{Ic}	plane-strain fracture toughness
K_{Jc}	a measure of fracture toughness calculated from the J-integral J_c at the point of cleavage using the relationship $(K_{Jc})^2 = EJ_c$
K_o	value of the stress intensity factor at crack initiation
L, L'	(See Fig. 2)

*Excerpted from ASTM E 1221-88.

SYMBOLS

N slot width
T test temperature
W nominal width of a crack-arrest specimen
 W_t total width of a crack-arrest specimen (Fig. 2)
x fractional crack depth a/W

FOREWORD

The work reported here was performed at Oak Ridge National Laboratory (ORNL) under the Heavy-Section Steel Irradiation (HSSI) Program, W. R. Corwin, Program Manager. The program is sponsored by the Office of Nuclear Regulatory Research of the U.S. Nuclear Regulatory Commission (NRC). The technical monitor for the NRC is A. Taboada.

This report is designated HSSI Report 3. Reports in this series are listed below:

1. F. M. Haggag, W. R. Corwin, and R. K. Nanstad, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Irradiation Effects on Strength and Toughness of Three-Wire Series-Arc Stainless Steel Weld Overlay Cladding*, NUREG/CR-5511 (ORNL/TM-11439), December 1989.

2. L. F. Miller, C. D. Baldwin, F. W. Stallman, and F. B. K. Kom, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Neutron Exposure Parameters for the Metallurgical Test Specimens in The Sixth Heavy-Section Steel Irradiation Series*, NUREG/CR-5409 (ORNL/TM-11267), May 1990.

3. This report.

The HSSI Program includes both follow-on and the direct continuation of work that was performed under the Heavy-Section Steel Technology (HSST) Program. Previous HSST reports related to irradiation effects in pressure vessel materials and those containing unirradiated properties of materials used in HSSI and HSST irradiation programs are tabulated below as a convenience to reader.

C. E. Childress, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Fabrication History of the First Two 12-in.-Thick A-533 Grade B, Class 1 Steel Plates of the Heavy Section Steel Technology Program*, ORNL-4313, February 1969.

T. R. Mager and F. O. Thomas, Westinghouse Electric Corporation, PWR Systems Division, Pittsburgh, Pa., *Evaluation by Linear Elastic Fracture Mechanics of Radiation Damage to Pressure Vessel Steels*, WCAP-7328 (Rev.), October 1969.

P. N. Randall, TRW Systems Group, Redondo Beach, Calif., *Gross Strain Measure of Fracture Toughness of Steels*, HSSTP-TR-3, Nov. 1, 1969.

L. W. Loeschel, Martin Marietta Corporation, Denver, Colo., *The Effect of Testing Variables on the Transition Temperature in Steel*, MCR-69-189, Nov. 20, 1969.

W. O. Shabbits, W. H. Pyle, and E. T. Wessel, Westinghouse Electric Corporation, PWR Systems Division, Pittsburgh, Pa., *Heavy-Section Fracture Toughness Properties of A533 Grade B Class I Steel Plate and Submerged Arc Weldment*, WCAP-7414, December 1969.

C. E. Childress, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Fabrication History of the Third and Fourth ASTM A-533 Steel Plates of the Heavy Section Steel Technology Program*, ORNL 4313-2, February 1970.

P. B. Crosley and E. J. Ripling, Materials Research Laboratory, Inc., Glenwood, Ill., *Crack Arrest Fracture Toughness of A533 Grade B Class I Pressure Vessel Steel*, HSSTP-TR-8, March 1970.

F. J. Loss, Naval Research Laboratory, Washington, D.C., *Dynamic Tear Test Investigations of the Fracture Toughness of Thick-Section Steel*, NRL-7056, May 14, 1970.

T. R. Mager, Westinghouse Electric Corporation, PWR Systems Div., Pittsburgh, Pa., *Post-Irradiation Testing of 2T Compact Tension Specimens*, WCAP-7561, August 1970.

F. J. Witt and R. G. Berggren, Union Carbide Corp. Nuclear Div., Oak Ridge National Laboratory, Oak Ridge, Tenn., *Size Effects and Energy Disposition in Impact Specimen Testing of ASTM A533 Grade B Steel*, ORNL/TM-3030, August 1970.

D. A. Canonico, Union Carbide Corp. Nuclear Div., Oak Ridge National Laboratory, Oak Ridge, Tenn., *Transition Temperature Considerations for Thick-Wall Nuclear Pressure Vessels*, ORNL/TM-3114, October 1970.

T. R. Mager, Westinghouse Electric Corporation, PWR Systems Div., Pittsburgh, Pa., *Fracture Toughness Characterization Study of A533, Grade B, Class I Steel*, WCAP-7578, October 1970.

W. O. Shabbits, Westinghouse Electric Corp., PWR Systems Div., Pittsburgh, Pa., *Dynamic Fracture Toughness Properties of Heavy Section A533 Grade B Class I Steel Plate*, WCAP-7623, December 1970.

C. E. Childress, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Fabrication Procedures and Acceptance Data for ASTM A-533 Welds and a 10-in.-Thick ASTM A-543 Plate of the Heavy Section Steel Technology Program*, ORNL-TM-4313-3, January 1971.

D. A. Canonico and R. G. Berggren, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Tensile and Impact Properties of Thick-Section Plate and Weldments*, ORNL/TM-3211, January 1971.

C. W. Hunter and J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *Fracture and Tensile Behavior of Neutron-Irradiated A533-B Pressure Vessel Steel*, HEDL-TME-71-76, February 6, 1971.

C. E. Childress, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Manual for ASTM A533 Grade B Class 1 Steel (HSST Plate 03) Provided to the International Atomic Energy Agency*, ORNL/TM-3193, March 1971.

P. N. Randall, TRW Systems Group, Redondo Beach, Calif., *Gross Strain Crack Tolerance of A533-B Steel*, HSSTP-TR-14, May 1, 1971.

C. L. Segaser, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Feasibility Study, Irradiation of Heavy-Section Steel Specimens in the South Test Facility of the Oak Ridge Research Reactor*, ORNL/TM-3234, May 1971.

H. T. Corten and R. H. Sailors, University of Illinois, Urbana, Ill., *Relationship Between Material Fracture Toughness Using Fracture Mechanics and Transition Temperature Tests*, T&AM Report 346, August 1, 1971.

L. A. James and J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *Heavy Section Steel Technology Program Technical Report No. 21, The Effect of Temperature and Neutron Irradiation Upon the Fatigue-Crack Propagation Behavior of ASTM A533 Grade B, Class 1 Steel*, HEDL-TME 72-132, September 1972.

P. B. Crosley and E. J. Ripling, Materials Research Laboratory, Inc., Glenwood, Ill., *Crack Arrest in an Increasing K-Field*, HSSTP-TR-27, January 1973.

W. J. Stelzman and R. G. Berggren, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Radiation Strengthening and Embrittlement in Heavy-Section Steel Plates and Welds*, ORNL-4871, June 1973.

J. M. Steichen and J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *High Strain Rate Tensile Properties of Irradiated ASTM A533 Grade B Class 1 Pressure Vessel Steel*, HEDL-TME 73-74, July 1973.

J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *The Irradiation and Temperature Dependence of Tensile and Fracture Properties of ASTM A533, Grade B, Class 1 Steel Plate and Weldment*, HEDL-TME 73-75, August 1973.

J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *Some Comments Related to the Effect of Rate on the Fracture Toughness of Irradiated ASTM A533-B Steel Based on Yield Strength Behavior*, HEDL-SA 797, December 1974.

J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *The Irradiated Fracture Toughness of ASTM A533, Grade B, Class 1 Steel Measured with a Four-Inch-Thick Compact Tension Specimen*, HEDL-TME 75-10, January 1975.

J. G. Merkle, G. D. Whitman, and R. H. Bryan, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *An Evaluation of the HSST Program Intermediate Pressure Vessel Tests in Terms of Light-Water-Reactor Pressure Vessel Safety*, ORNL/TM-5090, November 1975.

J. A. Davidson, L. J. Ceschin, R. P. Shogan, and G. V. Rao, Westinghouse Electric Corporation, Pittsburgh, Pa., *The Irradiated Dynamic Fracture Toughness of ASTM A533, Grade B, Class 1 Steel Plate and Submerged Arc Weldment*, WCAP-8775, October 1976.

J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *Tensile Properties of Irradiated and Unirradiated Welds of A533 Steel Plate and A508 Forgings*, NUREG/CR-1158 (ORNL/SUB-79/50917/2), July 1979.

J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *The Ductile Fracture Toughness of Heavy Section Steel Plate*, NUREG/CR-0859, September 1979.

K. W. Carlson and J. A. Williams, Hanford Eng. Dev. Lab., Richland, Wash., *The Effect of Crack Length and Side Grooves on the Ductile Fracture Toughness Properties of ASTM A533 Steel*, NUREG/CR-1171 (ORNL/SUB-79/50917/3), October 1979.

G. A. Clarke, Westinghouse Electric Corp., Pittsburgh, Pa., *An Evaluation of the Unloading Compliance Procedure for J-Integral Testing in the Hot Cell, Final Report*, NUREG/CR-1070 (ORNL/Sub-7394/1), October 1979.

P. B. Crosley and E. J. Ripling, Materials Research Laboratory, Inc., Glenwood, Ill., *Development of a Standard Test for Measuring K_{Ic} with a Modified Compact Specimen*, NUREG/CR-2294 (ORNL/SUB-81/7755/1), August 1981.

H. A. Domian, Babcock and Wilcox Company, Alliance, Ohio, *Vessel V-8 Repair and Preparation of Low Upper-Shelf Weldment*, NUREG/CR-2676 (ORNL/Sub/81-85813/1), June 1982.

R. D. Cheverton, S. K. Iskander, and D. G. Ball, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *PWR Pressure Vessel Integrity During Overcooling Accidents: A Parametric Analysis*, NUREG/CR-2895 (ORNL/TM-7931), February 1983.

J. G. Merkle, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *An Examination of the Size Effects and Data Scatter Observed in Small Specimen Cleavage Fracture Toughness Testing*, NUREG/CR-3672 (ORNL/TM-9088), April 1984.

W. R. Corwin, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Assessment of Radiation Effects Relating to Reactor Pressure Vessel Cladding*, NUREG/CR-3671 (ORNL-6047), July 1984.

W. R. Corwin, R. G. Berggren, and R. K. Nanstad, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Charpy Toughness and Tensile Properties of a Neutron Irradiated Stainless Steel Submerged-Arc Weld Cladding Overlay*, NUREG/CR-3927 (ORNL/TM-9709), September 1984.

J. J. McGowan, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Tensile Properties of Irradiated Nuclear Grade Pressure Vessel Plate and Welds for the Fourth HSST Irradiation Series*, NUREG/CR-3978 (ORNL/TM-9516), January 1985.

J. J. McGowan, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Tensile Properties of Irradiated Nuclear Grade Pressure Vessel Welds for the Third HSST Irradiation Series*, NUREG/CR-4086 (ORNL/TM-9477), March 1985.

W. R. Corwin, G. C. Robinson, R. K. Nanstad, J. G. Merkle, R. G. Berggren, G. M. Goodwin, R. L. Swain, and T. D. Owings, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Effects of Stainless Steel Weld Overlay Cladding on the Structural Integrity of Flawed Steel Plates in Bending, Series 1*, NUREG/CR-4015 (ORNL/TM-9390), April 1985.

W. J. Stelzman, R. G. Berggren, and T. N. Jones, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *ORNL Characterization of Heavy-Section Steel Technology Program Plates 01, 02, and 03*, NUREG/CR-4092 (ORNL/TM-9491), April 1985.

G. D. Whitman, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Historical Summary of the Heavy-Section Steel Technology Program and Some Related Activities in Light-Water Reactor Pressure Vessel Safety Research*, NUREG/CR-4489 (ORNL-6259), March 1986.

R. H. Bryan, B. R. Bass, S. E. Bolt, J. W. Bryson, J. G. Merkle, R. K. Nanstad, and G. C. Robinson, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Test of 6-in.-Thick Pressure Vessels. Series 3: Intermediate Test Vessel V-8A - Tearing Behavior of Low Upper-Shelf Material*, NUREG/CR-4760 (ORNL-6187), May 1987.

D. B. Barker, R. Chona, W. L. Journey, and G. R. Irwin, University of Maryland, College Park, Md., *A Report on the Round Robin Program Conducted to Evaluate the Proposed ASTM Standard Test Method for Determining the Plane Strain Crack Arrest Fracture Toughness K_{Ic} of Ferritic Materials*, NUREG/CR-4966 (ORNL/Sub/79-7778/4), January 1988.

L. F. Miller, C. A. Baldwin, F. W. Stallman, and F. B. K. Kam, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Neutron Exposure Parameters for the Metallurgical Test Specimens in the Fifth Heavy-Section Steel Technology Irradiation Series Capsules*, NUREG/CR-5019 (ORNL/TM-10582), March 1988.

J. J. McCowan, R. K. Nanstad, and K. R. Thoms, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Characterization of Irradiated Current-Practice Welds and A533 Grade B Class 1 Plate for Nuclear Pressure Vessel Service*, NUREG/CR-4880 (ORNL-6484/V1 and V2), July 1988.

R. D. Cheverton, W. E. Pennell, G. C. Robinson, and R. K. Nanstad, Martin Marietta Energy Systems, Oak Ridge Natl. Lab., Oak Ridge, Tenn., *Impact of Radiation Embrittlement on Integrity of Pressure Vessel Supports for Two PWR Plants*, NUREG/CR-5320 (ORNL/TM-10966), February 1989.

RESULTS OF CRACK-ARREST TESTS ON TWO IRRADIATED HIGH-COPPER WELDS*

S. K. Iskander
W. R. Corwin
R. K. Nanstad

ABSTRACT

The objective of this study was to determine the effect of neutron irradiation on the shift and shape of the lower-bound curve to crack-arrest data. Two submerged-arc welds with copper contents of 0.23 and 0.31 wt % were commercially fabricated in 220-mm-thick plate. Crack-arrest specimens fabricated from these welds were irradiated at a nominal temperature of 288°C to an average fluence of 1.9×10^{19} neutrons/cm² (>1 MeV). Evaluation of the results shows that the neutron-irradiation-induced crack-arrest toughness temperature shift is about the same as the Charpy V-notch impact temperature shift at the 41-J energy level. The shape of the lower-bound curves (for the range of test temperatures covered) did not seem to have been altered by irradiation compared to those of the ASME K_{Ic} curve.

*Research sponsored by the Office of Nuclear Regulatory Research, Division of Engineering Safety, U.S. Nuclear Regulatory Commission under Interagency Agreement DOE 1886-8109-8L with the U.S. Department of Energy under contract DE-AC05-84OR21400 with Martin Marietta Energy Systems, Inc.

1. INTRODUCTION

In the fracture mechanics integrity analysis of reactor pressure vessels (RPVs), the initiation and arrest fracture toughness curves as described in Sect. XI of *ASME Boiler and Pressure Vessel Code* are often used. These curves are used also for the normal operation of RPVs. The effects of neutron irradiation on toughness are accounted for by shifting the curves upward in temperature without change in shape by an amount equal to the temperature shift of the Charpy V-notch (CVN) impact energy curve at the 41-J level (ΔTT_{41-J}). Such a procedure implies that the shifts in the fracture toughness curves are the same as that of the CVN ΔTT_{41-J} and that irradiation does not change the shapes of the fracture toughness curves.

It is well known that irradiation of some RPV ferritic steels to fluences on the order of 2×10^{19} neutrons/cm² (>1 MeV) can cause changes in the shape of the CVN impact energy curve. To determine whether similar changes in shape can occur in the fracture toughness curves, particularly if such changes could lead to non-conservative determinations of the irradiated fracture toughness, research programs are sponsored by the U.S. Nuclear Regulatory Commission (NRC) within the Heavy-Section Steel Irradiation (HSSI) Program at Oak Ridge National Laboratory (ORNL).

Two of these programs are the Fifth and Sixth Irradiation Series. The objective of the Fifth Series was to determine the effect of neutron irradiation on the shift and shape of the K_{Ic} vs $(T-RT_{NDT})$ curve, where K_{Ic} is the plane-strain fracture toughness, T is the temperature, and RT_{NDT} is the reference nil-ductility-transition temperature. Although the objective is similar, the Sixth Series investigates the effect on K_{Ia} , the plane-strain crack-arrest fracture toughness. Both programs investigate the effects of irradiation on the fracture toughness of welds, since some pressure vessels in operation have welds with copper contents and end-of-life fluences which make them susceptible to severe degradation in toughness. The amount of experimental data on the effects of irradiation on crack-arrest fracture toughness is rather meager (Refs. [1] and [2]).

Two submerged-arc welds with copper contents of 0.23 and 0.31 wt % were commercially fabricated in 220-mm-thick plate. In the Fifth Irradiation Series, irradiated CVN impact, tensile, drop-weight, and compact specimens, made from the weldment were tested and the results are given in Refs. [3] and [4].

Crack-arrest specimens fabricated from these welds were irradiated at a nominal temperature of 288°C to an average fluence of 1.9×10^{19} neutrons/cm² (>1 MeV). This report compares the results of crack-arrest tests on 36 irradiated weld-embrittled-type specimens with those from unirradiated control specimens. Since this is only the first phase of a two-phase program, the conclusions presented here are preliminary.

2. DESCRIPTION OF MATERIALS AND PROCEDURES

The weld wire for both programs was produced commercially in one melt. The melt was split to allow for copper additions and resulted in two weld wires that were comparable in chemical composition except for copper. Several meters of weldment were commercially fabricated from each weld wire and were designated 72W (0.23 wt % Cu) and 73W (0.31 wt % Cu). The welds were commercially fabricated in A 533, grade B, class 2 plate of 220-mm (8 5/8-in.) thickness by using the submerged-arc weld process with one lot of Linde 0124 flux. A macrograph of weld 72W is shown in Fig. 1, and the chemical compositions of both welds are given in Table 1. The welds were given a postweld heat treatment of 607°C for 40 h, typical of that given commercial RPVs.

Two capsules, each containing 30 compact crack-arrest specimens of the two weldments, have been irradiated at a nominal temperature of 288°C to a fluence of approximately 1.9×10^{19} neutrons/cm² (>1 MeV) in the Oak Ridge Research Reactor located at the ORNL. The irradiated specimen complement is given in Table 2, which gives the overall specimen dimensions. The complete nominal specimen dimensions are given in Fig. 2 and Table 3. For administrative purposes, the program was conducted in two phases. This report presents results of Phase 1 which consisted of crack-arrest tests on the 36 weld-embrittled-type specimens. In Phase 2, the results from remaining 24 duplex-type crack-arrest specimens will be reported.

2.1 Testing Procedures

Testing was performed according to the ASTM "Test for Determining Plane-Strain Crack-Arrest Fracture Toughness, K_{Ic} , of Ferritic Steels" (E 1221-88). Crack-arrest testing of the irradiated specimens was performed in a hot cell by using a servohydraulic machine and the test chamber shown schematically in Fig. 3, and photographically in Fig. 4. This equipment allows specimens to be tested with the split pins in either the so-called "normal" or "inverted" configuration at test temperatures ranging from -100 to 260°C.* In the "normal" configuration, the lateral surfaces of the specimen are in contact with the test-machine platen and friction decreases the crack-driving force somewhat compared with the "inverted" configuration in which the specimen sits on the narrow shoulders of the split pin. The "inverted" configuration is used at testing temperatures above NDT. For further information on the "normal" and "inverted" test configuration in crack-arrest testing, see Note 5 of ASTM E 1221-88.

*This temperature range was chosen during the design phase of the test chamber on the basis of the anticipated test temperature. The maximum temperature is limited by the Teflon™ insert in the contact thermocouple.

ORNL-PHOTO 4145-90




Fig. 1. Cross section of typical submerged-arc weld used in the 72W and 73W welds used in the Fifth and Sixth Irradiation Series.

ORNL-PHOTO 4145-90




FIG. 1. Cross section of typical submerged-arc weld used in the 72W and 73W welds used in the Fifth and Sixth Irradiation Series.

Table 1. Chemical composition of the two submerged-arc welds in the Fifth and Sixth Irradiation Series

Material	Composition (wt %)										
	C	Mn	P	S	Si	Cr	Ni	Mo	Cu	V	
72W	0.093	1.60	0.006	0.006	0.44	0.27	0.60	0.58	0.23	0.003	
73W	0.098	1.56	0.005	0.005	0.45	0.25	0.60	0.58	0.31	0.003	

Source: Values based on formula from R. K. Nanstad et al., "Effects of Irradiation on K_{Ic} curves for High-Copper Welds," pp. 214-33 in *Effects of Radiation on Materials, 14th International Symposium*, ASTM STP 1046, Vol. II, ed. N. H. Packan, R. E. Stoller, and A. S. Kumar, American Society for Testing and Materials, Philadelphia, 1990.

Table 2. Irradiated crack-arrest specimen complement for each of the 72W and 73W weldments

Specimen type	Dimensions (mm)	Quantity per weld
Weld embrittled	25 × 76 × 76	8
Weld embrittled	25 × 152 × 152	7
Weld embrittled	33 × 152 × 152	3
Duplex	33 × 152 × 152	12

ORNL-DWG 90-12074




Fig. 2. Nominal dimensions in millimeters of weld-embrittled crack-arrest specimens used in the Sixth Irradiation Series.

Table 3. Nominal dimensions of weld-embrittled crack-arrest specimens
used in the Sixth Irradiation Series
(All dimensions are in millimeters)

Nominal specimen size	W	a_0	a_0/W	B	w_t	2H	L	D	L'
72W and 73W weldments									
25 × 76 × 76	63.50	20.96	0.33	25.40	76.20	76.20	12.70	21.06	44.45
72W weldment									
25 × 152 × 152		43.82-44.45	0.345-0.350						84.46-85.09
33 × 152 × 152		43.82-45.09	0.345-0.355						83.82-85.09
73W weldment									
25 × 152 × 152	127.00	49.53	0.39	25.40	152.40	152.40	25.40	31.75	79.38
33 × 152 × 152	127.00	49.53	0.39	33.02	152.40	152.40	25.40	31.75	79.38

^aTo accommodate the crack-starter notch within the brittle weld, L' had to be adjusted. The values shown reflect the range for the a_0 , a_0/W , and L' dimensions. All other dimensions are the same for both the 72W and 73W weldments.

NOTE:

- a_0 - initial slot length.
- B - specimen thickness.
- D - split-pin hole diameter.
- 2H - specimen height.
- L, L' - see fig. 2.
- W - nominal width of crack-arrest specimen.
- w_t - total width of crack-arrest specimen.




Fig. 3. Schematic drawing of equipment used to perform crack-arrest testing of irradiated specimens before set-up in the hot-cell 500-kN testing machine.




Fig. 4. Photograph of equipment used to perform crack-arrest testing of irradiated specimens before set-up in the hot-cell 500-kN testing machine.

Figure 5 shows a closeup view of the environmental chamber used for temperature conditioning of the crack-arrest specimens after it was installed in the hot cell 500-kN tensile testing machine. Figure 6 gives a general view of the test system as it is being prepared for a crack-arrest test.

Temperature conditioning below ambient is obtained by venting cold nitrogen gas into the chamber containing the crack-arrest specimen. Above ambient, temperature control is achieved by means of six heater elements. Four of these elements are cartridge type and are embedded in the base of the fixture. Two U-shaped heater elements can be moved into place below or above the specimen. After the specimen is positioned in the fixture, a contact thermocouple is lowered onto the specimen surface near the midpoint of the crack path to measure the specimen temperature.

Considerable effort was made to ensure temperature uniformity and accuracy in each crack-arrest specimen. Specimens of A 533B steel and of the same three sizes as those to be tested were instrumented with thermocouples and thermally conditioned in the fixture over the relevant temperature range in both normal and inverted configurations. The uniformity and accuracy of the temperature throughout the specimen were within $\pm 1^\circ\text{C}$ when compared to the values measured by the contact thermocouple used during testing.

The clip gage used for the irradiated specimen tests was specially designed and fabricated at ORNL. Long clip-gage arms were incorporated in the design to measure the crack mouth opening displacement (CMOD) from outside the temperature conditioning chamber. The arms are instrumented with temperature-compensated electrical resistance strain gages. Moreover, tests outside the hot cell have shown that the clip-gage temperature is $< 35^\circ\text{C}$ when the specimen temperature* is 350°C . Since the maximum test temperature for this series of tests is under 150°C , the clip-gage is calibrated at room temperature with no significant loss in accuracy. The clip-gage was calibrated in the hot cell with a Boekler micrometer before and after every test since the CMOD (not the load) measured during the test is central to the determination of the crack-arrest toughness K_a . The error in K_a due to errors in the measurement of CMOD is estimated to be less than 2%.

An irradiated specimen to be tested is placed in the conditioning chamber, and special "knives" are used to center the specimen beneath the loading wedge. The sides of the loading wedge were covered with a replaceable strip of TeflonTM to reduce the friction between the wedge and the split pins. The testing machine ram was then raised until the loading wedge just touches the split pins (a load of about 40 N); then the ram is lowered until no-load is indicated. The centering "knives" were then removed since the proper position of the specimen is maintained by the inserted load wedge. The clip-gage is then seated in conical grooves of gage blocks welded (prior to irradiation) to the crack-arrest

*For the purposes of this test, thermocouples were tack-welded to the test specimen.




Fig. 5. Closeup view of the environmental chamber used for temperature conditioning of the crack-arrest specimens after installation in the hot-cell 500-kN tensile testing machine.



Fig. 6. General view of the test system as it is being prepared for a crack-arrest test.

specimen. The load vs CMOD is recorded on an X-Y plotter together with the clip-gage calibration marks; a typical chart from a test is shown in Fig. 7. The charts from all the irradiated tests are included in Appendix E. As mentioned above, the value of the load is not used in the calculation of K_a . However, the plot of load vs CMOD is indispensable in the conduct of the test and determination of the CMOD at various points in the loading-unloading cycles (see ASTM E 1221-88).

2.2 Analysis Procedures

The arrested crack front is marked by heat-tinting the specimen after testing. The specimen is then cooled with liquid nitrogen and broken open. The length of the remaining ligament for each specimen is obtained by measuring the position of the arrested crack front by using the averaging procedure prescribed in ASTM E 1221-88. In the case of irradiated specimens, a digitizing tablet was used to measure the length of the remaining ligament on a photograph taken through a Kollmorgen periscope of the broken specimen half. Typical fracture surfaces for two 33. x 152-mm specimens are shown in Fig. 8 (photographs of the fracture surfaces of all the specimens tested are given in Appendix E). Numerous unbroken ligaments, typical for pressure vessel steels at these test temperatures, can be observed on the fracture surface of the specimens. The known dimensions of the specimen serve as the scale for these measurements. In the case of the unirradiated specimens, the length of the remaining ligament is directly measured by a digital measuring microscope. The errors due to the measurement method are estimated to be less than those due to the shape of the crack front.

To estimate accuracy of the crack-arrest toughness, two values of the stress intensity factor (K_0 and K_a) are calculated. The former is the stress intensity factor at crack initiation, and the latter is the value shortly after arrest. Both values are calculated by substituting appropriate values in the following expressions given in ASTM E 1221-88:

$$K = E \delta f(x) \sqrt{B/(B_W W)} , \quad (1)$$

where $f(x)$ = crack-arrest specimen calibration function defined as follows:

$$f(x) = \frac{2.24 (1.72 + 0.9x + x^2) \sqrt{1+x}}{(9.85 + 0.17x + 11x^2)} , \quad (2)$$

and

$$x = a/W,$$

E = Young's modulus,

a = initial slot length a_0 or arrested (final) crack length a_a ,

W = specimen width,

B = specimen thickness,




Fig. 7. Chart produced on an X-Y plotter during a typical crack-arrest test of an irradiated specimen.




Fig. 8. Photograph taken through a Kollmorgen periscope of the fracture surfaces of two typical crack-arrest specimens after heat-tinting and splitting them open. The 2- or 3-mm, darker, transverse strips near the initial crack front are the brittle crack-starter weld beads.

B_N = specimen thickness at crack plane,

δ = CMOD.

If all other values are unchanged the error in K is directly proportional to the error in δ (given above). The error in K due to errors in crack length is estimated as described below.

In Eq. (1), if all other values are constant, the error in K is equal to that of $f(x)$ due to the error in the fractional crack length x . Table 4 shows various estimates of the errors in $f(x)$ resulting from the measurement of the initial slot length a_0 and arrested crack length a_a and for the various specimen sizes. A plot of $f(x)$ vs fractional crack length x , shown in Fig. 9, is nearly linear in x . However, because $f(x)$ decreases as x increases, the absolute value of the average relative error in $f(x)$ increases as x increases. The average relative error is defined as:

$$\eta = \frac{f[(1+\epsilon)x] - f[(1-\epsilon)x]}{f(x)}$$

Two relevant values of x are 0.33 for the initial slot length and 0.85 for the final crack length. The former is the minimum value for the crack-arrest specimens manufactured for the Sixth Series program, and the latter is the maximum valid value allowed by ASTM E 1221-88. A $\pm 1\%$ change for $x = 0.33$ results in a $\mp 0.5\%$ change in $f(x)$, while the same $\pm 1\%$ change for $x = 0.85$ results in an approximate $\mp 3\%$ change in $f(x)$.

The determination of a_0 is performed with a digital measuring microscope, and the error is estimated to $\epsilon < 0.2$ mm, irrespective of the specimen size. Hence the maximum error in $f(x)$ (and K_0) for the initial slot length is $\pm 0.5\%$ for a small specimen and even less for a large specimen. In both cases, the initial slot length is used to estimate K_0 , which gives an estimate of K at the onset of rapid fracture. It is an estimate at best because the crack at initiation is not a sharp one and has a finite root radius. Moreover, K_0 is of interest to the experimenter only.

As mentioned, the measurement of the final crack length a_a is performed according to ASTM E 1221-88 by an averaging procedure. Since it is rare that the arrested crack front is square or straight (Fig. 8), it is difficult to estimate the error in such a determination. From the expression for K_a given in ASTM E 1221-88, estimates of the error were made by using different values of the arrested crack length to obtain bounds on the error. A maximum value of a_a is 54 mm for a small 25 \times 76 mm specimen since this is the maximum length permitted in E 1221-88 for this specimen size. Errors of ± 1 or ± 2 mm in a_a for this case result in errors of $\mp 6.5\%$ or $\mp 13\%$, respectively, in K_a . A similar procedure was followed for the large (33 \times 152 \times 152 mm) specimen. The error estimates are summarized in Table 4. The total maximum error in K_a from all sources is estimated to be approximately $\pm 10\%$ for the small specimens and $\pm 5\%$ for the large ones.

Table 4. Estimate of the average relative error^a in $f(x)$ (and thus in K_a) due to errors in the determination of initial and final crack lengths $x = a_o/W = 0.33$ and $x = a_s/W = 0.85$, respectively, for the various specimen sizes

Specimen size ^b	Initial crack length a_o					Final crack length a_s				
	W (mm)	Errors in				a_s (mm)	Errors in			
		a_o (mm)	a_o (mm)	a_o/W (%)	$f(x)$ (%)		a_s (mm)	a_s (mm)	a_s/W (%)	$f(x)$ (%)
Small	63.5	21	0.2	±1	±0.5	54	±1 ±2	±2 ±4	±2 ±4	±6.5 ±13
Large	127	44	0.2	±0.5	±0.2	108	±1 ±2	±1 ±2	±1 ±2	±3 ±6.5

^aDefined as $\frac{1}{2} \{f[(1+e) \cdot x] - f[(1-e) \cdot x]\}/f(x)$.

^bThe 25 × 76 × 76 mm specimens are the small specimens, while the 25 (or 33) × 152 × 152 mm ones are the large ones.

NOTE:

- a_s - arrested crack length.
- a_o - initial slot length.
- $f(x)$ - crack-arrest specimen specimen calibration function.
- k_a - value of stress intensity factor shortly after arrest.
- W - width.




Fig. 9. Calibration function for crack arrest specimens as given in ASTM E 1221-88.

3. RESULTS AND DISCUSSION

The temperature control for the two irradiation capsules, each containing 30 specimens, was excellent. The temperature most of both weld-embrittled and duplex-type specimens (22 in one capsule and 23 in the other) ranged from 286 to 290°C, while the few remaining specimens were irradiated at temperatures ranging from 280 to 286°C. The average irradiation temperature of the weld-embrittled-type crack-arrest specimens is 286 and 285°C for the 72W and 73W specimens, respectively. For both 72W and 73W specimens, the fluences to which the weld-embrittled-type crack-arrest specimens were irradiated ranged from approximately 1.4 to 2.4×10^{19} neutrons/cm² (>1 MeV), and the average fluence and standard deviation is approximately 1.9 and 0.3×10^{19} neutrons/cm² (>1 MeV), respectively. Bar charts showing the distribution of fluence of the specimens successfully tested, 18 and 17 from the 72W and 73W weldments, respectively, are given in Figs. 10 and 11, respectively. The average irradiation temperature and the exposure values of each specimen are given later in this report. A summary of the irradiation data for the weld-embrittled specimens tested in Phase 1 is given in Table 5. Detailed reports on the dosimetry and operating history of the two capsules will be published separately.

The yield strength and Young's modulus of the test material are required in crack-arrest testing. Young's modulus is calculated from the following expression, from Ref. [5]: $E = 207.2 + 0.0571T$, where E = Young's modulus in GPa, and T = temperature in °C (discussed also in Appendix C). The unirradiated and irradiated tensile strengths have been reproduced from Ref. [3] in Figs. 12 and 13 for welds 72W and 73W, respectively. The average fluence of the tensile samples, approximately 1.6×10^{19} neutrons/cm² (>1 MeV), is about 15% less than that for the crack-arrest specimens. This difference will not affect the values of the crack-arrest toughnesses K_a but could have a small effect on the validity of each specimen as it is prescribed in ASTM E 1221-88. The observations in this report are preliminary.

The RT_{NDT} values for both weldments in the unirradiated and irradiated conditions are given in Table 6 (from Refs. [3] and [4]). The initial RT_{NDT} values were determined in accordance with Subarticle NB-2330 of ASME Boiler and Pressure Vessel Code, Sect. III, and are the same as the drop-weight NDT values. The "adjusted" RT_{NDT} values were determined according to paragraph 10.2.2 of ASTM E 185-82 by adding the CVN ΔTT_{41-J} values to the initial RT_{NDT} values. The CVN ΔTT_{41-J} shifts have been determined from a relatively large number of specimens, as shown in Fig. 14 (also from Refs. [3] and [4]). Approximately 84 and 56 unirradiated and irradiated CVN specimens were tested from each of the 72W and 73W welds respectively. The average fluence of CVN-impact energy specimens for both the 72W and 73W weldments is 1.51×10^{19} neutrons/cm²,

ORNL-DWG 90-11095




Fig. 10. Distribution of fluence in the 18 irradiated weld-embrittled-type crack specimens tested from the 72W weld.




Fig. 11. Distribution of fluence in the 17 irradiated crack specimens of the 73W weld that were tested successfully.

Table 5. Summary of the irradiation temperature and fluence for Series 72W and 73W crack-arrest specimens

	72W (18 specimens)		73W (17 specimens)	
	Temperature (°C)	Fluence ^a	Temperature (°C)	Fluence ^a
Mean	286	1.88	285	1.93
Standard Deviation	3	0.30	3	0.32
Minimum	281	1.42	280	1.46
Maximum	289	2.34	289	2.39

^aIn units of 10^{19} neutrons/cm² (>1 MeV).

ORNL-DWG 90-15463




Fig. 12. Yield and ultimate strengths vs test temperature for weld 72W (a) unirradiated and (b) irradiated at a nominal temperature of 288°C to 1.57×10^{12} neutrons/cm² (>1 MeV).




Fig. 13. Yield and ultimate strengths vs test temperature for weld 73W (a) unirradiated and (b) irradiated at a nominal temperature of 288°C to 1.56×10^{19} neutrons/cm² (>1 MeV).

Table 6. Initial, adjusted, and normalized reference temperatures (RT_{NDT})
for the 72W and 73W weldments

Initial RT_{NDT} (°C)	Charpy impact ^a observed results		RT_{NDT} (°C)	Crack-arrest normalized results		Normalized ^b RT_{NDT} (°C)	
	F (10^{19} n/cm ²) (>1 MeV)	ΔTT_{41-J} (K)		F' (10^{19} n/cm ²) (>1 MeV)	ΔTT_{41-J} (K)		
72W	-23	1.51	72	49	1.88	80	57
73W	-34	1.51	82	48	1.93	93	59


^aSource: Data from R. K. Nanstad et al., "Effects of Irradiation on K_I curves for High-Copper Welds," pp. 214-33 in *Effects of Radiation on Materials, 14th International Symposium*, ASTM STP 1046, Vol. II, ed. N. H. Packan, R. E. Stoller, and A. S. Kumar, American Society for Testing and Materials, Philadelphia, 1990.

^bNormalization: $(\Delta TT_{41-J})(F'/F)^{0.5}$. Source: Adopted with permission from G. R. Odette and G. E. Lucas, "Irradiation Embrittlement of Reactor Pressure Vessel Steels: Mechanisms, Models, and Data Correlations," pp. 206-41 in *Radiation Embrittlement of Nuclear Pressure Vessel Steels: An International Review (Second Volume)*, ASTM STP 909, ed. L. E. Steel, American Society for Testing and Materials, Philadelphia.

NOTE:

- F = fluence for Charpy V-notch impact specimens.
- F' = fluence for crack-arrest specimens.
- n = neutrons.
- ΔTT_{41-J} = shift in 41-J Charpy V-notch impact energy level.

ORNL-DWG 89C-19510



(a)




Fig. 14. Charpy V-notch-impact energy vs test temperature for welds 72W and 73W (a) unirradiated (b) irradiated at a nominal temperature of 288°C to $1.51 \times 10^{19} \text{n/cm}^2 (>1\text{MeV})$.

while that for the crack-arrest specimens is approximately 1.9×10^{10} neutrons/cm². To normalize the RT_{NDT} shift, an average trend curve applicable to the behavior of test reactor data and having a slope of 0.5 was used (Ref. [6]). It is of the form:

$$\text{Normalized } \Delta T_{41-J} = (\Delta T_{41-J})(\phi'/\phi)^{0.5},$$

where ϕ' and ϕ are the average fluences for the crack-arrest and the CVN-impact specimens, respectively, in neutrons per square centimeter (>1 MeV). Both shifts for each weldment are given in Table 6. The normalized RT_{NDT} values were used to shift the ASME K_{Ia} curves shown later in this report.

Tables 7 and 8 give the results of testing the unirradiated crack-arrest specimens of the 72W and 73W Series, respectively, and Tables 9 and 10 give data for the irradiated specimens of these two series. These tables also give for each specimen the irradiation temperature and the exposure value [fluence for energies > 1 MeV and > 0.1 MeV as well as displacements per atom (dpa)]. The K_a values have not been normalized to a single average fluence to account for the variation of fluence from one specimen to another.

In testing of one specimen, A73W17 (listed in Table 10), the crack failed to initiate in a cleavage mode and exhibited tearing. It was retested at 30°C, but the crack did not arrest, and the specimen broke. The K_a value from specimen A73W37 (tested at -25°C) is recognized as too low because the arrested crack length a_a is 96% of the nominal specimen width W. The expression in ASTM E 1221-88 used to calculate K_a is limited to $a_a/W \leq 0.85$. While other specimens may be slightly invalid and hence may or may not necessarily represent plane-strain behavior, the authors believe this specimen to be so far beyond the validity limits as to be clearly nonrepresentative of plane-strain crack-arrest toughness of the weld. Hence, its position below the ASME K_{Ia} curve is of no significance. In general, even though some of the other individual specimens may not strictly meet all of the ASTM validity criteria, the authors believe the data to be representative of the arrest toughness that would exist within a thick-walled RPV.

The task group responsible for crack-arrest test procedure ASTM E 1221-88 recognized the need for the data to represent plain-strain conditions. Conservative validity criteria were selected on the basis of existing analytical and experimental results (Ref. [7]) to ensure that specimens meeting those criteria would indeed be representative of plane-strain conditions. Even at the time ASTM E 1221-88 was written, however, it was recognized that those criteria might be overly restrictive; they were, nonetheless, chosen to be used until more evidence justifying their relaxation could be amassed. More data are now available; for example, Ref. [8] shows crack-arrest test results clearly violating the size criteria of ASTM E 1221-88, that still accurately predict the arrest behavior of a thick-walled pressure vessel under simulated pressurized-thermal-shock loading. On the bases of these and other considerations, the ASTM task group will be asked to reconsider relaxation of the validity criteria.

Table 7. Unirradiated crack-arrest toughness data obtained from testing weldment 72W
 $(RT_{NDT} = -23^{\circ}\text{C})$

Specimen	Test temperature ($^{\circ}\text{C}$)	K_a ($\text{MPa} \cdot \sqrt{\text{m}}$)	Validity ^a
Weld-embrittled $25 \times 76 \times 76$ mm specimens			
A72W37	-61	66	
A72W35	-60	53	
A72W38	-59	57	
A72W36	-47	71	
A72W34	-45	73	
A72W24	-30	61	
A72W28	-30	60	
A72W25	-30	79	B
A72W31	-15	108	B, E
Weld-embrittled $25 \times 152 \times 152$ mm specimens			
A72W44	-60	76	
A72W39	-60	45	A
A72W20	-47	67	
A72W41	-45	74	
A72W46	-45	92	
A72W43	-32	92	
A72W08	-30	104	
A72W05	-30	107	
A72W48	-30	98	
A72W01	-16	97	
A72W03	-14	128	C
Weld-embrittled $33 \times 152 \times 152$ mm specimens			
A72W45	-45	76	
A72W47	-30	91	
A72W07	-15	103	
A72W04	-15	54	
A72W19	-15	94	
A72W02	0	93	
A72W12	0	114	
A72W40	0	114	B

Table 7. (continued)

Specimen	Test temperature (°C)	K _a (MPa·√m)	Validity ^a
Duplex 33 × 152 × 152 mm specimens			
A72W71	-14	91	
A72W66	-2	103	
A72W63	-1	125	
A72W64	1	108	
A72W65	4	125	
A72W68	5	115	
A72W73	5	142	C,D
A72W62	10	136	B,C
A72W57	21	146	C,D
Weld-embrittled 51 × 203 × 203 mm specimens			
A72W83	-30	85	
A72W85	-15	95	
A72W84	0	107	

^aOne or more letters for a specimen indicate that the results did not meet one of the minimum lengths of the ASTM E 1221-88 validity criteria. The letters correspond to those in Table 2 of ASTM E 1221-88, which can be paraphrased as:

- A,B = unbroken ligament too short.
- C = specimen too thin.
- D,E = insufficient crack-jump length.

NOTE:

- K_a = value of stress intensity factor shortly after arrest.
- RT_{NDT} = reference nil-ductility-transition temperature.

Table 8. Unirradiated crack-arrest toughness data obtained from testing weldment 73W
($RT_{NDT} = -34^\circ\text{C}$)

Specimen	Test temperature ($^\circ\text{C}$)	K_a ($\text{MPa}\cdot\sqrt{\text{m}}$)	Validity ^a
Weld-embrittled $25 \times 76 \times 76$ mm specimens			
A73W38	-62	50	A
A73W42	-60	58	
A73W32	-59	56	A
A73W36	-59	72	
A73W01	-45	52	
A73W02	-45	75	
A73W03	-45	64	A, B
A73W06	-35	83	B
A73W04	-30	67	
A73W05	-30	70	A, B
Weld-embrittled $25 \times 152 \times 152$ mm specimens			
A73W28	-61	69	
A73W43	-45	73	
A73W47	-45	85	
A73W30	-44	71	
A73W11	-32	85	
A73W48	-31	75	
A73W50	-30	80	
A73W16	-29	89	
A73W52	-29	77	
A73W20	-16	126	C
A73W25	-15	141	B, C
Weld-embrittled $33 \times 152 \times 152$ mm specimens			
A73W29	-30	100	
A73W10	-16	77	A
A73W22	-16	110	
A73W46	-15	124	
A73W44	-15	123	
A73W49	-15	117	
A73W24	-13	89	A, B
A73W27	-12	111	

Table 8. (continued)

Specimen	Test temperature (°C)	K _a (MPa·√m)	Validity ^a
Duplex 33 × 152 × 152 mm specimens			
A73W86	-5	101	
A73W07	5	129	B
A73W08	5	119	
A73W09	5	112	
A73W85	5	137	C,D
A73W87	5	113	
A73W88	15	132	
Duplex 51 × 203 × 203 mm specimen			
A73W75	5	107	

^aOne or more letters for a specimen indicate that the test results did not meet one of the minimum lengths of the ASTM E 1221-88 validity criteria. The letters correspond to those in Table 2 of ASTM E 1221-88, which can be paraphrased as:

- A,B = unbroken ligament too short.
- C = specimen too thin.
- D,E = insufficient crack-jump length.

NOTE:

- K_a = value of stress intensity factor shortly after arrest.
- RT_{NDT} = reference nil-ductility-transition temperature.

Table 9. Irradiated crack-arrest toughness data for the weld-embrittled type specimens from weldment 72W (normalized RT_{NDT} = 57°C). The average fluence and irradiation temperatures were 1.88×10^{19} neutrons/cm² (>1 MeV) and 286°C, respectively

Specimen	Test temperature (°C)	K _a (MPa·√m)	Irradiation temperature (°C)	Exposure values		Displacements per atom	Validity ^a
				Fluences (>1 MeV) (neutrons/cm ²)	Fluences (>0.1 MeV) (neutrons/cm ²)		
25 × 76 × 76 mm specimens							
A72W26	-25	38	285	2.01E+19	1.24E+20	0.0470	
A72W30	-25	43	283	2.04E+19	1.26E+20	0.0478	
A72W27	29	61	283	2.06E+19	1.28E+20	0.0483	
A72W21	30	53	281	2.34E+19	1.41E+20	0.0538	
A72W32	32	66	285	2.31E+19	1.39E+20	0.0530	D
A72W22	60	62	284	2.03E+19	1.26E+20	0.0475	A
A72W23	60	74	282	2.32E+19	1.39E+20	0.0532	D
A72W29	60	70	286	2.33E+19	1.41E+20	0.0536	
25 × 152 × 152 mm specimens							
A72W13	60	81	287	1.68E+19	1.11E+20	0.0415	
A72W10	75	101	289	1.64E+19	1.12E+20	0.0410	
A72W11	75	133	286	1.52E+19	1.01E+20	0.0376	
A72W15	75	114	289	1.54E+19	1.03E+20	0.0379	
A72W16	76	102	289	1.53E+19	1.02E+20	0.0377	
A72W06	90	160	289	1.65E+19	1.13E+20	0.0413	C,D
A72W18	90	132	287	1.42E+19	9.21E+19	0.0345	
33 × 152 × 152 mm specimens							
A72W09	90	120	289	1.67E+19	1.14E+20	0.0418	
A72W14	100	144	289	1.85E+19	1.26E+20	0.0462	
A72W17	100	118	289	1.85E+19	1.26E+20	0.0463	

^aOne or more letters for a specimen indicate that the test results did not meet one of the minimum lengths of the ASTM E 1221-88 validity criteria. The letters correspond to those in Table 2 of ASTM E 1221-88, which can be paraphrased as:

- A,B - unbroken ligament too short.
- C - specimen too thin.
- D,E - insufficient crack-jump length.

NOTE:

- K_a - value of stress intensity factor shortly after arrest.
- RT_{NDT} - reference nil-ductility-transition temperature.

Table 10. Irradiated crack-arrest toughness data for the weld-embrittled type specimens from weldment 73W (normalized RT_{NDT} = 59°C). The average fluence and irradiation temperatures were 1.93×10^{19} neutrons/cm² (>1 MeV) and 285°C, respectively

Specimen	Test temperature (°C)	K_a (MPa· \sqrt{m})	Irradiation temperature (°C)	Exposure values		Displacements per atom	Validity ^a
				Fluences (>1 MeV) (neutrons/cm ²)	Fluences (>0.1 MeV) (neutrons/cm ²)		
25 × 76 × 76 mm specimens							
A73W37 ^b	-25	29	280	2.38E+19	1.44E+20	0.0548	A
A73W39	-25	41	282	2.13E+19	1.31E+20	0.0497	
A73W31	29	57	283	2.10E+19	1.29E+20	0.0490	D
A73W34	29	60	283	2.08E+19	1.28E+20	0.0484	D
A73W35	29	67	283	2.37E+19	1.42E+20	0.0544	D
A73W33	60	74	282	2.39E+19	1.44E+20	0.0550	D
A73W40	60	81	280	2.36E+19	1.42E+20	0.0542	D
A73W41	60	79	284	2.11E+19	1.30E+20	0.0492	D
25 × 152 × 152 mm specimens							
A73W15	60	81	289	1.68E+19	1.15E+20	0.0421	
A73W13	75	150	289	1.69E+19	1.16E+20	0.0424	C,D
A73W18	75	131	287	1.56E+19	1.04E+20	0.0385	
A73W21	75	107	289	1.73E+19	1.14E+20	0.0426	
A73W26	75	88	288	1.58E+19	1.05E+20	0.0387	
A73W23	90	180	288	1.58E+19	1.05E+20	0.0389	B,C
A73W45	90	114	287	1.46E+19	9.45E+19	0.0354	
33 × 152 × 152 mm specimens							
A73W14	90	159	289	1.71E+19	1.17E+20	0.0429	B,C
A73W17 ^c	100		289	1.90E+19	1.29E+20	0.0474	
A73W51	100	184	289	1.90E+19	1.30E+20	0.0475	B,C

^aOne or more letters for a specimen indicate that the test results did not meet one of the minimum lengths of the ASTM E 1221-88 validity criteria. The letters correspond to those in Table 2 of ASTM E 1221-88, which can be paraphrased as:

A,B - unbroken ligament too short.

C - specimen too thin.

D,E - insufficient crack-jump length.

^bValue of K_a is unrealistically low because remaining ligament is too small.

^cSpecimen exhibited tearing behavior when tested at this temperature, then broke without arresting when retested at 30°C.

NOTE:

K_a - value of stress intensity factor shortly after arrest.

RT_{NDT} - reference nil-ductility-transition temperature.

In Tables 7 through 10, the results of the crack-arrest tests that were "invalid" relative to the requirements of ASTM E 1221-88 are indicated by one or more letters, a blank implying a "valid" result. To judge the degree of "invalidity," see the detailed results given in Appendix A.

The crack-arrest toughnesses, K_a , as a function of test temperature for the different materials, specimen sizes, and specimen types are plotted in Figs. 15 through 18. Comparisons of the unirradiated and irradiated crack-arrest toughnesses for each of the 72W and 73W welds are shown in Figs. 19 and 20, respectively. These figures also show the unirradiated and irradiated ASME K_{Ia} curves for each weldment indexed to their respective RT_{NDT} values. In the plots showing the results of the irradiated crack-arrest testing for weldment 73W, the data point at -25°C below the ASME K_{Ia} curve is that of specimen A73W37, described above.

Lower-bound curves to the test results have been plotted as dotted curves in Figs. 19 through 21. The dotted curves are ASME curves that have been shifted downward in temperature until the first data point is encountered. The amount of the shift is shown for both the unirradiated and irradiated conditions. In the case of 72W, the temperature shift downward from the normalized curve for the irradiated specimens is 8 K smaller than that for unirradiated specimens. For the 73W specimens, however, the opposite is obtained; the downward shift for the irradiated specimens results is 11 K greater than that for the unirradiated specimens. With all the uncertainties involved, the differences between the downward shifts are not deemed to be significant. Thus, the preliminary observation is that the shift in K_a due to irradiation is about the same as the shift in the CVN-impact energy at the 41-J energy level, as can be judged by the dotted curves in Figs. 19 and 20.

All the crack-arrest toughnesses, both unirradiated and irradiated, for both welds have been plotted as a function of $T-RT_{NDT}$ in Fig. 21. The irradiated specimen A73W17 described above (whose remaining ligament was too small to yield an accurate result) is not included in this figure. Figure 21 includes a total of 77 unirradiated and 34 irradiated data points, many of which overlap. This figure indicates that the results form a reasonable trend when indexed to RT_{NDT} . The normalized RT_{NDT} s (Table 6) have been used to index the irradiated data. When shifted by the normalized CVN ΔTT_{41-J} , the ASME curve is a conservative estimate of the irradiated crack-arrest toughness of the 72W and 73W weldments in the transition region to approximately 40 K above RT_{NDT} . At temperatures below RT_{NDT} , there seems to be a smaller K_{Ia} margin between the lower-bound curves and the ASME K_{Ia} curves.

The shape of the lower-bound curves shown dotted in Figs. 19 and 20 for the data obtained in Phase 1 of the Sixth Irradiation Series do not seem to have been altered by irradiation. The CVN-impact energy curve for both welds, especially for 73W, changed shape when irradiated to a

ORNL-DWG 90-15043




Fig. 15. Detailed crack-arrest toughness K_a vs test temperature for the unirradiated 72W weld showing the different specimen sizes and types used.

ORNL-DWG 90-15044




Fig. 16. Detailed crack-arrest toughness K_a vs test temperature for the unirradiated 73W weld showing the different specimen sizes and types used.




Fig. 17. Detailed crack-arrest toughness K_a vs test temperature for the irradiated 72W weld showing the different specimen sizes and types used.




Fig. 18. Detailed crack-arrest toughness K_a vs test temperature for the irradiated 73W weld showing the different specimen sizes and types used.




Fig. 19. Unirradiated and irradiated crack-arrest toughness K_a vs test temperature for the 72W weld.




Fig. 20. Unirradiated and irradiated crack-arrest toughness K_a vs test temperature for the 73W weld.




Fig. 21. All crack-arrest toughness K_a data for welds 72W and 73W plotted as a function of $(T - RT_{NDT})$.

fluence level of 1.51×10^{19} neutrons/cm² (>1 MeV), (see Ref. [3] and Fig. 14) Many empirical correlations exist between the CVN-impact energy and fracture toughness of unirradiated ferritic steels (Ref. [9]). If such a relationship also exists for irradiated ferritic steels and if the irradiated CVN curve changes shape, then the irradiated fracture toughness curve may also change shape correspondingly. One of the objectives of the Fifth and Sixth Irradiation Series research programs is to investigate whether irradiation can induce such a shape change in the toughness curves. Indeed, such a change has been observed in the lower-bound curve to the irradiated initiation toughness K_{Ic} data for the 73W weldment. Although no such change in shape has been observed in the K_a data obtained in tests to approximately 40 K above RT_{NDT} , further tests at higher temperatures are needed to ascertain whether a similar change in shape occurs in the arrest toughness curve. Moreover, statistical analyses of all the results will be performed to examine that question.

Successful cleavage crack initiation occurred in 35 of the 36 specimens tested. Such a success rate is unusual even for testing unirradiated specimens. Moreover, successful unstable crack initiation occurred in weld-embrittled-type specimens at test temperatures 40 K above NDT. A test temperature of approximately 20 K above NDT is generally considered to be the upper limit for a successful unstable crack to initiate in unirradiated weld-embrittled-type crack-arrest specimens for the steels and specimen thicknesses used here. It is likely that the radiation-induced increases in strength of the test material and the brittle-weld crack-starter material allows for a higher crack-driving force to enable testing at higher temperatures.

4. COMPARISON WITH OTHER DATA

Reference [2], which describes an Electric Power Research Institute (EPRI) project, contains almost all the published data on the effect of irradiation on crack-arrest toughness. Four steels were tested in the EPRI project: two welds and two plate materials. Both the plates and the welds included a low-copper as well as a high-copper steel. The total number of irradiated data points from all materials is 34. The results of the irradiated crack-arrest toughness tests were compared with the unirradiated data by shifting the irradiated data downward in temperature to achieve an approximate data coincidence. The EPRI downward shift is approximately comparable to the lower-bound shift that we used (obtained by shifting the ASME K_{Ic} curve downwards in temperature until the first data point was encountered). The EPRI shift in K_{Ic} due to irradiation for high-copper materials is less than ΔTT_{41-J} , whereas the shift in K_{Ic} for the low-copper materials is slightly greater or equal to ΔTT_{41-J} (in the EPRI program, the CVN shifts were also evaluated in several other ways). A similar trend is obtained in this study, although the range of copper contents is quite different. In the EPRI program, the copper contents ranged from approximately 0.03 to 0.23 % by weight. In our study, the copper contents for the two materials were 0.23 and 0.31% and the normalized ΔTT_{41-J} values were 80 and 93 K, the shifts of the lower-bound K_a curves were 88 and 82 K for the 72W and 73W welds respectively. We also increased the maximum values of irradiated crack-arrest toughness obtained when compared with those of the EPRI program from approximately 130 to 185 MPa· \sqrt{m} . Irradiated crack-arrest toughness data for both welds in our study were also obtained at higher temperatures with respect to the normalized adjusted RT_{NDT} (up to 40 K above RT_{NDT}) than were the EPRI data for the high-copper weld (up to approximately the adjusted RT_{NDT}).

5. SUMMARY

Crack-arrest testing of high-copper, submerged-arc welds was performed on unirradiated and irradiated weld-embrittled-type specimens 25- and 33-mm thick. Most of the crack-arrest test results are either valid or only marginally invalid according to ASTM E 1221-88. The 35 data points obtained by testing the irradiated crack-arrest specimens have approximately doubled the known data base of irradiated crack-arrest toughness and extended the data base coverage to higher levels of crack-arrest toughness and temperature relative to RT_{NDT} . Preliminary observations are:

1. Values of irradiated crack-arrest toughness K_{Ia} were obtained at temperatures 40 K above the irradiated RT_{NDT} of the welds. This accomplishment is experimentally significant because a temperature of 20 K above RT_{NDT} is generally considered to be the limit for obtaining useful results with the unirradiated weld-embrittled type of crack-arrest specimen.
2. The shifts of the lower-bound K_a curves for the 72W and 73W welds are approximately the same as the corresponding 41-J CVN-impact energy level shifts.
3. The ASME K_{Ia} curve, when shifted by ΔTT_{41-J} , is a conservative estimate of the irradiated crack-arrest toughness for welds 72W and 73W in the transition region 40 K above RT_{NDT} . At temperatures below RT_{NDT} , a smaller margin of toughness is apparent between the lower-bound curves and the ASME K_{Ia} curves.
4. The shape of the lower-bound curves compared to those of the ASME K_{Ia} curves were apparently unaltered by irradiation for the temperature range covered by the tests.

6. ACKNOWLEDGMENTS

In a project of this magnitude, it is difficult to acknowledge the contribution of the large number of individuals involved. The following individuals not only contributed to the various tasks mentioned but also made many useful suggestions. The authors acknowledge Eric T. Manneschmidt, J. Hoyt Mason, Jr., and John J. Henry, Jr., for testing; Thomas D. Owings for specimen fabrication and test fixture assembly and shakedown; Ronald L. Swain and David Thomas for assistance with equipment; Lloyd Turner for coordination of activities in the hot cell; Kenneth W. Boling for the original design and Bill H. Grubb for modifications of the test fixture during shakedown and for the design and manufacture of a jig for transporting irradiated specimens; Holly Neu and Donna Balltrip for manuscript preparation; and David J. Alexander and Roger E. Stoller for their helpful reviews. The authors would like to acknowledge the support and encouragement of Milton Vagins during the initial phases of this project.

The authors also acknowledge Frank B. Kam for dosimetry and Ken R. Thoms and Bill H. Montgomery for capsule design and operation respectively.

The authors are also grateful for the financial support and encouragement from the Nuclear Regulatory Commission (NRC) and Alfred Taboada, the current NRC technical monitor.

REFERENCES

1. C. W. Marschall and A. R. Rosenfield, "Crack-Arrest Tests of Irradiated High-Copper ASTM A508 Submerged-Arc Weld Metal," pp. 2467-75 in *International Conference on Fracture, Advances in Fracture Research*, Vol. 5, April 1981.*
2. T. R. Mager and C. W. Marschall, Electric Power Research Institute, Palo Alto, Calif., *Development of Crack Arrest Toughness Data Bank for Irradiated Reactor Pressure Vessel Materials*, EPRI NP-3616, July 1984.
3. R. K. Nanstad et al., "Effects of Irradiation on K_{Ic} Curves for High-Copper Welds," pp. 214-33 in *Effects on Radiation on Materials, 14th International Symposium*, ASTM STP 1046, Vol. II, ed. N. H. Packan, R. E. Stoller, and A. S. Kumar, American Society for Testing and Materials, Philadelphia, 1990.
4. R. K. Nanstad, F. M. Haggag, and S. K. Iskander, "Radiation-Induced Temperature Shift of the ASME K_{Ic} Curve," pp. 143-48 in *Transactions of the 10th International Conference on Structural Mechanics in Reactor Technology (SMIRT)*, Vol. S, ed. H. Hadgjian, Anaheim, Calif., August 1989.*
5. W. L. Server, J. W. Scheckherd, and R. A. Wullaert, Electric Power Research Institute, Palo Alto, Calif., *Fracture Toughness Data for Ferritic Nuclear Pressure Vessel Materials*, EPRI NP-119, April 1976.
6. G. R. Odette and G. E. Lucas, "Irradiation Embrittlement of Reactor Pressure Vessel Steels: Mechanisms, Models, and Data Correlations," pp. 206-41 in *Radiation Embrittlement of Nuclear Pressure Vessel Steels: An International Review Second Volume*, ASTM STP 909, ed. L. E. Steel, American Society for Testing and Materials, Philadelphia, 1986.
7. D. B. Barker et al., Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., *A Report on the Round Robin Program Conducted To Evaluate the Proposed ASTM Standard Test Method for Determining the Plane-Strain Crack-Arrest Fracture Toughness, K_{Ia} , of Ferritic Materials*, USNRC Report NUREG/CR-4996 (ORNL/Sub/79-7778/4), January 1988.†
8. R. H. Bryan et al., Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., Oak Ridge, Tenn., "Pressurized-Thermal-Shock Test of 6-in.-Thick Pressure Vessels. PTSE-2: Investigation of Low Tearing Resistance and Warm Prestressing," USNRC Report NUREG/CR-4888 (ORNL-6377), December 1987.†

9. S. T. Rolfe and J. M. Barson, Chap. 6 in *Fracture and Fatigue Control in Structures*, Prentice-Hall, Englewood Cliffs, N.J., 1977.

*Available in public technical libraries.

†Available for purchase from National Technical Information Service, Springfield, VA 22161.

APPENDIX A
DETAILED CRACK-ARREST SPECIMEN DATA
AND TEST RESULTS

Flow and Processing of Crack-Arrest Data

The appendices document for archival and quality assurance purposes various aspects of the crack-arrest data. Appendix A traces the flow and processing of data on the crack-arrest specimens and also givei detailed crack-arrest specimen dimensions and results. The BASIC computer code "CA_TEST" used to process the test data is listed in Appendix B, and the Young's moduli used are discussed in Appendix C. Typical output from CA_TEST for weld-embrittled and duplex-type crack-arrest specimens is shown in Appendix D. The load vs crack mouth opening displacement (CMOD) charts obtained during the test and a photograph of the fracture surface for each irradiated specimen is reproduced in Appendix E.

It is not possible to legibly present the voluminous data about each specimen in one table without resorting to foldout pages. Thus, to limit table widths to a single page, the data are logically grouped and the specimen identification is used to tie the tables together. To facilitate their use, the crack-arrest data tables given in the appendices are sorted by specimen identification (in the main body of the text they are sorted by test temperature).

The dimensions of each crack-arrest specimen are measured and recorded on data sheets, a sample of which is shown in Fig. A.1. The data on crack-arrest specimens are then recorded on a Hewlett Packard Series 200/300 computer. The BASIC computer code used for this purpose is CA_TEST, (crack arrest test), which was specifically written to process the crack-arrest test data. A listing of CA_TEST is included in Appendix B. The pretest input data consist of the measured specimen dimensions, test temperature, yield strength, and Young's modulus at the test temperature. The measured specimen dimensions, for the unirradiated and irradiated crack arrest tests are given in Tables A-1 and A-2, respectively. The yield strength and Young's moduli used have not been included in these tables. The yield strength for each of the 72W and 73W weldments are presented as Figs. 10 and 11 in the main body of the test, and Young's moduli are given in Appendix C.

The ASTM E 1221-88 test procedure prescribes for weld-embrittled-type specimens only a series of loading and unloading cycles. The yield strength and Young's modulus are used to calculate the load increment for the loading and unloading cycles for weld-embrittled-type specimens as well as the validity criteria. Young's modulus is also used to evaluate the stress intensity factors.

The pretest output for CA_TEST is an echo of the input data. CA_TEST also calculates and prints the load increments for the loading and unloading steps in terms of clip-gage CMOD. For duplex specimens, no loading and unloading cycles are prescribed in ASTM E 1221-88, but a single cycle with a CMOD approximately equal to that for weld-embrittled specimens is performed to seat the clip gage and generally shake down the test equipment.

After the rapid crack propagation and arrest event, the specimen is heat-tinted, chilled, and broken open. The length of the remaining ligament is measured at three locations by the procedure given in paragraph 8.6.2 of E 1221-88. These three lengths as well as the clip-gage CMODs at the four points on the load vs CMOD chart as prescribed in ASTM E 1221-88 are provided as posttest input to CA_TEST.

The maximum and minimum loads registered just before and after the rapid crack propagation event are also recorded. During the development of ASTM E 1221-88, the ratio of these loads was one of the validity requirements. Although the latest revision of ASTM E 1221-88 does not prescribe this ratio, it is still recorded for consistency with the large number of existing files. Experience has also shown that the relative load drop is an approximate indicator of the crack-jump length at the time of the test. A small drop in load is an indication that the crack has not propagated a significant amount. At the other extreme, if the load drops to almost zero, it is likely that the remaining ligament is small. All the posttest data are given in Tables A-3 and A-4 for the unirradiated and irradiated specimens respectively.

The output of CA_TEST echoes the posttest data input and calculates K_a and K_o as well as all the validity criteria prescribed in ASTM E 1221-88. The output also indicates which of the criteria have been met or not met. Typical output from CA_TEST for both a weld-embrittled and a duplex specimen is given in Appendix D.

The detailed values used to determine the validity of the crack-arrest results are given in Tables A-5 through A-8. Tables A-5 and A-6 are for the unirradiated 72W and 73W weldments respectively, and the corresponding information for the irradiated weldments is in Tables A-7 and A-8. In these four tables, the first row for each specimen contains the measured values required to judge the validity of the results. Below these values are the corresponding minimum values as prescribed in ASTM E 1221-88. Validity criteria are evaluated for weld-embrittled specimens (4 criteria) and duplex-type specimens (5 criteria).

In the right-hand column, the presence of one or more letters indicates that the specimen did not meet the validity criteria of ASTM E 1221-88. The arrested crack front is rarely straight or square. Thus, to allow for uncertainties in the measurement of the remaining ligament, the measured values were increased by 10% before they were compared with the ASTM criteria.

Other values included in the tables are the specimen type (whether weld embrittled or duplex) and nominal specimen thickness B and overall width (the height is equal to the width). Other parameters included are test temperature and stress intensity factors just before the rapid crack propagation event K_o (a measure of the crack-driving force) and that shortly after arrest K_a .

During the processing of the data, it was not clear how the information will be eventually presented. To maintain some flexibility, the data are maintained in the relational data base computer code PARADOX. Such a data base allows any of the information stored in it to be selected, sorted, and formatted for presentation. All data (including that from the Hewlett Packard Series 200/300 computers) are maintained in PARADOX on an IBM-compatible computer. The tables in this report have been prepared by using a RDB computer code. The RDB code has also proven useful in the evaluation of the data. When the data are examined from different viewpoints, input data errors are often noticed.

Table A-1. Measured dimensions in millimeters of the unirradiated crack-arrest specimens from the 72W and 73W weldments^a

Specimen	B	B _N	2H	W _t	Pr	R _S	R _t	T _U	T _V	N
A72W01	25.40	19.25	152.37	152.45	6.35	10.72	40.18	28.94	0.00	11.54
A72W02	33.05	24.73	152.37	152.45	6.35	10.69	40.24	28.89	0.00	12.98
A72W03	25.40	17.86	152.40	152.45	6.35	10.77	40.26	29.43	0.00	11.61
A72W04	33.05	24.94	152.37	152.45	6.35	10.73	40.26	28.90	0.00	11.53
A72W05	25.40	17.86	152.40	152.45	6.35	10.73	40.18	29.39	0.00	11.51
A72W07	33.02	25.12	152.37	152.43	6.35	10.67	40.33	28.91	0.00	11.52
A72W08	25.43	17.96	152.40	152.43	6.35	10.66	40.19	30.28	0.00	11.44
A72W12	33.05	25.07	152.40	152.43	6.35	10.68	40.32	28.77	0.00	11.45
A72W19	33.02	25.04	152.37	152.43	6.35	10.59	40.26	29.37	0.00	11.54
A72W20	25.37	18.15	152.43	152.43	6.35	10.47	40.52	28.68	0.00	11.49
A72W24	25.35	19.13	76.17	76.20	3.18	3.95	21.61	11.75	0.00	11.49
A72W25	25.35	19.15	76.17	76.17	3.18	3.77	21.54	11.58	0.00	11.46
A72W28	25.27	19.10	76.17	76.17	3.18	3.95	21.58	11.86	0.00	11.53
A72W31	25.27	19.20	76.17	76.17	3.18	3.95	21.60	11.80	0.00	11.41
A72W34	25.40	19.15	76.15	76.20	3.18	3.89	21.44	12.37	0.00	11.61
A72W35	25.40	19.08	76.20	76.23	3.18	3.93	21.66	11.86	0.00	11.57
A72W36	25.40	19.15	76.17	76.23	3.18	3.85	21.62	12.12	0.00	11.53
A72W37	25.40	19.02	76.17	76.23	3.18	4.00	21.68	12.03	0.00	11.52
A72W38	25.37	19.05	76.20	76.20	3.18	4.01	21.48	12.22	0.00	11.54
A72W39	25.40	19.00	152.37	152.40	6.35	10.62	40.44	28.54	0.00	11.53
A72W40	32.39	24.74	152.37	152.40	6.35	10.73	40.56	29.66	0.00	11.60
A72W41	25.6	19.00	152.37	152.43	6.35	10.74	40.50	28.39	0.00	11.55

Table A-1 (continued)

Specimen	B	B _y	2B	W _t	Pr	Rs	Rt	Tu	Tv	N
A72W43	25.43	19.00	152.40	152.37	6.35	10.62	40.44	28.42	0.00	11.50
A72W44	25.40	19.02	152.37	152.37	6.35	10.63	40.38	28.52	0.00	11.47
A72W45	32.99	24.74	152.40	152.40	6.35	10.56	40.40	28.89	0.00	11.41
A72W46	25.43	18.92	152.37	152.37	6.35	10.57	40.50	28.43	0.00	11.49
A72W47	33.02	24.74	152.37	152.40	6.35	10.70	40.51	28.52	0.00	11.50
A72W48	25.40	18.87	152.37	152.40	6.35	10.69	40.55	28.33	0.00	11.38
A72W57	32.97	24.79	152.40	152.40	6.35	9.40	41.13	27.07	42.67	1.43
A72W62	32.99	24.82	152.40	152.40	6.35	9.53	41.34	26.76	42.67	1.15
A72W63	32.99	24.84	152.35	152.37	6.35	9.55	41.39	26.50	42.67	1.04
A72W64	33.02	24.79	152.45	152.35	6.35	9.48	41.16	26.70	42.67	1.08
A72W65	33.05	24.79	152.40	152.40	6.35	9.53	41.38	26.89	42.67	1.17
A72W66	33.02	24.77	152.40	152.43	6.35	9.49	41.34	26.55	42.67	1.06
A72W68	32.99	24.79	152.40	152.40	6.35	9.45	41.33	27.22	42.67	1.10
A72W71	33.02	24.79	152.43	152.43	6.35	9.53	41.25	27.06	42.67	1.06
A72W73	33.05	24.82	152.43	152.40	6.35	9.46	41.20	30.19	42.67	1.13
A72W82	50.85	46.99	203.23	197.74	14.29	7.90	48.66	40.18	0.00	11.34
A72W84	50.90	46.99	203.20	197.71	14.29	7.76	48.74	40.19	0.00	11.33
A72W85	50.84	38.13	203.33	197.76	14.27	7.87	50.30	54.35	0.00	11.86
A73W01	25.45	19.02	76.15	76.15	3.18	3.65	21.65	11.82	0.00	11.52
A73W02	25.45	19.02	76.17	76.12	3.18	3.57	21.84	11.52	0.00	11.60
A73W03	25.45	19.10	76.15	76.12	3.18	3.70	21.58	11.74	0.00	11.52
A73W04	25.45	19.00	76.17	76.12	3.18	3.76	21.26	12.18	0.00	11.52
A73W05	25.45	19.13	76.17	76.10	3.18	3.84	21.64	11.70	0.00	11.51
A73W06	25.45	19.02	76.17	76.02	3.18	3.79	21.64	11.69	0.00	11.56
A73W07	32.97	24.93	152.35	152.27	6.35	9.54	41.12	26.74	43.18	2.37
A73W08	32.97	24.97	152.37	152.37	6.35	9.60	41.15	26.83	43.18	2.45
A73W09	32.94	24.94	152.35	152.37	6.35	9.57	41.11	27.00	43.18	2.36
A73W10	32.99	24.88	152.37	152.40	6.35	10.41	40.29	34.39	0.00	11.52

Table A.1 (continued)

Specimen	B	B _W	2H	W _t	Pr	Rs	Rt	Tu	Tv	N
A73W11	25.43	18.97	152.43	152.43	6.35	10.58	40.14	34.65	0.00	11.59
A73W16	25.40	18.95	152.35	152.37	6.35	10.50	40.30	34.59	0.00	11.56
A73W20	25.40	18.92	152.35	152.40	6.35	10.41	40.29	34.03	0.00	11.60
A73W22	33.05	24.78	152.40	152.37	6.35	10.37	40.14	34.60	0.00	11.52
A73W24	32.99	24.80	152.37	152.37	6.35	10.38	40.39	34.62	0.00	11.45
A73W25	25.40	19.02	152.35	152.40	6.35	10.52	40.45	34.19	0.00	11.57
A73W27	32.99	24.77	152.37	152.40	6.35	10.45	40.19	34.28	0.00	11.53
A73W28	25.40	18.97	152.35	152.40	6.35	10.43	40.43	34.38	0.00	11.58
A73W29	33.02	24.77	152.37	152.40	6.35	10.30	40.33	34.31	0.00	11.51
A73W30	25.40	18.95	152.43	152.45	6.35	10.51	40.30	34.48	0.00	11.59
A73W32	25.40	19.10	76.17	76.23	3.18	3.83	21.60	12.13	0.00	11.53
A73W36	25.40	19.02	76.17	76.23	3.18	4.02	21.56	11.81	0.00	11.49
A73W38	25.40	19.15	76.17	76.23	3.18	3.83	21.53	12.11	0.00	11.49
A73W42	25.40	19.08	76.20	76.23	3.18	3.85	21.46	12.17	0.00	11.55
A73W43	25.40	19.02	152.37	152.40	6.35	10.61	40.39	28.61	0.00	11.51
A73W44	33.05	24.79	152.40	152.40	6.35	10.61	40.46	29.62	0.00	11.52
A73W46	33.02	24.82	152.37	152.40	6.35	10.62	40.33	28.67	0.00	11.70
A73W47	25.43	18.95	152.40	152.40	6.35	10.73	40.41	28.65	0.00	11.48
A73W48	25.40	18.87	152.37	152.37	6.35	10.59	40.46	28.76	0.00	11.57
A73W49	33.02	24.74	152.32	152.37	6.35	10.59	40.43	28.52	0.00	11.37
A73W50	25.43	19.08	152.37	152.40	6.35	10.71	40.37	28.74	0.00	11.57
A73W52	25.43	19.05	152.40	152.37	6.35	10.76	40.59	28.64	0.00	11.55
A73W75	49.53	37.26	203.23	203.28	0.84	8.43	55.16	37.10	66.06	1.50
A73W85	33.05	24.87	152.32	152.43	6.27	9.58	41.30	27.97	42.57	1.34
A73W86	33.02	24.89	152.43	152.45	6.27	9.51	41.27	27.84	42.77	1.39
A73W87	32.99	24.89	152.45	152.43	6.27	9.53	41.26	28.69	44.19	1.38
A73W88	32.97	24.99	152.50	152.45	6.27	9.46	41.25	28.72	42.42	1.37

^aSee Fig. A.1 for definitions of nomenclature used in this table.

Table A-2. Measured dimensions in millimeters of the irradiated weld-embrittled crack-arrest specimens from the 72W and 73W weldments^a

Specimen	B	B _N	2H	W _t	Pr	R _s	R _t	T _U	N
A72W06	25.40	17.88	152.40	152.40	6.35	10.51	40.22	29.56	11.65
A72W09	33.02	24.82	152.40	152.40	6.35	10.50	40.23	30.13	11.51
A72W10	25.40	17.93	152.40	152.40	6.35	10.52	40.31	28.85	11.53
A72W11	25.40	17.83	152.40	152.40	6.35	10.43	40.29	29.35	11.51
A72W13	25.40	17.83	152.40	152.40	6.35	11.87	41.68	28.79	11.39
A72W14	33.02	25.02	152.40	152.40	6.35	10.49	40.27	28.92	11.51
A72W15	25.40	17.81	152.40	152.40	6.35	10.54	40.34	28.96	11.55
A72W16	25.40	17.83	152.40	152.40	6.35	10.48	40.29	29.37	11.56
A72W17	33.02	24.79	152.37	152.40	6.35	10.49	40.34	28.97	11.15
A72W18	25.40	18.01	152.40	152.40	6.35	10.51	40.34	28.89	11.51
A72W21	25.40	19.08	76.20	76.20	3.18	3.59	21.45	11.60	11.59
A72W22	25.40	19.10	76.20	76.20	3.18	3.73	21.36	11.91	11.48
A72W23	25.40	19.10	76.20	76.20	3.18	3.82	21.48	11.81	11.48
A72W26	25.40	19.10	76.20	76.20	3.18	3.94	21.62	11.76	11.56
A72W27	25.40	19.13	76.20	76.20	3.18	3.91	21.54	11.80	11.51
A72W29	25.40	19.08	76.20	76.20	3.18	3.64	21.35	11.81	11.55
A72W30	25.40	19.15	76.20	76.20	3.18	3.98	21.43	11.90	11.66
A72W32	25.40	19.13	76.20	76.20	3.18	3.60	21.43	11.78	11.54

Table A-2 (continued)

Specimen	B	R _g	2H	W _c	P _r	R _s	R _t	T _d	N
A73W13	25.40	18.92	152.40	152.40	6.35	10.35	40.33	34.58	11.55
A73W14	33.02	24.77	152.40	152.40	6.35	10.45	40.32	34.54	11.52
A73W15	25.40	18.95	152.40	152.40	6.35	10.41	40.35	34.59	11.62
A73W17	33.02	24.77	152.40	152.40	6.35	10.41	40.35	34.49	11.53
A73W18	25.40	18.92	152.40	152.40	6.35	10.27	40.41	34.68	11.60
A73W21	25.40	18.90	152.40	152.40	6.35	10.13	40.33	34.49	11.52
A73W23	25.40	18.90	152.40	152.40	6.35	10.31	40.32	34.52	11.64
A73W26	25.40	18.87	152.46	152.40	6.35	10.38	40.21	34.67	11.55
A73W31	25.40	19.06	76.20	76.20	3.18	3.80	21.63	12.12	11.55
A73W33	25.40	19.08	76.20	76.20	3.18	3.75	21.62	12.10	11.69
A73W34	25.40	19.05	76.20	76.20	3.18	3.78	21.65	11.99	11.48
A73W35	25.40	19.10	76.20	76.20	3.18	3.87	21.59	12.18	11.58
A73W37	25.40	19.05	76.20	76.20	3.18	3.83	21.57	12.35	11.59
A73W39	25.40	19.13	76.20	76.20	3.18	3.80	21.65	12.07	11.53
A73W40	25.40	19.00	76.20	76.20	3.18	3.75	21.60	12.13	11.54
A73W41	25.40	19.02	76.20	76.20	3.18	3.79	21.60	12.05	11.56
A73W45	25.40	19.13	152.40	152.40	6.35	10.68	40.45	28.74	11.51
A73W51	33.02	24.71	152.40	152.40	6.35	10.50	40.55	28.57	11.47

^aSee Fig. A.1 for the definition of the nomenclature used in this table.

Table A-3. Posttest values measured for unirradiated crack-arrest specimens from the 72W and 73W weldments

Specimen	W1	W2	W3	P1	P2	P3	P4	P _{max}	P _{min}
A72W01	33.01	30.94	33.66	0.056	0.163	1.351	1.369	52	4
A72W02	28.64	27.53	29.22	0.038	0.147	1.369	1.443	71	0
A72W03	42.67	42.52	42.70	0.051	0.165	1.405	1.455	54	17
A72W04	37.80	25.65	31.22	0.025	0.122	1.367	1.445	68	2
A72W05	36.73	36.13	42.57	0.046	0.165	1.265	1.326	54	11
A72W07	34.68	34.73	34.43	0.061	0.163	1.367	1.423	73	0
A72W08	35.86	34.64	34.81	0.030	0.145	1.283	1.346	52	4
A72W12	33.03	34.23	33.78	0.038	0.312	1.600	1.651	77	1
A72W19	33.09	36.33	33.54	0.051	0.142	1.224	1.326	71	0
A72W20	39.10	35.34	42.45	0.000	0.000	0.714	0.767	29	0
A72W24	10.58	10.37	10.35	0.020	0.058	0.742	0.815	27	0
A72W25	12.50	11.65	14.60	0.046	0.109	0.889	0.932	26	2
A72W28	9.82	10.54	9.45	0.018	0.079	0.762	0.828	33	0
A72W31	13.26	13.46	15.78	0.020	0.208	1.168	1.219	51	1
A72W34	14.77	13.69	15.95	0.013	0.043	0.732	0.737	28	2
A72W35	12.02	12.56	12.14	0.008	0.020	0.554	0.630	25	6
A72W36	13.67	14.84	11.62	0.010	0.069	0.737	0.800	31	2
A72W37	14.20	14.47	14.15	0.008	0.015	0.610	0.709	26	0
A72W38	11.65	11.74	11.15	0.020	0.028	0.620	0.699	28	0
A72W39	13.87	14.46	13.79	0.030	0.030	0.879	1.095	34	0
A72W40	24.79	27.18	23.77	0.051	0.320	1.892	1.956	87	0
A72W41	34.88	34.19	33.12	0.056	0.056	0.927	1.016	30	0
A72W43	33.35	31.12	34.07	0.025	0.066	1.184	1.245	49	0
A72W44	34.18	34.21	33.34	0.018	0.043	0.925	1.019	44	2
A72W45	38.29	38.93	36.84	0.058	0.058	0.889	0.980	38	2
A72W46	46.44	48.73	42.19	0.056	0.056	0.958	0.980	36	8
A72W47	33.36	38.38	29.52	0.061	0.097	1.189	1.255	56	2
A72W48	34.57	35.19	33.04	0.038	0.076	1.214	1.306	53	1
A72W57	54.48	54.34	56.69	0.018	0.000	1.283	1.316	78	4
A72W62	37.13	37.39	36.83	0.000	0.000	1.577	1.659	107	8
A72W63	39.81	40.04	41.37	0.005	0.000	1.361	1.427	143	1
A72W64	37.49	35.73	39.64	0.036	0.000	1.275	1.306	75	10
A72W65	34.33	34.35	38.15	0.010	0.000	1.509	1.554	84	8

Table A-3. (continued)

Specimen	W1	W2	W3	P1	P2	P3	P4	P _{max}	P _{min}
A72W66	31.37	32.20	30.64	0.018	0.000	1.346	1.402	87	3
A72W68	35.17	35.53	38.25	0.020	0.000	1.359	1.443	89	0
A72W71	23.22	22.16	25.71	0.025	0.000	1.392	1.504	106	0
A72W73	48.18	50.45	43.83	0.048	0.000	1.415	1.648	64	2
A72W83	59.33	60.56	56.02	0.079	0.079	1.209	1.224	66	26
A72W84	53.72	55.41	60.47	0.086	0.178	1.570	1.651	121	6
A72W85	32.98	39.89	28.27	0.102	0.163	1.745	1.816	76	6
A73W01	10.14	10.87	9.47	0.051	0.038	0.650	0.699	18	0
A73W02	14.24	12.53	15.76	0.025	0.038	0.732	0.808	27	0
A73W03	7.76	7.89	8.08	0.030	0.097	0.919	0.998	26	0
A73W04	10.36	9.00	11.43	0.030	0.102	0.838	0.909	38	0
A73W05	8.04	9.48	7.29	0.038	0.193	1.021	1.125	38	0
A73W06	12.99	13.00	12.67	0.043	0.254	0.996	1.052	37	9
A73W07	30.21	34.74	31.51	0.025	0.000	1.636	1.783	119	0
A73W08	39.08	38.93	40.81	0.025	0.000	1.313	1.417	88	1
A73W09	37.24	39.62	37.05	0.025	0.000	1.283	1.372	97	6
A73W10	16.62	16.62	16.31	0.030	0.229	1.605	1.671	66	0
A73W11	34.95	33.74	36.70	0.051	0.079	1.083	1.107	31	12
A73W16	32.55	34.35	31.80	0.013	0.051	1.143	1.186	48	0
A73W20	40.31	40.56	39.90	0.051	0.262	1.542	1.565	49	5
A73W22	27.44	26.80	29.91	0.013	0.173	1.651	1.671	54	0
A73W24	14.07	14.66	11.93	0.038	0.361	2.108	2.200	68	0
A73W25	35.53	35.93	39.76	0.038	0.229	1.781	1.819	48	12
A73W27	34.23	38.29	34.82	0.025	0.125	1.407	1.433	61	0
A73W28	29.54	30.73	28.66	0.051	0.051	0.968	1.003	30	2
A73W29	31.24	26.85	34.02	0.064	0.099	1.402	1.433	66	0
A73W30	25.60	28.52	23.98	0.025	0.053	1.067	1.118	31	0
A73W32	6.60	6.91	6.93	0.013	0.058	0.841	0.927	37	0
A73W36	10.84	13.75	12.90	0.013	0.043	0.716	0.792	31	1
A73W38	6.98	6.83	6.81	0.020	0.048	0.699	0.876	23	0
A73W42	8.80	8.09	9.36	0.025	0.053	0.726	0.874	34	0
A73W43	35.72	36.16	36.54	0.056	0.056	0.892	0.968	43	0
A73W44	41.77	44.87	42.95	0.064	0.150	1.372	1.433	75	18
A73W46	41.28	39.15	42.24	0.030	0.137	1.433	1.473	73	0
A73W47	39.58	41.03	39.26	0.056	0.056	0.968	1.031	38	8
A73W48	28.27	26.48	29.53	0.051	0.091	1.090	1.166	40	3
A73W49	35.39	33.42	38.65	0.030	0.206	1.516	1.539	64	0

Table A-3. (continued)

Specimen	W1	W2	W3	P1	P2	P3	P4	P _{max}	P _{min}
A73W50	18.05	18.28	22.52	0.036	0.152	1.435	1.560	67	0
A73W52	18.32	18.84	17.84	0.051	0.155	1.448	1.567	66	0
A73W75	40.84	37.67	45.12	0.000	0.000	1.613	1.765	181	0
A73W85	50.63	50.28	49.94	0.000	0.000	1.280	1.313	82	7
A73W86	34.19	35.10	32.86	0.000	0.000	1.245	1.285	83	1
A73W87	30.58	30.94	30.74	0.000	0.000	1.491	1.554	91	2
A73W88	42.81	46.58	42.56	0.000	0.000	1.387	1.407	82	3

NOTES:

W1, W2, and W3 = lengths in millimeters of the remaining ligament measured according to ASTM E 1221-88

P1 through P4 = displacements in millimeters measured from the load vs CMOD trace, see Fig. A.3.

P_{max}, P_{min} = maximum and minimum loads registered just before and just after the rapid crack propagation event.

Table A-4. Posttest values measured for unirradiated crack arrest specimens from the 72W and 73W weldments

Specimen	W1	W2	W3	P1	P2	P3	P4	P _{max}	P _{min}
A72W06	66.1	67.45	68.33	0	0.127	1.213	1.265	21	16
A72W09	46.34	45.59	52.86	0	0.152	1.246	1.308	50	16
A72W10	49.31	49.94	48.44	0	0.051	0.965	1.003	16	6
A72W11	60.43	60.25	62.5	0	0.159	1.124	1.149	18	12
A72W13	43.86	45.26	43.38	0	0.051	0.81	0.879	28	7
A72W14	59.19	68.53	56.84	0	0.14	1.232	1.283	58	29
A72W15	46.14	49.14	45.93	0	0.089	1.13	1.186	18	3
A72W16	54.8	57.81	52.31	0	0.102	0.919	0.958	15	8
A72W17	50.94	59.45	50.96	0	0.064	1.095	1.138	24	12
A72W18	52.18	66.86	52.02	0	0.038	1.138	1.138	39	1
A72W21	20.35	20.48	19	0	0	0.404	0.452	8	2
A72W22	6.682	7.145	7.406	0	0	0.957	0.97	2	1
A72W23	21.77	22.11	22.23	0	0	0.538	0.572	10	3
A72W26	15.57	14.19	15.03	0	0.013	0.34	0.406	7	2
A72W27	18.13	19.6	17.3	0	0	0.498	0.549	11	3
A72W29	20.23	22.09	19.96	0	0	0.538	0.574	11	3
A72W30	15.84	15.11	15.25	0	0	0.396	0.414	6	2
A72W32	24.77	24.78	24.97	0	0	0.434	0.472	10	5
A73W13	67.24	70.09	60.19	0	0.051	1.151	1.189	20	16
A73W14	29.69	24.59	33.03	0	0.218	2.255	2.398	58	1
A73W15	45.23	47.6	44.04	0	0.013	0.828	0.859	16	5
A73W17	0	0	0	0	0	0	0	0	0
A73W18	48.72	54.82	50.23	0	0.083	1.273	1.285	15	5
A73W21	52.97	53.16	56.02	0	0.032	0.972	0.997	12	7
A73W23	43.73	50.62	41.69	0	0.286	2.037	2.045	60	9
A73W26	56.14	55.65	56.27	0	0.02	0.77	0.813	12	6
A73W31	19.97	22.84	21.64	0	0	0.408	0.464	8	3
A73W33	26.34	26.68	26.6	0	0	0.464	0.495	10	4
A73W34	22.15	21.2	22.88	0	0	0.414	0.48	10	3
A73W35	27.82	25.31	30.01	0	0	0.411	0.424	9	4
A73W37	2.738	3.18	2.556	0	0.025	0.732	0.732	1	0
A73W39	13.66	13.86	14.39	0	0	0.362	0.464	13	1
A73W40	25.99	26.32	26.62	0	0	0.508	0.546	10	4
A73W41	31.13	32.23	29.41	0	0	0.432	0.472	9	5
A73W45	52.69	52.84	60.23	0	0.07	1.034	1.082	26	10
A73W51	47.38	51.28	42.7	-0.013	0.343	2.019	2.057	41	16

NOTES:

W1, W2, and W3 = lengths in millimeters of the remaining ligament measured according to ASTM E 1221-88.

P1 through P4 = displacements in millimeters measured from the load vs crack mouth opening displacement trace, see Fig. A.1.

P_{max}, P_{min} = maximum and minimum loads registered just before and just after the rapid crack propagation event

Table A-5. Values measured during crack-arrest testing of the unirradiated weldment 72W and 73W

specimen	Type	B	W _t	T	X-1	X-0	A	B	C	D	E	Validity
A72W01	WE	25	152	-16	-17	199	13	33	25	51	31	
A72W02	WE	33	152	0	-91	103	19	23	18	22	24	
A72W03	WE	25	152	-14	-128	214	43	43	25	40	40	C
A72W04	WE	33	152	-15	-96	209	26	28	33	25	55	
A72W05	WE	25	152	-10	-107	191	19	21	17	23	26	
A72W07	WE	33	152	-15	-103	201	35	35	33	49	49	
A72W08	WE	25	152	-10	-104	195	15	35	25	47	47	
A72W12	WE	33	152	0	-114	215	36	36	33	50	50	
A72W19	WE	33	152	-15	-96	180	16	36	13	49	49	
A72W20	WE	25	152	-67	-65	126	19	32	17	23	20	
A72W24	WE	25	76	-10	-91	168	0	10	25	32	32	
A72W25	WE	25	76	-10	-9	192	13	13	25	30	30	B
A72W28	WE	25	76	-10	-90	168	10	10	25	33	33	
A72W31	WE	25	76	-15	-108	204	14	14	25	29	29	B,E
A72W34	WE	25	76	-95	-73	168	19	19	25	28	28	
A72W35	WE	25	76	-60	-3	132	12	12	25	31	31	
A72W36	WE	25	76	-61	-61	166	13	13	22	29	29	
A72W37	WE	25	76	-61	-66	167	16	14	25	28	28	
A72W38	WE	25	76	-59	-77	166	12	12	25	31	31	
A72W39	WE	25	152	-60	-55	145	14	14	25	69	69	A
A72W40	WE	33	152	0	-114	261	25	25	13	52	52	B
A72W41	WE	25	152	-45	-74	149	14	34	25	50	50	
A72W43	WE	25	152	-12	-92	190	13	13	25	31	31	
A72W44	WE	25	152	-60	-56	151	16	36	25	50	50	
A72W45	WE	33	152	-65	-66	141	18	38	13	45	45	
A72W46	WE	25	152	-63	-63	154	16	36	25	38	38	
A72W47	WE	33	152	-30	-91	186	14	34	13	50	50	
A72W48	WE	25	152	-10	-98	194	14	34	25	49	49	
							19	22	18	23	22	

Table A-5. (continued)

Specimen	Type	B	V _t	T	E _a	E _b	A	B	C	D	E	Latitude
A72W57	DX	33	152	21	146	216	55	55	13	13	13	C, D
A72W62	DX	33	152	10	136	267	37	37	13	31	11	B, C
A72W63	DX	33	152	-1	125	232	40	40	13	28	28	
A72W64	DX	33	152	1	108	217	38	38	13	31	31	
A72W65	DX	33	152	4	125	256	36	36	33	33	33	
A72W66	DX	33	152	-2	103	229	31	31	33	37	17	
A72W68	DX	33	152	5	115	229	36	36	33	32	32	
A72W71	DX	33	152	-14	91	237	26	24	33	45	45	
A72W73	DX	33	152	5	142	230	48	48	33	21	21	C, D
A72W83	WE	51	203	-30	85	146	59	59	51	50	50	
A72W84	WE	51	203	0	107	178	57	57	51	52	52	
A72W85	WE	51	203	-15	95	195	36	36	51	59	59	
A73W01	WE	25	/6	-65	52	151	10	10	26	33	33	
A73W02	WE	25	/6	-65	75	172	14	14	26	29	29	
A73W03	WE	25	/6	-65	66	203	8	8	26	35	35	B, C
A73W04	WE	25	/6	-30	67	181	10	10	26	32	32	
A73W05	WE	25	/6	-30	70	204	8	8	26	35	35	A, B
A73W06	WE	25	/6	-15	83	184	13	13	26	30	30	B
A73W07	DX	33	152	5	129	277	32	32	33	36	36	B
A73W08	DX	33	152	5	119	222	40	40	33	28	28	
A73W09	DX	33	152	5	112	216	38	38	33	30	30	
A73W10	WE	33	152	-16	77	216	17	17	33	61	61	A
A73W11	WE	25	152	-32	85	159	35	35	25	43	43	
A73W16	WE	25	152	-29	89	172	13	13	25	45	45	
A73W20	WE	25	152	-16	126	203	40	40	25	38	38	C
A73W22	WE	33	152	-16	110	232	28	28	33	50	50	
A73W24	WE	33	152	-13	89	273	16	16	33	64	64	A, B
A73W25	WE	25	152	-15	141	243	37	37	25	41	41	B, C

Table A-5. (continued)

Specimen	Type	B	W_1	T	K_I	K_{Ic}	A	B	C	D	E	Validity
A73W27	WE	33	152	-12	111	202	16	36	13	42	42	
A73W28	WE	25	152	-61	69	166	10	10	25	23	25	
A73W29	WE	33	152	-30	100	205	31	31	13	47	47	
A73W30	WE	25	152	-44	71	151	26	26	25	52	52	
A73W32	WE	25	76	-59	56	192	7	7	25	36	36	A
A73W36	WE	25	76	-59	72	168	14	14	25	29	29	
A73W38	WE	25	76	-62	50	160	7	7	25	36	36	A
A73W42	WE	25	76	-60	58	166	9	9	25	34	34	
A73W43	WE	25	152	-45	73	142	36	36	25	47	47	
A73W44	WE	33	152	-15	123	206	43	63	13	39	39	
A73W46	WE	33	152	-15	126	219	41	41	13	43	43	
A73W47	WE	25	152	-45	85	156	40	40	25	43	43	
A73W48	WE	25	152	-31	75	170	28	28	25	55	55	
A73W49	WE	33	152	-15	117	222	36	36	33	48	48	
A73W50	WE	25	152	-30	80	221	20	20	25	64	64	
A73W52	WE	25	152	-29	77	219	18	18	25	65	65	
A73W75	DX	74	203	5	107	229	61	61	50	61	61	
A73W85	DX	33	152	5	137	214	50	50	13	18	18	C,D
A73W86	DX	33	152	5	101	209	34	34	13	34	34	
A73W87	DX	33	152	5	113	247	31	31	13	36	36	
A73W88	DX	33	152	15	132	228	64	64	13	25	25	
									19	44	36	25

NOTES:

- Type = either WE (weld-embrittled) or DX (duplex)
 B, W_1 = nominal overall specimen size, in millimeters, see Fig. 2
 T = test temperature in °C
 K_I, K_{Ic} = stress intensity factor at crack arrest and at crack initiation,
 respectively, in MPa·m

The letters A, B, ... E are the letters used in the ASTM E 1221-88 validity criteria. The top row of numbers are the measured values for each criterion, and those below are the minimums specified in the standard. The remaining ligament has to fulfill two criteria, and thus the same value is repeated for A and B. The same is true for the crack jump.

- A,B = length of remaining ligament, millimeters
 C = specimen width, millimeters
 D,E = crack jump, millimeters. For duplex specimens, only D is applicable.
 Validity = On or more letters in this column indicates that the specimen did not meet the validity criteria of E 1221-88. To allow for the uncertainty in the measurement of the crack front, the measured values were increased by 10% before comparing them with the criteria in the standard

Table A-6. Values measured during crack-arrest testing of irradiated weldment 72W and 73W

Specimen	Type	B	W _t	T	K _θ	K _φ	A	B	C	D	E	Validity
A72W06	WE	25	152	90	160	182	67	67	25	15	15	C,D
							19	50	40	23	15	
A72W09	WE	33	152	90	120	176	48	48	33	34	34	
							19	28	23	23	14	
A72W10	WE	25	152	75	101	155	49	49	25	34	34	
							19	20	16	23	11	
A72W11	WE	25	152	75	133	163	61	61	25	22	22	
							19	35	28	23	12	
A72W13	WE	25	152	60	81	130	44	44	25	38	38	
							19	13	10	23	7.3	
A72W14	WE	33	152	100	144	177	62	62	33	22	22	
							19	41	33	23	14	
A72W15	WE	25	152	75	114	177	47	47	25	36	36	
							19	25	20	23	14	
A72W16	WE	25	152	76	102	138	55	55	25	28	28	
							19	20	16	23	8.5	
A72W17	WE	33	152	100	118	168	54	54	33	29	29	
							19	28	22	22	13	
A72W18	WE	25	152	90	132	185	57	57	25	26	26	
							19	34	27	23	16	
A72W21	WE	25	76	30	53	98	20	20	25	23	23	
							9.6	5.2	4.2	23	4	
A72W22	WE	25	76	60	62	229	7.1	7.1	25	36	36	A
							9.5	7.4	6	23	23	
A72W23	WE	25	76	60	74	129	22	22	25	21	21	D
							9.5	10	8.3	23	7.3	
A72W26	WE	25	76	-25	38	81	15	15	25	28	28	
							9.5	2.5	2	23	2.4	
A72W27	WE	25	76	29	61	121	18	18	25	25	25	
							9.5	7	5.6	23	6.1	
A72W29	WE	25	76	60	70	129	21	21	25	22	22	
							9.6	9.5	7.6	23	7.3	
A72W30	WE	25	76	-25	43	97	15	15	25	28	28	
							9.5	3.1	2.5	23	3.5	
A72W32	WE	25	76	32	66	105	25	25	25	18	18	D
							9.6	8.2	6.5	23	4.6	
A73W13	WE	25	152	75	150	168	66	66	25	12	12	C,D
							19	41	33	23	12	
A73W14	WE	33	152	90	159	325	29	29	33	48	48	B,C
							19	46	37	23	44	
A73W15	WE	25	152	60	81	125	46	46	25	32	32	
							19	12	9.4	23	6.3	
A73W17	WE	33	152	100								
A73W18	WE	25	152	75	131	182	51	51	25	26	26	
							19	31	25	23	14	
A73W21	WE	25	152	75	107	144	5%	54	25	24	24	
							19	21	17	23	8.4	
A73W23	WE	25	152	90	180	263	45	45	25	32	32	B,C
							19	60	48	23	29	
A73W26	WE	25	152	75	88	115	55	55	25	22	22	
							19	14	11	23	5.4	
A73W31	WE	25	76	29	57	98	22	22	25	21	21	D
							9.5	5.7	4.6	23	3.7	
A73W33	WE	25	76	60	74	110	27	27	25	16	16	D
							9.5	9.7	7.8	23	4.8	
A73W34	WE	25	76	29	60	100	22	22	25	21	21	D
							9.5	6.2	5	23	3.8	

Table A.6 (continued)

Specimen	Type	B	W _t	T	K _a	K ₀	A	B	C	D	E	Validity
A73W35	WE	25	76	29	67	99	28	28	25	15	15	D
A73W37	WE	25	76	-25	29	171	2.8	2.8	25	40	40	A
A73W39	WE	25	76	-25	41	88	14	14	9.5	1.4	1.1	23 10
A73W40	WE	25	76	60	81	121	26	26	25	16	16	D
A73W41	WE	25	76	60	79	103	31	31	9.5	12	9.3	23 5.8
A73W45	WE	25	152	90	114	158	55	55	25	28	28	
A73W51	WE	33	152	100	184	274	47	19	24	19	23	10
								19	33	36	36	B,C
								19	63	50	23	31

NOTES:

- Type = either WE (weld-embrittled) or DX (duplex)
 B, W_t = nominal overall specimen size, in millimeters, see Fig. 2
 T = test temperature in °C
 K_a, K₀ = stress intensity factor at crack arrest and at crack initiation, respectively, in MPa·m^{0.5}

The letters A, B, ... E are the letters used in the ASTM E 1221-88 validity criteria. The top row of numbers are the measured values for each criterion, and those below are the minimums specified in the standard. The remaining ligament has to fulfill two criteria, and thus the same value is repeated for A and B. The same is true for the crack jump.

- A,B = length of remaining ligament, millimeters.
 C = specimen width, millimeters.
 D,E = crack jump, millimeters. For duplex specimens, only D is applicable.
- Validity = On or more letters in this column indicates that the specimen did not meet the validity criteria of E 1221-88. To allow for the uncertainty in the measurement of the crack front, the measured values were increased by 10% before comparing them with the criteria in the standard.

CRACK ARREST DATA SHEET

Test date: 1/25/73

Spec. No.: A72W32

Project: NPS-10000
Orientation:Material: 304L
Depth:

Pins: NORMAL / INVERTED

WELD EMBRITTLED / DUPLEX

Test temperature: \times °C0.2% Yield Strength: 615 MPa
(at test temp)CVN (30 ft-lb): \times °C
E: 215 GPa MPaCVN (50 ft-lb): \times °C
Drop Weight NDT: \times °C

Pre-test specimen dimensions

B: 1.000 in (1)
BH: 0.752 in (1)
ZH: 2.000 in
WT: 3.000 inPR: 3.175 mm
RS: 3.597 mm
RT: 27.432 mm
TU: 77.799 mm
H: 11.542 mm

IF DUPLEX

TV: \times mm
D: \times mm (2)(1) Average of 2 measurements
(2) Diameter of starter hole

POST-TEST

Crack face:

Measure ($W - A_B$) at 3 points:
at + BN/4 \downarrow 25.4 (19.3) mm
at midline \downarrow (29.7) mm
at - BN/4 \downarrow (29.97) mm

Load/COD chart:




 $R_1 = 0$ mils
 $R_2 = 0$ mils
 $P_1 = 17.0$ mils 17.1
 $P_2 = 18.5$ mils 18.6 $P_{\text{MAX}} = 2220$ lb
 $P_{\text{MIN}} = 1240$ lb#WorkingData.VISITNCRACKARDDATA.BAT
February 24, 1988

Fig. A-1. Comparison of values of Young's moduli as calculated from an American Society of Mechanical Engineers table and an Electric Power Research Institute expression.

APPENDIX B
LISTING OF BASIC COMPUTER CODE CA_TEST

Documentation of Computer Code CA TEST

The listing of the computer code CA_TEST has been included solely for purposes of QA. It details in a concise manner the computational details that were performed with the crack arrest data. Moreover, the methodology in crack-arrest testing is still evolving. The standard test method used in this work, ASTM Test for Determining Plane-Strain Crack-Arrest Fracture Toughness, K_{Ic} , of Ferritic Steels (E 1221-88), is in its first issue and will probably be modified. It is therefore important that the precise details of the algorithms used to calculate K_a as well as the validity criteria be documented. If crack-arrest methodology does change, that data can be re-evaluated using the new methodology.

```

10 ! THE NAME OF THIS PROGRAM IS CA_TEST
20 !
30 DIM Banner$(40)
40 Banner$ = "Version 5.1 Revised February 14, 1990"
50 !
60 !
70 ! THIS PROGRAM PERFORMS CRACK ARREST TEST COMPUTATIONS
80 !
90 !
100 INTEGER Cycle,Nrec,Nbytes,Nvar
110 !
120 !
130 ! INITIALIZATION OF VARIABLES
140 !
150 ! Data_stored = 0 (FALSE) (DEFAULT) data for specimen .ave NOT been stored
160 !           = 1 (TRUE) data for this spec. have been stored previously
170 !           This is set in subprogram Load after successful input
180 !
190 ! For DUPLEX specimens, Tv = measured value, rad for
200 ! WELD-EMBRITTLED specimens Tv = 0
210 !
220 ! Yso = Dynamic yield strength increment is set at 205 MPa
230 ! per ASTM 1221-88 Para.
240 !
250 ON ERROR GOTO Error_sub
260 !
270 Yso = 205
280 Data_stored = 0
290 Msus$ = ".700,1"
300 PRINTER IS 1
310 !
320 PRINT "CRACK ARREST CALCULATIONS      "&Banner$
330 PRINT "THIS PROGRAM LOADS DATA PREVIOUSLY STORED ON 3.5" DISKS"
340! WAIT 2
350 !
360 !
370 !               **** Begin ****
380 Begin: !
390 M$ = "Y"
400 INPUT "LOAD DATA FROM DISKETTE? (Y/N) Y",M$
410 IF M$ = "Y" THEN
420   PRINTER IS 1
430   DISP "INSERT DATA SOURCE AND PRESS CONTINUE"
440   PAUSE
450   GOSUB Load
460   GOTO Print_dta
470 END IF
480 !
490 !
500 !               **** Start ****
510 ! Starts data input from Keyboard
520 Start: !
530 PRINTER IS 1
540 PRINT USING "@"
550 INPUT "ENTER SPECIMEN NO.",File$
560 PRINT USING "***SPECIMEN NO. = **.10A*",File$
570 PRINT
580 INPUT "ENTER TEST TEMPERATURE IN C",Tp
590 INPUT "ENTER YIELD STRENGTH AT TEST TEMPERATURE IN MPa",Ys
600 INPUT "ENTER TEST DATE IN THE FORM 072989 (6 CHARACTERS MAX)",Test_date

```

```

610 PRINT USING "3X,2" TEST DATE = "",IX,6Z";Test date
620 PRINT USING ""YS = "",10D,2X,9A,SD,4A";Ys,"MPa at",Tp,"C"
630 INPUT "ENTER E IN MPa",E
640 PRINT USING ""E = "",10D,2X,4A";E,"MPa"
650 PRINT
660 INPUT "ENTER B IN INCHES",B
670 PRINT USING ""B = "",3D,3D,2X,4A";B,"inch"
680 INPUT "ENTER BN IN INCHES",Bn
690 PRINT USING ""BN = "",3D,2X,4A";Bn,"inch"
700 INPUT "ENTER 2H IN ",H,$,H
710 PRINT USING ""H = "",3D,2X,4A";H,"inch"
720 INPUT "ENTER W ",W,$,W
730 PRINT USING ""W = "",3D,3D,2X,4A";W,"inch"
740 PRINT
750 INPUT "ENTER PR IN mm",Pr
760 PRINT USING ""PR = "",3D,2D,3X,4A";Pr,"mm"
770 INPUT "ENTER RS IN mm",Rs
780 PRINT USING ""RS = "",3D,2D,3X,4A";Rs,"mm"
790 INPUT "ENTER RT IN mm",Rt
800 PRINT USING ""RT = "",3D,2D,3X,4A";Rt,"mm"
810 INPUT "ENTER TU IN mm",Tu
820 PRINT USING ""TU = "",3D,2D,3X,4A";Tu,"mm"
830 PRINT
840 INPUT "ENTER N IN mm",N
850 PRINT USING ""N = "",3D,2D,3X,4A";N,"mm"
860 !
870 INPUT "ENTER TV IN mm, (= 0 for WELD-EMBRITTLED !!!)",Tv
880 PRINT USING "/K,3D,2D,2X,2A","TV = ",Tv,"mm"
890 !
900 !           **** Correc_0 ****
910 Cor_wc_0: !
920 Cor$:="Y"
930 INPUT "CORRECTIONS? (Y/N) Y",Cor$
940 IF L PC$(Cor$)="Y" THEN GOTO Start
950 !
960 !
970 Strt$:="Y"
980 :NP JT "STORE DATA ON DISKETTE? (Y/N) Y",Store$
990 IF L PC$(Store$)="Y" THEN GOSUB Store
1000 !
1010 !
1020 !
1030 !           ***** Print_dta *****

1040 Print_dta: !
1050 ! Prints input data if required
1060 GOSUB Hardcopy
1070 !
1080 !
1090 ! READ LABEL Label$ FROM Msus$
1100 !
1110 !
1120 GOSUB Specimen
1130 !
1140 !
1150 PRINT USING "/9X,""YIELD STRENGTH = "",5D,1X,3A,#";Ys,"MPa"
1160 PRINT USING "8X,""YOUNG'S MODULUS = "",7D,1X,3A,#";E,"MPa"
1170 PRINT USING "" INCR. TO YIELD (DYN) (Yso) = "",4D,1X,3A";Yso,"MPa"
1180 !
1190 !
1200 PRINT USING "/,""Pre-test specimen dimension measurements"""

```

```

1210 !
1220 !
1230 PRINT USING "/.9X,."B = "",3D.3D.2X.4A";B,"inch"
1240 PRINT USING "9X,."BN = "",3D.3D.2X.4A";Bn,"inch"
1250 PRINT USING "9X,."2H = "",3D.3D.2X.4A";H,"inch"
1260 PRINT USING "9X,."WT = "",3D.3D.2X.4A";Wt,"inch"
1270 PRINT
1280 PRINT USING "9X,."PR = "",3D.2D.2X.4A";Pr,"mm"
1290 PRINT USING "9X,."RS = "",3D.2D.2X.4A";Rs,"mm"
1300 PRINT USING "9X,."RT = "",3D.2D.2X.4A";Rt,"mm"
1310 PRINT USING "9X,."TU = "",3D.2D.2X.4A";Tu,"mm"
1320 PRINT USING "9X,."N = "",3D.2D.2X.7A;D.6D.2A";N,"mm"
1330 !
1340 PRINT USING "/.9X,K,3D.2D.2X.2A";"TV = ",Tv,"mm"
1350 !
1360 !
1370 PRINT USING "/,""Pre-test specimen dimension calculations"""
1380 !
1390 W=W*25.4-(Rs+Rt)/2
1400 Ao=Tu+(Rt-Rs)/2
1410 Ro=Ao/W
1420 !
1430 PRINT USING "/.9X,."W = "",4X,6D.2D.2X.2A";W,"mm"
1440 PRINT USING "9X,."Ao = "",4X,6D.2D.2X.2A";Ao,"mm"
1450 PRINT USING "9X,."Ao/w = "",4X,D.3D";Ro
1460 !
1470 !
1480 Fflow=(2.24*(1.72-.9*Ro+Ro^2)*(1-Ro)^.5)/(9.85-.17*Ro+11*Ro^2)
1490 PRINT USING "9X,."F(Ao/W) = "",4X,D.4D";Fflow
1500 !
1510 Ff=Pr+(Rt+Rs)/2
1520 Fflowrw=Ff/W
1530 PRINT USING "/.9X,."Clip gage is located at (FF/W) = "",4X,D.2D";Fflowrw
1540 !
1550 Fflow_cor=.25
1560 IF (Fflowrw > .98*Fflow_cor) AND (Fflowrw < 1.02*Fflow_cor) THEN
1570   GOTO Proceed
1580 ELSE
1590   PRINT "WARNING !!! Do not proceed to test this specimen"
1600   PRINT "Check input data, particularly PR, RS, and RT"
1610   PRINT "Clip gage location blocks are NOT located at FF/W = 0.25 !"
1620   DISP "INCORRECT (FF/W)! IF POSSIBLE CORRECT DATA BEFORE PROCEEDING"
1630   Que$="Y"
1640   INPUT "DO YOU WANT TO CORRECT INPUT DATA? (Y/N) Y";Que$
1650   IF UPC$(Que$)="Y" THEN GOTO Surr
1660   Que$="Y"
1670   INPUT "Do you want to QUIT now? (Y/N) Y";Que$
1680   IF UPC$(Que$)="Y" THEN GOTO Finish
1690 END IF
1700 !
1710 !
1720 Proceed: !
1730 IF Tv < > 0 THEN
1740   Ebel=(Rt-Rs)/2+Tv
1750   PRINT USING "/.9X,."EBCL= "",10X,4D.2D.4A";Ebel," mm"
1760 END IF
1770 !
1780 !
1790 PRINT USING "/.K,."Pre-test loading calculations"
1800 !

```

```

1810 ! Fact is in mils, W is in mm
1820 Fact=1.E+3*(Ys*W/25.4*(Bn/B))^.5)/(E*Fact)
1830 Deltacinit=.69*Fact
1840 !
1850 Num_cycles=10
1860 IF Tv< > 0 THEN
1870   Num_cycles=1
1880   PRINT USING "/.K./";"This is a DUPLEX specimen, only one loading cycle
needed"
1890 END IF
1900 FOR Cycle=1 TO Num_cycles
1910   Del_max=(1+.25*(Cycle-1))*Deltacinit
1920 !
1930 ! 100 mils = 10 volts
1940 Volts=.1*Del_max
1950 PRINT USING "11X,2FOR CYCLE No. =",SD,". maximum COD =",SD.D," m
ils",SD.2D," Volts";Cycle,Del_max,Volts
1960 NEXT Cycle
1970 Deltamax=1.5*Fact
1980 !
1990 IF Tv=0 THEN PRINT USING "11X,2Probable maximum COD for useful results"
",SD.D,". Mils",Deltamax
2000 !
2010 Cor$="Y"
2020 INPUT "DO YOU WANT TO MAKE CORRECTIONS IN THE STORED DATA? (Y/N) Y",Cor$
2030 IF Cor$="Y" THEN GOTO Start
2040 !
2050 Print$="Y"
2060 INPUT "DO YOU WANT TO PRINT OUT DATA (SCREEN/PRINTER)? (Y/N) Y",Print$
2070 IF UPC$(Print$)="Y" THEN GOTO Print_dta
2080 !
2090 Ptc$="Y"
2100 INPUT "DO YOU WANT TO DO POST TEST CALCULATIONS? (Y/N) Y",Ptc$
2110 IF UPC$(Ptc$)="Y" THEN Post_tcalc
2120 GOSUB Hardcopy
2130 Que$="Y"
2140 INPUT "DO YOU WANT TO DO MORE PRE TEST CALCULATIONS? (Y/N) Y",Que$
2150 IF UPC$(Que$)="Y" THEN Begin
2160 Que$="N"
2170 INPUT "DO YOU WANT TO STORE THE DATA (Y/N) N",Que$
2180 IF UPC$(Que$)="Y" THEN GOSUB Store
2190 Que$="Y"
2200 INPUT "DO YOU WANT TO DO MORE? (Y/N) Y",Que$
2210 IF UPC$(Que$)="Y" THEN GOTO Begin
2220 GOTO Finish
2230 STOP
2240 !
2250 !
2260 !           ***** Post_tcalc *****
2270 Post_tcalc: !
2280 PRINTER IS !
2290 ! Check if only pre-test data was stored, but no post-test data
2300 Pstsdta$="Y"
2310 INPUT "HAS POST TEST DATA FOR THIS TEST BEEN PREVIOUSLY STORED? (Y/N) Y",P
stsdta$
2320 IF UPC$(Pstsdta$)="Y" THEN
2330 !
2340 ! CODs have been stored in inches. Initialize variables R1,R3,P4 & P5
2350 ! for printing out in mils.
2360 !

```

```

2370 R1 = Deltapsb1*1.E+3
2380 R3 = Sdeltap*1.E+3
2390 P4 = Deltao*1.E+3
2400 P5 = Deltaa*1.E+3
2410 GOTO Pr_dta2
2420 END IF
2430 !
2440 !           **** Correc_1 ****
2450 ! Post-test data input from keyboard
2460 Correc_1: !
2470 INPUT "ENTER W-Aa AT -BN/4 IN mm",Waat
2480 PRINT USING "",W-Aa AT -BN/4 = "",4X,3D,2D,2X,4A";Waai,"mm "
2490 INPUT "ENTER W-Aa AT MIDLINE IN mm",Waam
2500 PRINT USING "",W-Aa AT MIDLINE = "",4X,3D,2D,2X,4A";Wasam,"mm "
2510 INPUT "ENTER W-Aa AT +BN/4 IN mm",Waab
2520 PRINT USING "",W-Aa AT +BN/4 = "",4X,3D,2D,2X,4A";Waab,"mm "
2530 PRINT
2540 PRINT
2550 INPUT "ENTER R1 IN mils",R1
2560 PRINT USING "",R1 = "",2X,4D.D," mils",R1
2570 INPUT "ENTER R3 IN mils",R3
2580 PRINT USING "",R3 = "",2X,4D.D," mils",R3
2590 INPUT "ENTER P4 IN mils",P4
2600 PRINT USING "",P4 = "",2X,4D.D," mils",P4
2610 INPUT "ENTER P5 IN mils",P5
2620 PRINT USING "",P5 = "",2X,4D.D," mils",P5
2630 PRINT
2640 INPUT "ENTER Pmax IN pounds",Pmax
2650 PRINT USING "",Pmax = "",4X,6D,2X,4A";Pmax,"lbs "
2660 INPUT "ENTER Pmin IN pounds",Pmin
2670 PRINT USING "",Pmin = "",4X,6D,2X,4A";Pmin,"lbs "
2680 Cor$ = "Y"
2690 INPUT "CORRECTIONS? (Y/N) Y",Cor$
2700 IF Cor$ = "Y" THEN
2710   PRINT USING '@'
2720   GOTO Correc_1
2730 END IF
2740 !
2750 !
2760 ! For compatibility with previous data stored on diskettes, CODs
2770 ! are stored in inches
2780 Deltapsb1 = R1*1.E-3
2790 Sdeltap = R3*1.E-3
2800 Deltao = P4*1.E-3
2810 Deltaa = P5*1.E-3
2820 !
2830 !
2840 Store$ = "Y"
2850 INPUT "STORE DATA ON DISKETTE? (Y/N) Y",Store$
2860 IF Store$ = "Y" THEN GOSUB Store
2870 :
2880 !           **** Pr_dta2 ****
2890 Pr_dta2: !
2900 GOSUB Hardcopy
2910 !
2920 GOSUB Specimen
2930 !
2940 !
2950 PRINT USING "/,""Post-test crack arrest measurements"""
2960 PRINT USING "/,9X,""W-Aa AT -BN/4 = "",4X,3D,3D,"" mm""",Waat

```

```

2970 PRINT USING "9X,2W-Aa AT MIDLINE = ",4X,3D,3D," mm";Waam
2980 PRINT USING "9X,2W-Aa AT -BN/4 = ",4X,3D,3D," mm";Waab
2990 !
3000 !
3010 PRINT USING "/9X,2Zero load disp. offset at end of cycle 1 (R1) = "
  *4D.D,2W-Aa;R1
3020 PRINT USING "9X,2Total disp. offset at end of cycle n-1 (R3) = "
  4D.D,2W-Aa;R3
3030 PRINT USING "9X,2Displacement at onset of unstable crack growth (P4) = "
  4D.D,2W-Aa;P4
3040 PRINT USING "9X,2Displacement approx. 1 s after arrest (P5) = "
  4D.D,2W-Aa;P5
3050 !
3060 !
3070 PRINT USING "/9X,2Pmax = ",6D,2X,3A;Pmax," lbs"
3080 PRINT USING "9X,2Pmin = ",6D,2X,3A;Pmin," lbs"
3090 Rp=(Pmax-Pmin)/Pmax
3100 PRINT USING "9X,2(Pmax-Pmin)/Pmax = ",5D,2D;Rp
3110 IF Rp > .5 THEN
3120   PRINT USING "9X,2Load drop guideline met"
3130 ELSE
3140   PRINT *****Load drop guideline NOT met*****
3150 END IF
3160 !
3170 !
3180 !
3190 PRINT USING "/2Post-test crack arrest calculations"
3200 !
3210 W_aa_avg=(Waam+Waat+Waab)/3
3220 PRINT USING "/9X,2Length of remaining ligament W-Aa(average) = "
  4D.D,2W_aa_avg
3230 !
3240 ! Aa = arrested crack length per ASTM Paragr. 6.6
3250 Aa=W-W_aa_avg
3260 Crakjmp=Aa-Ao
3270 PRINT USING "/9X,2Crack jump Aa - Ao",24X,2W-Aa;Crakjmp," m"
  m
3280 !
3290 !
3300 ! Do and Da are 'net' CODs per ASTM (in m)
3310 Do=(Deltao-Sdeltap)*25.4 / E-3
3320 ! For duplex specimens, there is only one unload cycle
3330 ! $ Deltapab1 (R1) is equal to Sdeltap (R3)
3340 !
3350 Da=.5*(Deltao + Deltaao-Deltapab1-Sdeltap)*25.4*E-3
3360 Rf=Aa/W
3370 Fafw=(2.24*(1.72-.9*Rf+Rf^2)*(1-Rf)^.5)/(9.85-.17*Rf+1*Rf^2)
3380 Fac=E*(B/(Bn*W*.001))^.5
3390 Ko=Do*Faow*Fac
3400 Kf=Da*Fafw*Fac
3410 !
3420 !
3430 PRINT USING "/9X,2Net COD at initiation per ASTM = ",2X,1D,3DE,2W-Aa;D
  0
3440 PRINT USING "9X,2Net COD at arrest per ASTM = ",2X,1D,3DE,2W-Aa;Da
3450 !
3460 !
3470 PRINT USING "/9X,2Arrested crack length (Aa) = ",5D,D,2W-Aa;" mm
  ***,Aa
3480 PRINT USING "9X,2Fractional arrested crack length (Aa/w) = ",4X,3D;Rf

```



```

4020 ELSE
4030 PRINT ****THICKNESS CRITERION **C** NOT MET****
4040 END IF
4050 !
4060 !
4070 !
4080 !      dddddd ddd ddd
4090 !      d Crack jump length criteria (D, and (E)) - d
4100 !      eeeeeeee eeee eeee eeee eeee eeee eeee eeee eeee eeee eeee
4110 !
4120 !
4130 !
4140 !
4150 !
4160 IF Tv<3 THEN
4170 PRINT USING "/1X, **Crack jump Aa - Au", 20X, " - ", 1X, 3D, D, 1X, 2A, #":Crak
kjmp, "mm"
4180 PRINT USING "17X, **ASTM 2N", 36X, " - ", 3D, D, 1X, 2A":Nval, "mm"
4190 IF Crakjmp > Nval THEN
4200 PRINT USING "1X, K", "WELD EMBRITTLED SPEC. CRACK JUMP-LENGTH CRITERI
ON **D** MET"
4210 ELSE
4220 PRINT ****WELD EMBRITTLED SPEC. CRACK JUMP-LENGTH CRITERION **D** NO
T MET****
4230 END IF
4240 !
4250 !
4260 PRINT USING "/1X, **Crack jump Aa - Au", 20X, " - ", 1X, 3D, D, 1X, 2A, #":Crak
kjmp, "mm"
4270 PRINT USING "17X, **Min. crack jump (Ku/YS)^2/2PI", 12X, " - ", 3D, D, 1X,
2A":Minjmp, "mm"
4280 IF Crakjmp > Minjmp THEN
4290 PRINT USING "1X, K", "WELD EMBRITTLED SPEC. CRACK-JUMP LENGTH CRITERIO
N **E** MET"
4300 ELSE
4310 PRINT ****CRACK-JUMP LENGTH CRITERION **L** NOT MET****
4320 END IF
4330 !
4340 ELSE      ! DUPLEX SPECIMEN CRITERION 'D' + 'E'
4350 !
4360 !      ('D' & 'E' ARE REPLACED WITH A SINGLE ONE)
4370 Dpxjmp = Aa - Ebcl
4380 PRINT USING "/1X, **Crack jump beyond EB weld (Aa - EBCL) = ", 1X, 3D, D, 2
X, 4A, #":Dpxjmp, "mm"
4390 !
4400 !
4410 Bnm = Bn * 25.4
4420 PRINT USING "14X, **Specimen width at notch (Bn) = ", D, 3D, " inches = "
, 3D, D, " mm"; Bn, Bnm
4430 IF Dpxjmp > Bnm THEN
4440 PRINT "DUPLEX SPECIMEN CRACK JUMP CRITERION **D** + **E** MET"
4450 ELSE
4460 PRINT ****DUPLEX SPEC. CRACK JUMP CRITERION **D** + **E** NOT MET**
*
4470 END IF
4480 END IF
4490 ! END OF CRITERIA 'D' & 'E' DETERMINATIONS
4500 !
4510 !
4520 Cor$ = "Y"

```

```

4530 INPUT "DO YOU WANT TO CORRECT POST TEST DATA (Y/N) Y",Cor$
4540 IF UPC$(Cor$)= "Y" THEN
4550   PRINTER IS 1
4560   GOTO Corre_1
4570 END IF
4580 Ques$ = "Y"
4590 INPUT "DO YOU WANT TO DO MORE (Y/N) Y",Ques$
4600 IF UPC$(Ques$)= "Y" THEN Begin
4610   GOTO Finish
4620 !
4630 !
4640 !           ***** Store *****
4650 Store: !
4660 ! ON ERROR GOSUB Error
4670 DISP "INSERT INITIALIZED AND LABELLED DISC IN DRIVE AND PRESS CONTINUE"
4680 PAUSE
4690 !
4700 READ LABEL Label$ FROM Msus$
4710 !
4720 !
4730 ! Data stored = 1 (TRUE) if data has been previously stored.
4740 ON ERROR GOTO 4770 !*****
4750 IF Data_stored THEN PUROE File$&Msus$
4760 GOTO 4810 !*****
4770 IF (ERRN = 56) THEN GOTO 4810 !NO PROBLEM !*****
4780 GOTO Error_sub !*****
4790 !
4800 ! There are 26 variables. Round up to 30
4810 Nrec = 1
4820 Nvar = 30
4830 Nbytes = 8*Nvar
4840 CREATE BDAT File$&Msus$,Nrec,Nbytes
4850 ASSIGN @Path TO File$&Msus$,FORMAT OFF
4860 !
4870 ! Note: Bmet,Hmet,Wmet, and Wn are not used, but for compatibility
4880 ! with previously written output, its location is reserved.
4890 ! It can be used for other purposes.
4900 ! Following line is one used to date (July 8, 1989)
4910 ! OUTPUT @Path,File$,Ys,Tp,E,B,Bmet,Bn,H,Hmet,Wt,Wmet,Wn,Pr,Rs,Rt,Tu,Tv,N
        ,Waam,Waat,Waab,Deltapsb1,Sdeltap,Deltao,Deltaa,Pmax,Pmin
4920 OUTPUT @Path,File$,Ys,Tp,E,B,Test ,date,Bn,H,Hmet,Wt,Wmet,Wn,Pr,Rs,Rt,Tu,T
        v,N,Waam,Waat,Waab,Deltapsb1,Sdeltap,Deltao,Deltaa,Pmax,Pmin
4930 ASSIGN @Path TO *
4940 Data_stored = 1
4950 DISP "DATA STORAGE SUCCESSFUL"
4960 WAIT 1
4970 DISP "
4980 RETURN
4990 !
5000 !           ***** Load *****
5010 Load:!
5020 !
5030 !
5040 INPUT "SPECIMEN NO.",File$
5050 READ LABEL Label$ FROM Msus$
5060 !
5070 ASSIGN @Path1 TO File$&Msus$,FORMAT OFF
5080 ! Bmet, Hmet, Wmet, & Wn is no longer used, but location is kept for com
        patability
5090 ! See comment in Store routine

```

```

5100 READ LABEL Label$ FROM Msus$
5110 ENTER @Path1;File$,Ys,Tp,E,B/Test_date,Bn,H,HiMet,Wt,WiMet,Wn,Pr,Rs,Rt,Tu,T
v,N,Waam,Waab,Deltapsb1,Sdelup,Deltaa,Pmax,Pmin
5120 ASSION @Path1 TO *
5130 ! If data input from storage was successful, then data is actually
5140 ! there. Initialize Data_stored = 1 (TRUE)
5150 Data_stored=1
5160 DISP "DATA LOAD FROM DISK '&Msus$&' '&Label$&' SUCCESSFUL"
5170 WAIT 3
5180 RETURN
5190 !
5200 !
***** Advance *****
5210 Advance: !
5220 PS="N"
5230 INPUT "ADVANCE PAPER? (Y/N) N",PS
5240 IF UPC$(PS)="Y" THEN PR'IT USING "@"
5250 RETURN
5260 !
5270 !
5280 !
***** Hardcopy *****
5290 Hardcopy: !
5300 H$="N"
5310 INPUT "NEED HARDCOPY? (Y/N) N",H$ 
5320 IF UPC$(H$)="Y" THEN
5330  PRINTER IS 9
5340  GOSUB Advance
5350  PRINT USING "K,2X,K,3X,K,2X,K","CRACK ARREST COM , JTER CODE CA_TEST "&Ba
nner$, "Time of this run: ",DATE$(TIMEDATE),TIME$(TIMEDATE)
5360 ELSE
5370  PRINTER IS 1
5380 END IF
5390 RETURN
5400 !
5410 !
***** Error_sub *****
5420 Error_sub: !
5430 PRINT ERRM$
5440 PRINT "POSSIBLE INPUT DATA ERROR: CHECK INPUT"
5450 DISP "HIT CONTINUE"
5460 PAUSE
5470 GOTO Begin
5480 !
5490 !
***** Specimen *****
5500 Specimen: !
5510 PRINT USING "2,I1X,2SPECIMEN NO. **,7A,#";File$
5520 IF Tv<>0 THEN
5530  PRINT USING "*** (DUPLEX)**,#"
5540 ELSE
5550  PRINT USING "*** (WELD EMBRITTLED)**,#"
5560 END IF
5570 !
5580 !
5590 PRINT USING "9X,2TEST TEMPERATURE = **,4D,1X,A,#";Tp,"C"
5600 PRINT USING "3X,K,#";" from disk "&Label$
5610 PRINT USING "3X,2TEST DATE = **,1X,6Z";Test_date
5620 RETURN
5630 !
5640 !
***** Dpx_we *****
5650 ! Dpx_we: ! This subprogram prints out whether specimen
5660 ! is a duplex or weld-embrittled type and value of Tv
5670 ! Note that Tv is set equal to zero for weld-embrittled

```

```
5680      ! specimens, and is the measured value for duplex specimen
5690! IF Dpxspm$="Y" THEN
5700! PRINT USING "/,";"This is a DUPLEX specimen***"
5710! ELSE
5720! PRINT USING "/.K";"This is a WELD EMBRITTLED specimen and TV is set = 0
by program"
5730! END IF
5740! PRINT USING "/.9X.K.3D.2D.2X.2A";"Tv = ",Tv,"mm"
5750! RETURN
5760 !
5770 !          **** Finish ****
5780 Finish:   ! End of Program
5790 PRINTER IS 1
5800 DISP "Crack arrest program ended."
5810 STOP
5820 END
```

APPENDIX C

YOUNG'S MODULUS
USED IN THE EVALUATION OF THE CRACK ARREST DATA

Young's modulus is used to calculate the stress intensity factors K_o and K_s , both of which are directly proportional to the value of E used [see Eq. (C.1)]. Young's modulus together with the yield strength are used to calculate the load increment for the loading and unloading cycles for weld-embrittled type specimens as well as the validity criteria.

The Young's modulus used to evaluate both unirradiated and irradiated crack arrest data is calculated from the following expression [1]:

$$E = 207.2 + 0.0571T , \quad (C.1)$$

where E = Young's modulus in GPa, and T = temperature in °C. Reference [1] in turn cites Subsection NB 2300, ASME Boiler and Pressure Vessel Code, Sect. III. The current version of NB 2300 does not give this equation, so it is of interest to compare it with values in the recent edition of the ASME Code [2]. Figure C.1 and Table C.1 compare Young's modulus calculated at the tabular temperatures given in the American Society of Mechanical Engineers Code. In the temperature range used for testing both the unirradiated and irradiated crack arrest specimens, -75 to 100°C, Eq. (C.1) gives values that are about 2% higher than those in Ref. [2]. It is planned to measure Young's modulus for the weldments and reanalyze the crack-arrest data.

Table C.1. Comparison of Young's modulus calculated using values given in the ASME Code and Eq. (C.1)

Temperature (°C)	Young's modulus (GPa)		% Difference [(E-A)/A]
	ASME (A)	EPRI (E)	
-198	216.5	218.5	1
-129	212.4	214.6	1
-73	208.2	211.4	2
21	203.4	206.0	1
93	198.6	201.9	2
149	195.1	198.7	2
204	191.0	195.5	2
260	188.2	192.4	2
316	184.1	189.2	3
371	175.8	186.0	6
427	166.9	182.9	10

NOTE:

ASME = American Society of Mechanical Engineers
 EPRI = Electric Power Research Institute

REFERENCES FOR APPENDIX C

1. W. L. Server, J. W. Scheckerd, and R. A. Wullaert, Electric Power Research Institute, Palo Alto, Calif., *Fracture Toughness Data for Ferritic Nuclear Pressure Vessel Materials*, EPRI NP-119, April 1976.
2. ASME *Boiler and Pressure Vessel Code*, Sect. III, Div. 1, Appendix I, Table I-6.0, American Society of Mechanical Engineers, July 1, 1989.

APPENDIX D

TYPICAL OUTPUT FROM CA TEST
FOR A WELD-EMBRITTLED AND DUPLEX SPECIMEN

CRACK ARREST COMPUTER CODE CA_TEST Version 5.1 Revised February 14, 1990 Time on disk rec'd 12 Sep 1990 16:02:48

SPECIMEN NO. A72W48 (WELD EMBRITTLED) TEST TEMPERATURE = -30 C from disk CAN01 TEST DATE = 000
YIELD STRENGTH = 539 MPa YOUNG'S MODULUS = 208900 MPa (INCR. TO YIELD (DYN) (Y_{so}) = 205 MPa

Pre-test specimen dimension measurements

B = 1.000 inch
BN = .743 inch
2H = 5.999 inch
WT = 6.000 inch

PR = 6.35 mm
RS = 10.69 mm
RT = 40.55 mm
TU = 28.33 mm
N = 1.38 mm

TV = 0.00 mm

Pre-test specimen dimension calculations

W = 126.78 mm
Ao = 43.27 mm
Ao/w = .341
F(Ao/W) = .2511

Clip gage is located at (FF/W) = .25

Pre-test loading calculations

FOR CYCLE No. = 1,	maximum COD = 30.5 mils	3.05 Volts
FOR CYCLE No. = 2,	maximum COD = 38.1 mils	3.81 Volts
FOR CYCLE No. = 3,	maximum COD = 45.8 mils	4.58 Volts
FOR CYCLE No. = 4,	maximum COD = 53.4 mils	5.34 Volts
FOR CYCLE No. = 5,	maximum COD = 61.0 mils	6.10 Volts
FOR CYCLE No. = 6,	maximum COD = 68.6 mils	6.86 Volts
FOR CYCLE No. = 7,	maximum COD = 76.3 mils	7.63 Volts
FOR CYCLE No. = 8,	maximum COD = 83.9 mils	8.39 Volts
FOR CYCLE No. = 9,	maximum COD = 91.5 mils	9.15 Volts
FOR CYCLE No. = 10,	maximum COD = 99.1 mils	9.91 Volts

Probable maximum COD for useful results 66.3 Mils

CRACK ARREST COMPUTER CODE CA_TEST Version 5.1 Revised February 14, 1990 Time of this run: 12 Sep 1990 16:03:09

SPECIMEN NO. A72W48 (WELD EMBRITTLED) TEST TEMPERATURE = -30 C from disk CAN01 TEST DATE = 0000

Post-test crack arrest measurements

W-Aa AT +BN/4 = 35.192 mm
W-Aa AT MIDLINE = 34.573 mm.
W-Aa AT -BN/4 = 33.037 mm

Zero load disp. offset at end of cycle 1 (R1) = 1.5 mils
Total disp. offset at end of cycle n-1 (R3) = 3.0 mils
Displacement at onset of unstable crack growth (P4) = 47.8 mils
Displacement approx. .1 s after arrest (P5) = 51.4 mils

Pmax = 12000 lbs
Fmin = 750 lbs
(Pmax-Pmin)/Pmax = .94
Load drop guideline met

Post-test crack arrest calculations

Length of remaining ligament W-Aa(average) = 34.3 mm

Crack jump Aa - Ao = 49.2 mm

Net COD at initiation per ASTM = 1.138E-03 m
Net COD at arrest per ASTM = 1.203E-03 m

Arrested crack length (Aa) = 92.5 mm
Fractional arrested crack length (Aa/w) = .730
Geometry factor F(Aa/W) = .1193

* Ko = 194 MPa.m^0.5 *
* Ka = 98 MPa.m^0.5 *

VALIDITY CRITERIA PER ASTM 1221-88, PARA. 9.3

ACTUAL VALUES

ASTM CRITERIA MINIMUMS

Length of remaining ligament (W - Aa) = 34.3 mm
REMAINING LIGAMENT CRITERION "A" MET

Remaining ligament (0.15W) = 19.0 mm

Length of remaining ligament (W - Aa) = 34.3 mm
REMAINING LIGAMENT CRITERION "B" MET

Remaining ligament 1.25*[Ka/(YS + YSo)]^2 = 21.5 mm

Specimen width B = 1.000 inches = 25.4 mm
THICKNESS CRITERION "C" MET

Specimen width [Ka/(YS + YSo)]^2 = 17.2 mm

Crack jump Aa - Ao = 49.2 mm ASTM 2N = 22.8 mm
WELD EMBRITTLED SPEC. CRACK JUMP-LENGTH CRITERION "D" MET

Crack jump Aa - Ao = 49.2 mm Min. crack jump (Ko/YS)^2/2PI = 20.7 mm
WELD EMBRITTLED SPEC. CRACK-JUMP LENGTH CRITERION "E" MET

CRACK ARREST COMPUTER CODE CA TEST Version 3.1 Revised February 14, 1990 Time of this run: 12 Sep 1990 16:06:07

SPECIMEN NO. A72W57 (DUPLEX) TEST TEMPERATURE = 21 C from disk CAN02 TEST DATE = 080000

YIELD STRENGTH = 496 MPa YOUNG'S MODULUS = 206100 MPa INCR. TO YIELD (DYN) (Y_{SO}) = 205 MPa

Pre-test specimen dimension measurements

B = 1.298 inch

BN = .976 inch

2H = 6.000 in.

WT = 6.000 in.-in

PR = 6.35 mm

RS = 9.40 mm

RT = 41.13 mm

TU = 27.07 mm

N = 1.43 mm

TV = 42.66 mm

Pre-test specimen dimension calculations

W = 127.14 mm

Ao = 42.94 mm

Ao/w = .338

F(Ao/W) = .2525

Clip gage is located at (FF/W) = .25

EBCL = 58.53 mm

Pre-test loading calculations

This is a DUPLEX specimen, only one loading cycle needed

FOR CYCLE No. = 1, maximum COD = 28.5 mils 2.85 Volts

CRACK ARREST COMPUTER CODE CA TEST Version 5.1 Revised February 14, 1990 Time of this run: 12 Sep 1990 16:05:03

SPECIMEN NO. A72W57 (DUPLEX) TEST TEMPERATURE = 21 C from disk CAN02 TEST DATE = 000000

Post-test crack arrest measurements

W-A_x AT +BN/4 = 54.341 mm
 W-A_a AT MIDLINE = 54.484 mm
 W-A_a AT -BN/4 = 56.693 mm

Zero load disp. offset at end of cycle 1 (R1) = .7 mils
 Total disp. offset at end of cycle n-1 (R3) = 0.0 mils
 Displacement at onset of unstable crack growth (P4) = 50.5 mils
 Displacement approx. 1 s after arrest (P5) = 51.8 mils

P_{max} = 17600 lbs
 P_{min} = 1000 lbs
 (P_{max}-P_{min})/P_{max} = .94
 Load drop guideline met

Post-test crack arrest calculations

Length of remaining ligament W-A_a(average) = 55.2 mm

Crack jump A_a - A₀ = 29.0 mm

Net COD at initiation per ASTM = 1.283E-03 m
 Net COD at arrest per ASTM = 1.290E-03 m

Arrested crack length (A_a) = 72.0 mm
 Fractional arrested crack length (A_a/w) = .566
 Geometry factor F(A_a/W) = .1701

 * Ko = 216 MPa.m^{0.5} *
 * Ka = 146 MPa.m^{0.5} *

VALIDITY CRITERIA PER ASTM 1221-88, PARA. 9.3

ACTUAL VALUES

ASTM CRITERIA MINIMUMS

Length of remaining ligament (W - A_a) = 55.2 mm
 REMAINING LIGAMENT CRITERION 'A' MET

Remaining ligament (0.15W) = 19.1 mm

Length of remaining ligament (W - A_a) = 55.2 mm
 REMAINING LIGAMENT CRITERION 'B' MET

Remaining ligament 1.25*[Ka/(YS + YSo)]^2 = 54.5 mm

Specimen width B = 1.298 inches = 33.0 mm
 THICKNESS CRITERION 'C' NOT MET

Specimen width [Ka/(YS + YSo)]^2 = 43.6 mm

Crack jump beyond EB weld (A_a - EBCL) = 13.4 mm Specimen width at notch (B_n) = .976 inches = 24.8 mm
 DUPLEX SPEC. CRACK JUMP CRITERION 'D' + 'E' NOT MET

APPENDIX E
STRIP CHARTS AND FRACTURE SURFACES

This page intentionally left blank.



Specimen Identification = A72W06
Test Temperature = 90°C
Crack Arrest Toughness = 160 MPa·J/m
Length of Remaining Ligament = 67.3 mm

SPEC. # A72W06 DATE: Oct. 30, 1979 Normal Inverted Non Radiated

TEST TEMP. 90°C CLIP GAGE
CAG#2

VOLTAGES:

Excitation - 6.598

During calibration-

0.0 75 7.55

25 2.58% 100

50 5.03

In specimen at zero - 0.30 (+)

MACHINE SETTINGS

Load Range ± 120 KIPS


Strain Range $\pm 1.20 \times 10^{-4}$


Stroke Range ± 1

X-Y CHART SETTINGS

X = $1 \frac{1}{4}$


Y = $1 \frac{1}{4}$





Specimen Identification	=	A72W09
Test Temperature	=	90 °C
Crack Arrest Toughness	=	120 MPa·m
Length of Remaining Ligament	=	48.0 mm

SPEC. # A72 w/ Ø9		DATE: 9-25-89		Normal Inverted		Non-Irradiated	
TEST TEMP.	90 °C	CLIP GAGE	MACHINE SETTINGS				
VOLTAGES:		# CAGE 02	Load Range = ± 10 KIPS				
Excitation - G. 54.3			Strain Range = ± 20%				
During calibration-			Stroke Range = ± 1				
0.0	75		X-Y CHART SETTINGS				
25-2.449 100			X = 0.5 mm				
SP - 4.975			Y = 0.5 mm / 1.0 mm / 20				
In specimen at zero- + 0.680							



72W10



Oak Ridge National Laboratory

Materials And Ceramics Division

6

Specimen Identification	-	A72W10
Test Temperature	-	75°C
Crack Arrest Toughness	-	101 MPa·m
Length of Remaining Ligament	-	49.2 mm

SPEC. #	AT25W/C	DATE: 9/22/69	Nominal	Inverted	Gas Irradiated
TEST TEMP.	75°C	CLIP GAGE # AGC2	MACHINE SETTINGS		
VOLTAGES:			Lens Range = $\pm 2\pi$ 275		
Excitation -	6.543		Strain Range = $\pm 2.32\%$		
During calibration-			Strain Range = $\pm 1\%$		
0 0.0	75				
25 -2.47	800				
50 -24.755					
In specimen at zero-	-0.700				

37.6 mmile $\times \frac{50}{295} = 38$


→ +352.5 Open

X-Y CHART SETTINGS

X= 6.5%

Y= c. 5%

In specimen at zero -0.700



72w11



Specimen Identification - A72W11
Test Temperature - 75°C
Crack Arrest Toughness - 133 MPa·m
Length of Remaining Ligament - 61.1 mm


72w11



96

Specimen Identification - A72W11
Test Temperature - 75°C
Crack Arrest Toughness - 133 MPa·m
Length of Remaining Ligament - 61.1 mm

SPEC. # A72w11	DATE: Oct. 25, 1975	Normal / Inverted	Non - Irradiated		
TEST TEMP. 75 °C	CLIP GAGE # CAG 82	MACHINE SETTINGS			
VOLTAGES:					
Excitation - 6.588	Load Range $\pm \pm 20$ KIPS				
During calibration-	Strain Range $\pm \pm 20\%$				
0 0.0 75 - 7.57	Stroke Range = ± 1				
25 - 2.53 100 - 10.09	X-Y CHART SETTINGS				
50 - 5.04	X = $1 \frac{1}{4}$				
In specimen at zero- -0.299 (c.c.)	Y = $1 \frac{1}{2}$				



67

72w13

MILLIMETERS

0 10 20 30 40 50 60 70 80 90 100


Oak Ridge National Laboratory

Materials And Ceramics Division

86

Specimen Identification	-	A72W13
Test Temperature	-	60°C
Crack Arrest Toughness	-	81 MPa·m
Length of Remaining Ligament	-	44.2 mm

72w13




Dak Ridge National Laboratory


Maths And Ceramics Division

86


Specimen Identification	-	A72W13
Test Temperature	-	60°C
Crack Arrest Toughness	-	81 MPa·m
Length of Remaining Ligament	-	44.2 mm

SPEC. #	A72_w13	DATE:	2/3/1969	<u>Normal</u>	<u>Inverted</u>	<u>Non-Irradiated</u>
TEST TEMP.	60°C	CLIP GAGE	# AC 02	MACHINE SETTINGS		
VOLTAGES:				Load Range = 12.0 kN		
Excitation - K. SFG				Strain Range = $\pm 2.0 \%$		
During calibration-				Stroke Range = $\pm 1.0 \%$		
0 - 2.5	75	X-Y CHART SETTINGS				
25 - 2.5	100					
50 - 5.0		X = 0.5 %/in				
In specimen at zero-	-0.27	(2.2)	Y = 0.5 %/in			





Specimen Identification	=	A72W14
Test Temperature	=	100 °C
Crack Arrest Toughness	=	144 MPa·m
Length of Remaining Ligament	=	61.5 mm



Specimen Identification	=	A72W14
Test Temperature	=	100°C
Crack Arrest Toughness	=	164 MPa·m
Length of Remaining Ligament	=	61.5 mm

SPEC. # 472-14 DATE: Dec. 29, 1987 Normal Unloaded Non-Irradiated

TEST TEMP. 100°⁴ CLIP GAGE
VOLTAGES: # CAS 22 MACHINE SETTINGS

Excitation - 6.5 mV Load Range ± 20%


During calibration Strain Range ± 25%


0.00 - 25 - 7.5% Strike Rate ± 1

25-250 100 -40.12 X= 1 1/2

SP -5.705 Y= 1 1/2

In specimen at zero - 1 1/2 (δ o)






102

Gas Phase Ceramic Laboratory

Metallic And Ceramic Structures

Specimen Identification	-	A72W15
Test Temperature	-	75°C
Crack Arrest Toughness	-	114 MPa·m
Length of Remaining Ligament	-	47.1 mm



102

Los Alamos National Laboratory

Materials And Ceramics Division

Specimen Identification	-	A72W15
Test Temperature	-	75°C
Crack Arrest Toughness	-	114 MPa·m
Length of Remaining Ligament	-	47.1 mm

SPEC. # A72w15 DATE: 9-19-89 Normal / Inverted Non-Irradiated
 TEST TEMP. 75°C CLIP GAGE #CAG 02
 VOLTAGES:
 Excitation - 6.543
 During calibration-
 0 0.00 75
 25 100
 50 -4.975
 In specimen at zero- +0.234

MACHINE SETTINGS

Load Range = ± 10 KIPS

Strain Range = $\pm 20\%$

Stroke Range = ± 1


X-Y CHART SETTINGS

X= 1.0 v/in

Y= 2.0 v/in


Calving Settings
36°

Loadinq Rate 1.0 mm/min 1.02
1500 SEC. 30 mm





72w16



Coin Ridge National Laboratory

Metals And Ceramics Division

specimen identification	-	A72W16
Test Temperature	-	76°C
Crack Arrest Toughness	-	102 MPa·m
Length of Remaining Ligament	-	55.0 mm

72W16





Oak Ridge National Laboratory

Marble And Ceramics Division

specimen identification	-	A72W16
Test Temperature	-	76°C
Crack Arrest Toughness	-	102 MPa·m
Length of Remaining Ligament	-	55.0 mm


SPEC. # A72-116		DATE: 9-21-69	Normal (Inverted)	Non-Irradiated
TEST TEMP.	75°C	CLIP GAGE	From Specimen	
VOLTAGES:	# CAC 92	MACHINE SETTINGS	Load Range $\pm 10\%$	
Excitation -	6.543	Strain Range $\pm 2.0\%$	Angular $\pm 150^\circ$	
During calibration-		Stroke Range $\pm \frac{1}{4}$	Angular $\pm 30^\circ$	
0 0.0	75	X-Y CHART SETTINGS	Specimen 34.25 mm	
2. -2.497	196	X = 0.5' / sec	34.00 lb/in	
50 . 4.997		Y = 0.5' / sec		
In specimen at zero-	+0.776			





Specimen Identification = A72W17
Test Temperature = 100 °C
Crack Arrest Toughness = 118 MPa·J/m
Length of Remaining Ligament = 53.8 mm

72W17




901

MILLIMETERS
0 10 20 30 40 50 60 70 80 90 100
DAE Ridge National Laboratory
Metals And Ceramics Division

Specimen Identification	-	A72W17
Test Temperature	-	100°C
Crack Arrest Toughness	-	118 MPa·m
Length of Remaining Ligament	-	53.8 mm

SPEC. #	P72W/7	DATE	2/27/67	Specimen	Inverted	Irradiated
TEST TEMP.	40°C	CLIP GAGE	#	MACHINE SETTINGS		
VOLTAGES:	Excitation - 6.5VDC	Charge		Lod Range	$\pm 2.0 \text{ VDC}$	
				Strain Range	$\pm 2.0\%$	
				Stroke Range	± 1.1	
				X-Y CHART SETTINGS		
During calibration-						
0 4.00	75 - 7.672					
25 - 2.537	100 - 10 2.2					
50 - 5.16						
In specimen at zero-	-0.683 (0.0)					



72w18



Oak Ridge National Laboratory

Materials And Ceramics Division

108


Specimen Identification	-	A72W18
Test Temperature	-	90°C
Crack Arrest Toughness	-	132 MPa·m ^{0.5}
Length of Remaining Ligament	-	57.0 mm




Materials Division
Oak Ridge National Laboratory Metals And Ceramics Division

Specimen Identification	-	A72W18
Test Temperature	-	90°C
Crack Arrest Toughness	-	132 MPa·m
Length of Remaining Ligament	-	57.0 mm

SPEC. #	A72-1/8	DATE: May 10, 1971	Normal (Inverted)	Non-Irradiated
TEST TEMP.	90°C	CLIP GAGE		
VOLTAGES:	#CAGBZ	MACHINE SETTINGS		
Excitation - C. 588		Lod Range ± 2.0 kIPS		
During calibration -		Strain Range $\pm 2.0\%$		
0 0.2 75 - 7.5% 25 - 2.5% 100 - 10.0% 50 - 5.0%		Stroke Range ± 1		
In specimen at zero- -0.350 (0.0) Y= 1 μ m		X= 1 μ m		





72W21

10 20 30 40 50 60 70 80 90 100

Argonne National Laboratory

Metals And Ceramics Division

Specimen Identification	=	A72W21
Test Temperature	=	30°C
Crack Arrest Toughness	=	53 MPa·m
Length of Remaining Ligament	=	19.9 mm

SPEC. A72W21 $X = .5\%$ Tilt 30°c

Rate 8-23.89

Land Slope ± 20 m/s

Surf. Slope $\pm 10\%$

Stroke Space $\gtrsim (\pm 1^\circ)$

Normal Position

Cir. Current = 3426 V DC

6

5

4


KIPS

3


2


1

0



Specimen Identification : 72W22
Test Temperature : 60°C
Crack Arrest Toughness : 62 MPa·m
Length of Remaining Ligament : 7.1 mm









Specimen Identification	-	A72W23
Test Temperature	-	60°C
Crack Arrest Toughness	-	74 MPa·√m
Length of Remaining Ligament	-	22.0 mm


SPEC. #		72-2223		DATE: 3-27-87		Nominal Tension		Test-Tensile	
TEST TEMP.		60° C		CLIP GAGE		MACHINE SETTINGS			
VOLTAGES:		# CAG@1		Load Range = ±10 KIPS		Strain Range = ± 10%		Stroke Range = 3 (±1)	
Excitation -		3.436							
During calibration-									
0	-2.2	75				X-Y CHART SETTINGS			
25	-4.79	180				X= 0.5 %			
50	-7.36					Y= 0.2 %			
In specimen at zero-		72-2223		3.70					



Specimen Identification A72W26
Tensile Temperature -23°C
Crack Arreste Toughness 38 MPa·m
Length of Remaining Ligament 14.9 mm




SPEC. #	T _{TEST}	Z _{TEST}	DATE:	Specimen Inverted	Specimen Inverted With Load Applied
	TEST TEMP.	-25°C	CLIP GAUGE		
			# CAG-B		
VOLTAGES:			MACHINE SETTINGS		
	Excitation -	3.436	Load Range =	± 10 kips	
During calibration-	0 - 7.92	75	Strain Range =	± 10%	
	25 - 7.92	100	Stroke Range =	3(± 1)	
	50 - 12.47	-2.03	X-Y CHART SETTINGS		
		-2.03	X = 0.5 %		
In specimen at zero-			Y = 0.5 %		






Specimen Identification	=	A72W27
Test Temperature	=	29°C
Crack Arrest Toughness	=	61 MPa·m
Length of Remaining Ligament	=	18.3 mm


SPEC.	# 72227	DATE: 9-5-89	TESTED	REMARKS
TEST TIME	2455	CLIP GAGE	REACHABLE	
	30°C	CAGE #2		
VOLTAGES:		LOAD RANGE	2 TO 10 KIPS	
Extensometer - G 544		STRAIN RANGE	± 20%	
Detailed CALIBRATION -		STRAINS RANGE	3 (1)	
0 0 TS		X-Y CHART SETTINGS		
25 -2.45 100				
50		X = 0.5 %		
IN SPECIMEN AT ZERO - 5 sec		Y = 0.5 %		



Specimen Identification A72W29
Test Temperature 60°C
Crack Arrest Toughness -
Length of Remaining Ligament 20.8 mm
70 MPa·m



SPEC. # A72W29 DATE: 8-25-89	
TEST TEMP.	60°C
CLIP GAGE	# CAG01
VOLTAGES:	MACHINE SETTINGS
Excitation - 3.436	Load Range = $\pm 2.0 \text{ kN}$
During calibration- 0.308	Strain Range = $\pm 10\%$
25.0 544 100	Stroke Range = 3 (± 1)
50 - / 79	X-Y CHART SETTINGS
In specimen at zero- -1.37	X= 0.5 γ_{in} Y= 0.2 γ_{in}







Oak Ridge National Laboratory

Mechanical And Corrosion Division

Specimen Identification	=	A72W30
Test Temperature	=	-25°C
Crack Arrest Toughness	=	43 MPa·m
Length of Remaining Ligament	=	15.4 mm

SPEC. # A72-30	DATES 8-30-59	Normal	Inverted	New - Irradiated
TEST TEMP. -25°C	CLIP GAGE	MA. HINE SETTINGS		
VOLTAGES:	# CAGE/			
Excitation - 3.436		Lead Range = ± 10 Kips		
During calibration:		Strain Range = ± 10%		
0 - 1.66 75		Stroke Range = 3 (±)		
25 - 50 100		X-Y CHART SETTINGS		
50 - 6.75		X = 0.5 %		
In specimen at zero-°C		Y = 0.5 %/μ		





Specimen Identification = A72W32
Test Temperature = 32°C
Crack Arrest Toughness = 66 MPa·m
Length of Remaining Ligament = 24.8 mm

SPEC. # A72-22 DATE: 9-5-89 (Normal) Inverted Non-Axialated

TEST IRML 300% CLIP GAGE # CAG 22

VOLTAGES: 32C Load Range = 1/10 kips

Facilitation - C 542 Strain Range = 2.2%

Paring calibration, Stroke Range = 3 (±1)

X-Y CHART SETTINGS

0 0 75 X= 0.5 %

25 -2.47 100 Y= 0.5 %

50 -3.97 -5.04

In specimen at zero. (→ 1.41) D

0.250 -2.41% ← a plateau

0.250 1.0001 V

1000 2500

17.0 mm

2200 Blue

17.5 mm

1290 Blue

18.5 mm

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

1900

73W13



Specimen Identification	-	A73W13
Test Temperature	-	75°C
Crack Arrest Toughness	-	150 MPa·√m
Length of Remaining Ligament	-	65.8 mm

73W13

126


0 10 20 30 40 50 60 70 80 90 100

Dak Ridge National Laboratory

Metals And Ceramics Division

Specimen Identification	-	A73W13
Test Temperature	-	75°C
Crack Arrest Toughness	-	150 MPa·J/m
Length of Remaining Ligament	-	65.8 mm

SPEC. #	A73w13	DATE: OCT. 25, 1971	Normal / Inverted	Non-Irradiated
TEST TEMP.	75° ²	CLIP GAGE	#CAG#2	MACHINE SETTINGS
VOLTAGES:				
Excitation -	6.582			
During calibration-				
0 0.0	75 - 7.55			
25 - 2.52	100 - 10.37			
50 - 5.0				
In specimen at zero-	-0.05' (so)	X=	1 1/2	
		Y=	1 1/2	



73W14

L
92
99

MM METERS

0 10 20 30 40 50 60 70 80 80 100

Oak Ridge National Laboratory

Materials And Ceramics Division

Specimen Identification - A73W14
Test Temperature - 90°C
Crack Arrest Toughness - 159 MPa·m
Length of Remaining Ligament - 29.1 mm

73W14

128

MICRIMETERS

0 10 20 30 40 50 60 70 80 90 100

Cook Ridge National Laboratory

Metals And Ceramics Division

Specimen Identification	-	A73W14
Test Temperature	-	90°C
Crack Arrest Toughness	-	159 MPa·m
Length of Remaining Ligament	-	29.1 mm

SPEC. # A73-w14 DATE: 9-25-81 Normal Inverted Non-Irradiated
 TEST TEMP. 90°C CLIP GAGE
 VOLTAGES:
 Excitation - C. 542
 During calibration -
 0.000 75
 25 - 2.49 100
 50 - 4.97
 In specimen at zero - 0.875


MACHINE SETTINGS

Load Range = ± 10 KIPS
 Strain Range = $\pm 20\%$
 Stroke Range = ± 1

X-Y CHART SETTINGS

X = 0.5 mils / $1\frac{1}{2}$ in
 Y = 2.0 mils

VARIAL
 SETTING
 40 VOLTS



73w15



Oak Ridge National Laboratory

Mechanics And Ceramics Division

Specimen Identification - A73W15
Test Temperature - 60°C
Crack Arrest Toughness - 81 MPa·√m
Length of Remaining Ligament - 45.6 mm

73w15

10 20 30 40 50 60 70 80 90 100


Oak Ridge National Laboratory

Metals And Ceramics Division

130

Specimen Identification	-	A73W15
Test Temperature	-	60°C
Crack Arrest Toughness	-	81 MPa·J/m
Length of Remaining Ligament	-	45.6 mm

SPEC. # A-2 DATE: Jan 3, 1967 Normal / Inverted Non - Irradiated
 TEST TEMP. 65°C CLIP GAGE # CAG-32
 VOLTAGES:
 Excitation - 6.585
 During calibration -
 0.007 75 - 7.55
 25 100 - 12.2
 50 125
 In specimen at zero - 290 (a.s.) X = 1%
 Y = 1%






Specimen Identification	-	A73W17 (no test)
Test Temperature	-	100 °C
Crack Arrest Toughness	-	-
Length of Remaining Ligament	-	-



Specimen Identification - A73W17 (no test)
Test Temperature - 100°C
Crack Arrest Toughness -
Length of Remaining Ligament -

SPEC. #	TEST TEMP. (°F)	DATE: JUN 24, 1967	Normal / Inverted	Non-Irradiated
TEST TEMP. (°C)	VOLTRIMES:	CLIP GAGE	MACHINE SETTINGS	
		# C41522	Load Range = ± 2.0 x 10 ² N	
			Strain Range = ± 2.0 %	
			Stroke Range = ± 1	
			X-Y CHART SETTINGS	
			X = 1 mm	
			Y = 1 1/2 in	
During calibration-				
0 0.0	75 -7.5°			
25 -2.5°	100 -11.1°			
50 -5.0°				
In specimen at zero-	-2.25°	(0.0)		



SPEC. # A73W17 DATE: 10-25-89 Normal / Inverted Neg.-Irradiated
 TEST TEMP. 30°C CLIP GAGE # CAGBZ MACHINE SETTINGS
 VOLTAGES:
 Excitation - 6.588 Load Range = ± 2.0 KIPS / 50 KIP
 During calibration- Strain Range = $\pm 20\%$
 0 0.0 75 - 7.55 Stroke Range = ± 1
 25 - 2.52 100 - 10.10
 50 - 5.07 X-Y CHART SETTINGS
 In specimen at zero- -3.77 (0.0) Y = $1 \frac{1}{2}$ in. $2 \frac{1}{2}$ in. $1 \frac{1}{2}$ in.

12,000/24,000

10,000/20,000

8,000/16,000

6,000/12,000

4,000/8,000

2,000/4,000

0

0

MILS

CHANGED
TO 50 KIP
LOAD


135



Clark Ridge National Laboratory

Materials And Ceramics Division

Specimen Identification	-	A73W18
Test Temperature	-	75°C
Crack Arrest Toughness	-	131 MPa·J/m
Length of Remaining Ligament	-	51.3 mm




Oak Ridge National Laboratory

Metals And Ceramics Division

136

Specimen Identification	-	A73W18
Test Temperature	-	75°C
Crack Arrest Toughness	-	131 MPa·m
Length of Remaining Ligament	-	51.3 mm

SPEC. # A 73-18		DATE: 9-24-87		Negat. / Inverted	Neg. Irradiated
TEST TEMP.	75°C	CLIP GAGE	# CAG Ø 2-	MACHINE SETTINGS	
VOLTAGES:				Load Range	$\pm 10 \text{ KIPS}$
Excitation	- 6.543			Strain Range	$\pm 20\%$
During calibration				Stroke Range	± 1
0 0.00	75	X-Y CHART SETTINGS			
25 - 2.5k	100	X = 0.5	$\frac{\text{voltage}}{\text{amp}}$		
In specimen at zero-	- 0.415	Y = 0.5	$\frac{\text{voltage}}{\text{amp}}$		



73W21



Oak Ridge National Laboratory

Metals And Ceramics Division

12
30
80

Specimen Identification	-	A73W21
Test Temperature	-	75°C
Crack Arrest Toughness	-	107 MPa·m
Length of Remaining Ligament	-	54.1 mm

73W21




Oak Ridge National Laboratory

Materials And Ceramics Division

138

Specimen Identification	-	A73W21
Test Temperature	-	75°C
Crack Arrest Toughness	-	107 MPa·m
Length of Remaining Ligament	-	54.1 mm

SPEC. # A73-21	DATE: 9-22-57	Normal	Inverted	Irradiated
TEST TEMP. 75° C	CLIP GAGE	# AGPZ	MACHINE SETTINGS	
VOLTAGES:				
Excitation - 6.543			Load Range = ± 10 KIPS	
During calibration-			Strain Range = ± 20 %	
0 0.00 75	X-Y CHART SETTINGS		Stroke Range = ± 1	
25 - 2.49 100	X = 0.5 mil			
50 - 4.977	Y = 0.5 mil			
In specimen at zero- + 0.351				



73W23

L
070

0 10 20 30 40 50 60 70 80 90 100
MILLIMETERS

Oak Ridge National Laboratory

Metals And Ceramics Division

Specimen Identification	-	A73W23
Test Temperature	-	90°C
Crack Arrest Toughness	-	180 MPa·m
Length of Remaining Ligament	-	45.3 mm

73W23

140

MILLIMETERS

0 10 20 30 40 50 60 70 80 90 100

Oak Ridge National Laboratory

Metals And Ceramics Division

Specimen Identification	-	A73W23
Test Temperature	-	90°C
Crack Arrest Toughness	-	180 MPa·m
Length of Remaining Ligament	-	45.3 mm

SPEC. #	TEST TEMP.	DATE:	NON IRRADIATED	IRRADIATED
VOLTAGES:	CLIP GAGE	MACHINE SETTINGS		
0 0 0	75 -7.49	Load Range = ± 2.0 KIPS		
25 -2.53	100 -7.58	Strain Range = ± 2.0%		
50 -5.05	-100 -9.12	Stroke Range = ± 1%		
In specimen at zero-	-0.47%	(0.0)	Y = 1%	


During calibration:


0	75	-7.49
25	-2.53	100
50	-5.05	-100

X-Y CHART SETTINGS

X = 1 mil	Y = 1 mil
-----------	-----------

1444AC 54771145
15 45






Specimen Identification = A73W26
Test Temperature = 75 °C
Crack Arrest Toughness = 88 MPa·m
Length of Remaining Ligament = 55.4 mm



Specimen Identification = A73W26
Test Temperature = 75°C
Crack Arrest Toughness = 88 MPa·m
Length of Remaining Ligament = 55.4 mm

SPEC. # A 73-26	DATE: 4-19-67	Normal / Inverted	Spec. Irradiated
TEST TEMP. 75°C	CLIP GAGE # AG-2	MACHINE SETTINGS	
VOLTAGES:			
Excitation - 6.543			
During calibration-			
0-0.02 75			
25 100	X= 1.0 %/in		
50-5.02.3	Y= 1.0 %/in		
In specimen at zero-	0.30		





Specimen Identification	=	A73W31
Test Temperature	=	29°C
Crack Arrest Toughness	=	57 MPa·m
Length of Remaining Ligament	=	21.5 mm

Sec. A 73-131 X-5 μ ₃ Temp. 29°
 Date 8-23-75 V- no μ ₃ No. of stations /
 Load Range *20 kg
 Step in Distance ± 10 Z
 Stroke " 3 (+10)
 Normal force 10
 Frictional force 0.500 ± 0.36 ± 0.5

10


8

6

4


2

0



Specimen Identification A73W33
Test Temperature 60°C
Crack Arrest Toughness 74 MPa·m
Length of Remaining Ligament 26.5 mm





Specimen Identification = A73W34
Test Temperature = 29°C
Crack Arrest Toughness = 60 MPa·m/m
Length of Remaining Ligament = 22.1 mm



SPEC. #	TEST HEMP.	DATE	Normal	Inverted	Spec. Standard
VOLTAGES.	CLIP GAGE				
+27.5	# CAG 22				
Excitation - 243G 6.53					
During calibration:					
0 0 0 75					
25 - 246 100					
50 - 4.977					
In specimen at zero-	7.84				

MACHINE SETTINGS

Load Range = 1/10 KIPS


Strain Range = 1/1000


Stroke Range = 3 (1)

X-Y CHART SETTINGS

X= 0.5 in


Y= 0.5 in






Specimen Identification = A73W35
Test Temperature = 29°C
Crack Arrest Toughness = 67 MPa·m
Length of Remaining Ligament = 27.7 mm

SPEC. # A75-35	DATE: 9-5-74	Normal / Inverted	Non-Irradiated
TEST TEMP. 21°C	CLIP GAGE	MACHINE SETTINGS	
VOLTAGES:	#060 #Z-		
Excitation - 6.544		Load Range = 3/5 kN	
During calibration -		Strain Range = ± 2.0%	
0 (2.45 mm) 75		Stroke Range = 3(1)	
25 - 2.49 100		X-Y CHART SETTINGS	
50		X= 0.5 %	
In specimen at zero- ω		Y= 0.5 %	





Specimen Identification	=	A73W37
Test Temperature	=	+25°C
Crack Arrest Toughness	=	29 MPa·m
Length of Remaining Ligament	=	2.8 mm


SPEC. #	473-037	DATE 8-30-37	Normal	Inverted	Spec. Irradiated
TEST TEMP.	-25°C	CLIP GAGE	MACHINE SETTINGS		
VOLTAGES:		# 06571			
Excitation - 3.436					
During calibration-					
0 - 2.92	75				
25 - 2.92	100				
50 - 3.00					
In specimen at zero-					


- 2500 -

2000 400

1500 - 300


1000 - 100






Specimen Identification	=	A73W39
Test Temperature	=	-25°C
Crack Arrest Toughness	=	41 MPa·m
Length of Remaining Ligament	=	14.0 mm


TEST TEMP.	DATE	Normal Irradiated
VOLTAGES:	CLIP GAGE	MACHINE SETTINGS
Excitation - 6	Load Range = 100 kgf	Strain Range = 20%
During calibration - 6	Stroke Range = 10 mm	
25	X-Y CHART SETTINGS	
50	X = 0.5% / in	
In specimen at zero-	Y = 5%	




Specimen Identification - A73W40
Test Temperature - 60°C
Crack Arrest Toughness - 81 MPa/m
Length of Rematting Llgament - 26.3 mm



SPEC. # 73440		DATE: 8-25-69		Inverted	Irradiated
TEST TEMP.	60°C	CLIP GAGE		MACHINE SETTINGS	
VOLTAGES:	#C46 #1			Load Range = ± 20 KIPS	
Excitation -	3.436			Strain Range = $\pm 10\%$	
During calibration-				Stroke Range = 3 (2 1/2)	
0-4.98	75			X-Y CHART SETTINGS	
25-4.51	100			X: 0.5% Δ	
50-7.06				Y: 0.2% Δ	
In specimen at zero-/-80°					






Specimen Identification = A73W41
Test Temperature = 60°C
Crack Arrest Toughness = 79 MPa·√m
Length of Remaining Ligament = 30.9 mm

SPEC. 73 w 41 DATE 8-20-85 TEMP 60°C
 $X = 5\%_{vol}$ INCUBATED INCUBATION: 3 hrs
 $Y = 5\%_{vol}$ LOAD PAMENT: 20 KIPS
 INJECTED: Residual STEAM: ± 60%
 STROKE: 3±1)
 CACO₃ CONC: CACO₃

7





160

Oak Ridge National Laboratory

Mechanical Properties

Specimen Identification	-	A73W45
Test Temperature	-	90°C
Crack Arrest Toughness	-	114 MPa·m
Length of Remaining Ligament	-	55.3 mm




160

Oak Ridge National Laboratory

Smith's And Ceramic Disk

Specimen Identification -	A73W45
Test Temperature -	90°C
Crack Arrest Toughness -	114 MPa·J/m
Length of Remaining Ligament -	55.3 mm

SPEC. # A73w45		DATE: Oct-20/87	Normal	Inverted	Noir-Irradiated
TEST TEMP.	VOLTAGES:	CLIP GAGE #C4692	MACHINE SETTINGS		
75°C 90°C	- Excitation - C. 589	Load Range ± 1.2% F.S.			
	During calibration:	Strain Range ± 6.25% F.S.			
0.00	75 - 7.56	Stroke Range ± 1.1			
25 - 2.52	100 - 10.08	X-Y CHART SETTINGS			
50 - 5.04		X = 1 $\frac{1}{\mu}$			
In specimen at zero-	-0.254 (0.0)	Y = 1 %			



73W51




CBN Ridge National Laboratory

Mechanics And Ceramics Division

Specimen Identification - A73W51
Test Temperature - 100°C
Crack Arrest Toughness - 184 MPa·m
Length of Remaining Ligament - 47.1 mm

73w51




CBK Ridge National Laboratory


Metals And Ceramics Division

Specimen Identification: - A73W51
Test Temperature - 100°C
Crack Arrest Toughness - 184 MPa·m
Length of Remaining Ligament - 47.1 mm

SPEC. # A73-51	DATE: 9-27-89	Normal (Inverted)	New (Irradiated)
TEST TEMP. 100°C	CLIP GAGE # CACD2	MACHINE SETTINGS	
VOLTAGES:			
Excitation - 6.588 "		Load Range ± 120 KOPS	
During calibration-		Strain Range $\pm 10\%$	
0 .00	75 - 7.48	Stroke Range $\pm 5\%$	
25 - 2.51	100 - 2.97	X-Y CHART SETTINGS	
50 - 5.01		X= 1 1/2	
In specimen at zero-		Y= 2 1/2	



SPEC. # A73-51	DATE: 9-27-87	Normal / Inverted	Non-Irradiated
TEST TEMP. 100°C	CLIP GAGE # 2ACD-2	MACHINE SETTINGS	
VOLTAGES:		Load Range	$\pm 20\text{ kNPS}$
Excitation - 6.588 "		Strain Range	$\pm 10\%$
During calibration-		Stroke Range	$\pm \pm 1$
0.0 75 - 7.48		X-Y CHART SETTINGS	
25.251	100 - 9.97	X = $1\frac{1}{2}$ "	
50.501		Y = $2\frac{1}{2}$ " / $1\frac{1}{2}$ "	
In specimen at zero-	-340		



NUREG/CR-5584
ORNL/TM-11575
Distribution
Category RF

INTERNAL DISTRIBUTION

1. D. J. Alexander	34. G. C. Robinson
2. B. R. Bass	35. D. K. Shum
3. R. D. Cheverton	36. G. M. Slaughter
4-8. W. R. Corwin	37. J. O. Stiegler
9. T. L. Dickson	38. R. E. Stoller
10. F. M. Haggag	39. T. Theiss
11-22. S. K. Iskander	40. K. R. Thoms
23. F. B. Kam	41. J. A. Wang
24. J. Keeney-Walker	42. ORNL Patent Section
25. D. E. McCabe	43. Central Research Library
26. J. G. Merkle	44. Document Reference Section
27-31. R. K. Nanstad	45-46. Laboratory Records Department
32. W. E. Pennell	47. Laboratory Records (RC)
33. C. E. Pugh	48-50. M&C Records Office

EXTERNAL DISTRIBUTION

51. D. J. Ayres, Department 487-4, Combustion Engineering, Windsor, CT 60695	
52. BABCOCK AND WILCOX, Research and Development Division, 1562 Beeson Street, Alliance, OH 44601	
W. A. Van Der Sluys	
53. BABCOCK AND WILCOX, 3315 Old Forest Road, Lynchburg, VA 24501	
A. Lowe	
54-55. BATTELLE-COLUMBUS LABORATORIES, 505 King Avenue, Columbus, OH 43201	
C. Marschall	
A. R. Rosenfield	
56. IITTS ATOMIC POWER LABORATORY, Westinghouse Electric Corp., P.O. Box 79, West Mifflin, PA 15122	
L. A. James	

57-58. DAVID TAYLOR RESEARCH CENTER, Code 2814, Annapolis, MD 21402

E. M. Hackett
M. T. Kirk

59. ELECTRIC POWER RESEARCH INSTITUTE, P.O. Box 10412, Palo Alto,
CA 94303

T. Griesbach

60-61. ENERGIA NUCLEARE DELLA ENERGIA ALTERNATIVA (ENEA-DISP),
Via Brancati, 00144 Roma, Italy

P. M. Pietro
A. Pini

62. FRAUENHOFER-INSTITUT FUER WERKSTOFFMECHANIK, Woehlerstr. 11,
D 7800 Freiburg, Federal Republic of Germany

W. Boehme

63. IMATRON VOIMA, Mechanical Department, P.O. Box 138, SS 00101,
Helsinki 10, Finland

R. Ahlstrand

64. IMPERIAL COLLEGE, Mechanical Engineering Department, Exhibition Road,
London, SW7 2AZ England

H. J. Macgillivray

65. G. R. Irwin, 7306 Edmonston Ave., College Park, MD 20740

66. MATERIAL ENGINEERING ASSOCIATION, 9700B Martin Luther King, Jr.
Highway, Lantham, MD 20706

J. R. Hawthorne

67. MITSUBISHI HEAVY INDUSTRIES, LTD., Takasago Research and Development
Center, 2-1-1 Shinhama, ARAI-CHO, Takasago, 676 Japan

Y. Urabe

68. NATIONAL INSTITUTE OF STANDARDS, Department of Commerce, Office of
Non-Destructive Evaluation, Gaithersburg, MD 20899

J. Gudas, Deputy Chief

- 69-73. NRC, Division of Engineering, Washington, DC 20555
A. Hiser (MS NL/S217C)
R. E. Johnson
M. E. Mayfield
C. Z. Serpan
M. Vagins
74. NRC, Region I, 631 Park Avenue, King of Prussia, PA 19406
J. R. Strosnider
75. E. J. Rippling, One Science Road, Glenwood, IL 60425
76. OHIO STATE UNIVERSITY, Department of Engineering Mechanics, 155 West Woodruff, Columbus, OH 43210
C. H. Popelar
- 77-78. SOUTHWEST RESEARCH INSTITUTE, P.O. Drawer 28510, 6220 Culebra Rd., San Antonio, TX 78284
S. J. Hudak
M. F. Kanninen
79. STAATL. MATERIALPRUFUNGSANSTALT, Pfaffenwalde 32, 7000 Stuttgart 80, Federal Republic of Germany
R. Gillet
80. L. E. Steele, 7624 Highland St., Springfield, VA 22150-3931
81. TENERA ENGINEERING SERVICES, 1995 University Avenue, Berkeley, CA 94704
W. Server
82. TENERA ENGINEERING SERVICES, 308 N. Peters Rd., Suite, 280, Knoxville, TN 37922
W. A. Pavinich
- 83-84. TEXAS A&M UNIVERSITY, Department of Mechanical Engineering, College Station, TX 77843-3123
T. Anderson
R. Chona
85. TOYOHASHI UNIVERSITY OF TECHNOLOGY, 1-1 Tempaku-Cho, Toyohashi, Japan 441
H. Homma

86. TVFA TU VIENNA, Karlsplatz 13, 1040 Vienna, Austria

T. Varga

87. UNIVERSITY OF CALIFORNIA, Department of Chemical and Nuclear
Engineering, Ward Memorial Drive, Santa Barbara, CA 93106

G. R. Odette

88. UNIVERSITY OF MARYLAND, Mechanical Engineering Department,
College Park, MD 20742

W. L. Fourney

89. UNIVERSITY OF TENNESSEE, Engineering Science and Mechanics,
310 Perkins Hall, Knoxville, TN 37996-2030

J. A. Landes

90. WASHINGTON STATE UNIVERSITY, Mechanical and Materials Engineering
Department, Pullman, WA 99164

R. G. Hogland

91. E. T. Wessel, Lake Region Mobile Home Village, 312 Wolverine Lane,
Haines City, FL 33844

92-93. WESTINGHOUSE ELECTRIC CORP., P.O. Box 355, Pittsburgh, PA 15230

W. Bamford
F. J. Witt, Bldg. 701

94-95. WESTINGHOUSE R & D CENTER, 1310 Beulah Rd., Pittsburgh, PA 15325

J. A. Begley
R. G. Lott

96. DOE, Oak Ridge Operations Office, Oak Ridge, TN 37831-6269

Office of Deputy Assistant Manager for Energy Research
and Development

97-98. DOE, Office of Scientific and Technical Information, P.O. Box 62,
Oak Ridge, TN 37831

99-226. Given distribution as shown in category RF (NTIS-10)

BIBLIOGRAPHIC DATA SHEET

[See instructions on the reverse.]

2. TITLE AND SUBTITLE

Results of Crack-Arrest Tests on Two Irradiated High-Copper Welds

5. AUTHOR(S)

S.K. Iskander, W.R. Corwin, P., Nanstad

1. REPORT NUMBER
(Assigned by NRC Add Vol. Supp., Rev., and Addendum Numbers, if any.)

NUREG/CR-5584
ORNL/TM-11575

3. DATE REPORT PUBLISHED

MONTH YEAR

December 1990

4. FIN OR GRANT NUMBER

11098

5. TYPE OF REPORT

Technical

7. PERIOD COVERED *(Inclusive Dates)*

6. SPONSORING ORGANIZATION - NAME AND ADDRESS *(If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address. If contractor, provide name and mailing address.)*

Oak Ridge National Laboratory
Oak Ridge, TN 37831-6285

8. SPONSORING ORGANIZATION - NAME AND ADDRESS *(If NRC, type "Same as above". If contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)*

Division of Engineering
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT *(200 words or less)*

The objective of this study was to determine the effect of neutron irradiation on the shift and shape of the lower-bound curve to crack-arrest data. Two submerged-arc welds with copper contents of 0.23 and 0.31 wt % were commercially fabricated in 220-mm-thick plate. Crack-arrest specimens fabricated from these welds were irradiated at a nominal temperature of 288°C to an average fluence of 1.9×10^{19} neutrons/cm² (>1 MeV). Evaluation of the results shows that the neutron-irradiation-induced crack-arrest toughness temperature shift is about the same as the Charpy V-notch impact temperature shift at the 41-J energy level. The shape of the lower-bound curves (for the range of test temperatures covered) did not seem to have been altered by irradiation compared to those of the ASME K_{1A} curve.

12. KEY WORDS/DESCRIPTORS *(List words or phrases that will assist researchers in locating the report.)*

Charpy V-notch impact toughness neutron fluence
copper content nil-ductility transition temperature
crack arrest reactor pressure vessels
drop-weight submerged arc welds
fracture toughness temperature shift
irradiation ΔRT_{NDT}
K_{1A}
light-water reactors

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

15. NUMBER OF PAGES

16. PRICE

THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER.

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

SPECIAL FOURTH CLASS RATE
POSTAGE & FEES PAID
USNRC

PERMIT NO. G-67