

January 2, 1991

Docket No. 50-42

Mr. Michael D. Lyster  
Vice President, Nuclear-Perry  
The Cleveland Electric Illuminating  
Company  
10 Center road  
Perry, Ohio 44081

DISTRIBUTION	Docket File
RSchott	DMiller
PD33 r/f	BBoger
JZwolinski	PKreutzer
JRHall	OGC
ACRS(10)	PD33 gray
DRP, Region III	

Dear Mr. Lyster:

SUBJECT: UNIMPLEMENTED GENERIC SAFETY ISSUES AT THE PERRY NUCLEAR POWER PLANT, UNIT NO. 1

On April 25, 1990 the staff issued Generic Letter 90-04 which requested information concerning the implementation status of certain generic safety issues (GSIs) at your facility. Based on your response to this Generic Letter, dated June 29, 1990, our own records and discussions with your staff, we have updated our database on GSI implementation status. The results of this effort were presented to the Commission at a meeting on October 25, 1990.

The enclosure to this letter summarizes the staff's understanding of the current status of those GSIs which remain unimplemented at the Perry Nuclear Power Plant, Unit No. 1. We appreciate the assistance you provided in responding to Generic Letter 90-04 and we encourage your timely completion of those GSIs listed in the enclosure.

Please contact me if you have any questions or comments about the enclosed information.

Sincerely,

Original Signed By:

James R. Hall, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

DOCUMENT NAME: PERRY GSI LETTER

LA/PDIII-3 PKreutzer 12/23/90	PM/PDIII-3 JRHall:rs 12/23/90	PD/PDIII-3 JHannon 1/12/91
-------------------------------------	-------------------------------------	----------------------------------

9101070139 910102  
PDR ADDCK 05000440  
P PDR

JFO1  
1/10

January 2, 1991

Docket No. 50-440

Mr. Michael D. Lyster  
Vice President, Nuclear-Perry  
The Cleveland Electric Illuminating  
Company  
10 Center road  
Perry, Ohio 44081

DISTRIBUTION	Docket File
RSchoff	DMiller
PD33 r/f	BBoger
JZwolinski	PKreutzer
JRHall	OGC
ACRS(10)	PD33 gray
DRP, Region III	

Dear Mr. Lyster:

SUBJECT: UNIMPLEMENTED GENERIC SAFETY ISSUES AT THE PERRY NUCLEAR POWER  
PLANT, UNIT NO. 1

On April 25, 1990 the staff issued Generic Letter 90-04 which requested information concerning the implementation status of certain generic safety issues (GSIs) at your facility. Based on your response to this Generic Letter, dated June 29, 1990, our own records and discussions with your staff, we have updated our database on GSI implementation status. The results of this effort were presented to the Commission at a meeting on October 25, 1990.

The enclosure to this letter summarizes the staff's understanding of the current status of those GSIs which remain unimplemented at the Perry Nuclear Power Plant, Unit No. 1. We appreciate the assistance you provided in responding to Generic Letter 90-04 and we encourage your timely completion of those GSIs listed in the enclosure.

Please contact me if you have any questions or comments about the enclosed information.

Sincerely,

Original Signed By:

James R. Hall, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

DOCUMENT NAME: PERRY GSI LETTER

LA/PDIII-3  
PKreutzer  
12/27/90

PM/PDIII-3  
JRHall:rc/LH  
12/31/90

PD/PDIII-3  
JHannon  
1/2/91

Mr. Michael D. Lyster  
Cleveland Electric Illuminating Company

Perry Nuclear Power Plant  
Unit Nos. 1 and 2

cc: Jay E. Silberg, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, N.W.  
Washington, D.C. 20037

David E. Burke  
The Cleveland Electric  
Illuminating Company  
P. O. Box 5000  
Cleveland, Ohio 44101

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
Parly at Center Road  
Perry, Ohio 44081

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Frank P. Weiss, Esq.  
Assistant Prosecuting Attorney  
105 Main Street  
Lake County Administration Center  
Painesville, Ohio 44077

Ms. Sue Hiatt  
OCRE Interim Representative  
8275 Munson  
Mentor, Ohio 44060

Terry J. Lodge, Esq.  
618 N. Michigan Street  
Suite 105  
Toledo, Ohio 43624

John G. Cardinal, Esq.  
Prosecuting Attorney  
Ashtabula County Courthouse  
Jefferson, Ohio 44047

Robert A. Newkirk  
Cleveland Electric  
Illuminating Company  
Perry Nuclear Power Plant  
P. O. Box 97 E-210  
Perry, Ohio 44081

Mr. James W. Harris, Director  
Division of Power Generation  
Ohio Department of Industrial  
Relations  
P. O. Box 825  
Columbus, Ohio 43216

The Honorable Lawrence Logan  
Mayor, Village of Perry  
4203 Harper Street  
Perry, Ohio 44081

The Honorable Robert V. Orosz  
Mayor, Village of North Perry  
North Perry Village Hall  
4778 Lockwood Road  
North Perry Village, Ohio 44081

Attorney General  
Department of Attorney General  
30 East Broad Street  
Columbus, Ohio 43216

Radiological Health Program  
Ohio Department of Health  
1224 Kinnear Road  
Columbus, Ohio 43212

Ohio Environmental Protection  
Agency  
DERR--Compliance Unit  
P. O. Box 1049  
1800 Watermark Drive  
ATTN: Zack A. Clayton  
Columbus, Ohio 43266-0149

Mr. Phillip S. Haskell, Chairman  
Perry Township Board of Trustees  
Box 65  
4171 Main Street  
Perry, Ohio 44081

State of Ohio  
Public Utilities Commission  
East Broad Street  
Columbus, Ohio 43266-0573

ENCLOSURE

UNIMPLEMENTED GSIs AT THE PERRY NUCLEAR POWER PLANT, UNIT NO. 1

<u>GSI NO.</u>	<u>TITLE</u>	<u>PROJECTED IMPLEMENTATION DATE</u>	<u>REMARKS</u>
51	Improving the Reliability of Open-Cycle Service Water Systems	12/93	Procedure changes, testing and in- spections to comply with GL 89-13. Final confirmation 12/93.
67.3.3	Improved Accident Monitoring	TBD	Neutron flux monitoring issue appealed by BWROG 9/20/90.
75	Salem ATWS Item 2.2.2, Vendor Interface for Safety-Related Components	6/91	Implementation of key safety-related component vendor periodic contact program.