

TABLE 3.3.5.2-1

REMOTE SHUTDOWN MONITORING INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>READOUT LOCATION</u>	<u>MINIMUM CHANNELS OPERABLE</u>
1. Reactor Vessel Pressure	RSP ^(a)	1
2. Reactor Vessel Water Level	RSP ^(a)	1
3. Suppression Chamber Water Level	RSP ^(a)	1
4. Suppression Chamber Water Temperature	RSP ^(a)	1
5. Drywell Pressure	RSP ^(a)	1
6. Drywell Temperature	RSP ^(a)	1
7. Residual Heat Removal System Flow	RSP ^(a)	1

(a) Remote Shutdown Panel, Reactor Building 20' Elevation

TABLE 4.3.5.2-1

REMOTE SHUTDOWN MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Reactor Vessel Pressure	M	Q
2. Reactor Vessel Water Level		
N017 Instrument Loop:	NA	Q
Remaining Instruments:	M	Q
3. Suppression Chamber Water Level	M	R
4. Suppression Chamber Water Temperature	M	R
5. Drywell Pressure	M	Q
6. Drywell Temperature	M	R
7. Residual Heat Removal System Flow	M	Q