

OCT 7 1982

Docket Nos: 50-327/328
50-369/370
and 50-315/316

APPLICANT: Tennessee Valley Authority
Duke Power Company
American Electric & Power (Indiana & Mich. Elec. Co.)

FACILITY: Sequoyah Nuclear Power Station
McGuire Nuclear Power Station
D. C. Cook

SUBJECT: SUMMARY OF MEETING HELD ON AUGUST 4-5, 1982

A meeting was held on August 4-5, 1982, at the NRC office in Bethesda, Maryland, to discuss the results of the research program on hydrogen combustion and control. This program is sponsored by TVA, AEP, and Duke Power in support of their overall efforts to demonstrate the adequacy of the hydrogen control systems installed in their nuclear plants that utilize the ice condenser containment concept. The list of attendees for the meeting is provided as enclosure 1. A copy of the slides that were used during the meeting are provided in enclosure 2.

The importance of the research effort by the utilities was emphasized by the Project Manager in that Sequoyah and McGuire stations have license conditions that require a determination (prior to startup after the first refueling) that the installed system will perform its intended function in a manner that provides adequate safety margins. It was further noted that this is a mandate from the Commissioners themselves and this matter must receive their approval prior to restart of Sequoyah Unit 1. Sequoyah 1 completed its first core burn cycle, and startup is expected on or before January 1, 1983. For this reason the staff will have to issue its Safety Evaluation Report in mid-November to be consistent with the Sequoyah 1 plant schedule.

Quarterly progress reports have been issued on the licensee's efforts and a number of topical reports will be issued in the near future. Also, each licensee has been requested to submit an Executive Summary Report whose purpose is to set forth their position and justification on the adequacy of their hydrogen control systems. The TVA Sequoyah report is expected in late September 1982.

The results of the laboratory tests on hydrogen control and combustion were discussed in considerable detail by each of the organizations that performed the tests for the utilities. This provided an opportunity for the staff and others to hear from the principal investigators the manner in which the experiments were carried out. The staff also solicited their opinions on whether or not the results of these experiments contributed to the resolution of the issues that are associated with their respective test program. The principal investigators appeared to be generally aware of the issues and need for the experiments to produce data that would contribute to the resolution of the issues. The discussions by the utility representatives and the investigators did not adequately cover, however, the staff's questions of how the experimental results supported the analysis on the hydrogen mitigation

B211080022 B21007
PDR ADDCK 05000327
PDR

OFFICE
SURNAME
DATE

system. It is anticipated that each utility will provide this assessment in their respective Executive Summary Reports. During the presentations the staff noted in several instances that some of the data had not been previously presented in the quarterly reports. Also, TVA stated that the tests on their TAYCO ignitor were continuing. The results of such tests would be submitted at a later date. A few of the planned tests were not carried out as was anticipated in other documentation. One test of particular interest was a Whiteshell test that involved a 8.5% hydrogen/30% steam mixture with ignition taking place at the top of the test vessel. No explanation was provided, but the licensees were to investigate these deletions and report on this matter. Other comments on the adequacy of the experiments were provided by the staff during the meeting; however, the staff noted that it would respond, formally, to its adequacy after further analysis of the data. On September 17, 1982, a NRR letter was issued to each licensee requesting additional information which was based on the available data and discussions during the August 4-5, 1982, meeting.

With respect to safety related equipment surviving a successive number of deliberate ignition hydrogen burns in containment, the licensees reanalyzed the exposed equipment for a different flame speed and radiative heat. The results show that the temperatures were within the qualification temperatures. On this basis, the licensees stated that the designated safety related equipment will survive deliberate hydrogen burns. Staff comments on this matter have now been prepared and they were forwarded to the utilities for response.

No further work on local detonations was performed by the licensees, since they consider that all possible areas were discussed in previous correspondence and reports. Nevertheless, the staff has requested further information in this area in the letter of September 17, 1982.

Carl Stahle, Project Manager
Licensing Branch No. 4
Division of Licensing

Enclosures:
As stated

cc: See next page

OFFICE ▶	DL:LB #4	DL:LB #4	ORB #1	LA:DL:LB #4	DL:LB #4		
SURNAME ▶	CStahle/hmc	RBirkel	RCilimberg	MDuncan	EAdensam		
DATE ▶	10/10/82	10/7/82	10/7/82	10/7/82	10/7/82		

Enclosure 1

List of Attendees

For H₂ Meeting
On August 4-5, 1982

NAME

ORGANIZATION

V. Srinivas	Westinghouse
K. J. Vehstedt	American Electric Power
D. A. Medek	American Electric Power
J. L. Milhoas	NRC - Office of Policy Evaluation
R. A. Strehlow	Univ. of Illinois at Urbana
C. G. Tinkler	NRC/CSB
R. L. Palla	NRC/CSB
Jerry S. Wills	TVA - SQN Licensing Engineer
R. C. Torok	Acurex Corp.
Bob Zalosh	Factory Mutual
A. L. Sudduth	Duke Power Company
A. J. Ignatonis	NRC/I&E, RII
Don L. Williams	TVA
Wang Lau	TVA
Bob Bryan	TVA
David Renfro	TVA
Gregory Hudson	Duke Power Company
Harold Polk	NRC/SEB
Morton Fleishman	NRC/RES/DRA
W. R. Butler	NRC/CSB
K. I. Parczewski	NRC/CMEB/DE
Heiki Tamm	AECL/WNRE
Gary Quittschreiber	NRC/HCRS
John Long	NRC/NRR/RSB
John T. Larkins	NRC/RES/SAAB
Matt. A. Lechowicz	Bechtel
Al Nofufrancesco	NRC/CSB
Clifford Anderson	NRC/DST/GIB
T. Su	NRC/GIB
D. Houston	NRC/DL/LB #2
K. Steyer	NRC/RES
Bal Raj Sehgal	EPRI
Pat Worthington	NRC/RES/CEB
John Hosler	EPRI
John Carey	EPRI
Tom Auble	EPRI
R. A. Birkel	NRC/NRR/DL/LB #4
G. A. Copp	Duke Power Company
Loren Thompson	EPRI
Lewis Muhlestein	Westinghouse Hanford/HEDL
Jerry Bloom	Westinghouse Hanford/HEDL
R. K. Mattu	NUS Corp.
G. M. Fuls	Westinghouse/OPS
Fred Peters	Westinghouse/ARD
G. Stabile	NRC/NRR/DL/LB #4
Ken Perry	Westinghouse/OPS
Bob Shepard	MP&L

OFFICE ▶	Ken Perry				
SURNAME ▶	Bob Shepard				
DATE ▶					

Enclosure 2

Information Presented at
H2 Meeting on August 4-5, 1982

OFFICE ▶
SURNAME ▶
DATE ▶

MEETING SUMMARY DISTRIBUTION

Docket No(s): 50-327/328 50-369/370 50-315/316

NRC/PDR

Local PDR

TIC/NSIC/TERA

LB #4 r/f

Attorney, OELD

OIE

E. Adensam

Project Manager C. Stanle, R. Birkel & R. Cilimberg

Licensing Assistant M. Duncan

OCT 7 1982

NRC Participants:

J. L. Milhoan
C. G. Tinkler
R. L. Palla
A. J. Ignatonis
H. Polk
M. Fleishman
W. R. Butler
K. I. Parczewski
G. Quittschreiber
J. Long
J. T. Larkins
A. Notufrancesco
C. Anderson
T. Su
D. Houston
K. Steyer
P. Worthington
R. Birkel
C. Stanle

bcc: Applicant & Service List

SEQUOYAH

Mr. H. G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

cc: Herbert S. Sanger, Jr., Esq.
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33
Knoxville, Tennessee 37902

Mr. H. N. Culver
Tennessee Valley Authority
400 Commerce Avenue, 249A HBB
Knoxville, Tennessee 37902

Mr. Bob Faas
Westinghouse Electric Corp.
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. Jerry Wills
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Donald L. Williams, Jr.
Tennessee Valley Authority
400 West Summit Hill Drive, W10B85
Knoxville, Tennessee 37902

Resident Inspector/Sequoyah NPS
c/o U.S. Nuclear Regulatory
Commission
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

James P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

McGuire

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

cc: Mr. A. Carr
Duke Power Company
P.O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. G. A. Copp
Duke Power Company
Nuclear Production Department
P.O. Box 33189
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Debevoise & Liberman
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Paul Bemis
Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Huntersville, North Carolina 28078

James P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. John Dolan
Indiana and Michigan Electric Company

cc: Mr. Robert W. Jurgensen
Chief Nuclear Engineer
American Electric Power
Service Corporation
2 Broadway
New York, New York 10004

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
Post Office Box 18
Bowling Green Station
New York, New York 10004

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Maude Preston Palenske Memorial
Library
500 Market Street
St. Joseph, Michigan 49085

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
P. O. Box 458
Bridgman, Michigan 49106

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

William J. Scanlon, Esquire
2034 Pauline Boulevard
Ann Arbor, Michigan 48103

The Honorable Tom Corcoran
United States House of Representatives
Washington, D. C. 20515

James G. Keppler
Regional Administrator - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Enclosure 1

List of Attendees

For H₂ Meeting
On August 4-5, 1982

NAME

ORGANIZATION

V. Srinivas	Westinghouse
K. J. Vehstedt	American Electric Power
D. A. Medek	American Electric Power
J. L. Milhoan	NRC - Office of Policy Evaluation
R. A. Strehlow	Univ. of Illinois at Urbana
C. G. Tinkler	NRC/CSB
R. L. Palla	NRC/CSB
Jerry S. Wills	TVA - SQN Licensing Engineer
R. C. Torok	Acurex Corp.
Bob Zalosh	Factory Mutual
A. L. Sudduth	Duke Power Company
A. J. Ignatonis	NRC/I&E, RII
Don L. Williams	TVA
Wang Lau	TVA
Bob Bryan	TVA
David Renfro	TVA
Gregory Hudson	Duke Power Company
Harold Polk	NRC/SEB
Morton Fleishman	NRC/RES/DRA
W. R. Butler	NRC/CSB
K. I. Parczewski	NRC/CMEB/DE
Heiki Tamm	AECL/INRE
Gary Quittschreiber	NRC/HCRS
John Long	NRC/NRR/RSB
John T. Larkins	NRC/RES/SAAB
Matt. A. Lechowicz	Bechtel
Al Nofufrancesco	NRC/CSB
Clifford Anderson	NRC/DST/GIB
T. Su	NRC/GIB
D. Houston	NRC/DL/LB #2
K. Steyer	NRC/RES
Bal Raj Sehgal	EPRI
Pat Worthington	NRC/RES/CEB
John Hosler	EPRI
John Carey	EPRI
Tom Auble	EPRI
R. A. Birkel	NRC/NRR/DL/LB #4
G. A. Copp	Duke Power Company
Loren Thompson	EPRI
Lewis Muhlestein	Westinghouse Hanford/HEDL
Jerry Bloom	Westinghouse Hanford/HEDL
R. K. Mattu	NUS Corp.
G. M. FuIs	Westinghouse/OPS
Fred Peters	Westinghouse/ARD
C. Stanle	NRC/NRR/DL/LB #4
Ken Perry	Westinghouse/QPS
Bob Shepard	MP&L

Enclosure 2


Information Presented at
H2 Meeting on August 4-5, 1982

WATER FOG INERTING EXPERIMENTS

EPRI RP 1932-1 (Task 5)

**Factory Mutual Research Corporation
Norwood, Massachusetts**

**OBJECTIVE: Determine Hydrogen Flammability
Limit Variation With Applied Fog
Density, Drop Size, and Temperature.**



1. Inerting Tube (Plexiglas)
2. Vent & Plumbing Support Cap
3. Funnel
4. Vent Disks (A total of four)
5. Spray Nozzle
6. Electrodes
7. Thermocouple Probes
8. Heating Tape
9. Flash Arrester
10. Rotameters
11. Hydrogen-Air Mixer
12. Check Valves
13. Hot Water Tank
14. Solenoid Valves
15. Pressure Regulators
16. Water Collector

Figure 2-1. Hydrogen-Water Fog Inerting Experimental Setup


<u>NOZZLE</u>	VOL MEAN DROP SIZE (MICRONS)	FLOW RATE (CC/MIN)	<u>SPRAY ANGLE</u>
SONICORE 35H	22	170	
SPRACO 2163	35	470	65°
SPRACO 1806	43	60	40°
SPRACO 2020	50	460	61°
SPRACO 1405	92	550	20°

DROP SIZE AND CONCENTRATION MEASUREMENTS

INSTRUMENT: HOT WIRE ANEMOMETER
(KLD ASSOCIATES MODEL DC-2)
COUNTS AND SIZES DROPS BASED
ON DROP COOLING

ADVANTAGE: CONVENIENT FOR DROP SIZE
DISTRIBUTIONS IN TUBE AND
IN OPEN AREA

LIMITATION: CONCENTRATION CALCULATION
REQUIRES DROP VELOCITIES



FOG INERTING DATA
FOR H₂ - AIR - H₂O MIXTURES

TEMP (°C)	HYDROGEN LFL No FOG DRY-SAT	(DRY VOL %) DENSE FOG*
20	4.0-4.1	4.6-7.2**
50	4.0-4.7	5.4-7.9**
70	4 -7.7	5.4-8.5

* FOG DENSITY - 10^{-4} - 10^{-2} GM/CC

**HIGHEST VALUE IS FOR SONICORE NOZZLE




Figure 4-3. Fog Concentration as a Function of Drop Size to Achieve indicated Inerting Levels




Figure 4-4. Fog Concentration versus Drop Size Requirements for Inerting to 4.76 Hydrogen at 20°C

CONCLUSIONS

1. DENSE WATER FOGS CAUSE ONLY A SLIGHT INCREASE IN HYDROGEN LFL (FROM 4.0 TO 4.6- 7.2%) AT ROOM TEMPERATURE.
2. FOG INERTING EFFECT IS MORE PRONOUNCED AT HIGHER TEMPERATURES (5.4-7.9% LFL AT 50°C).
3. FOG DENSITIES REQUIRED TO ACHIEVE A GIVEN LFL INCREASE APPROXIMATELY AS SECOND POWER OF CHARACTERISTIC FOG DROP SIZE. PREDICTABLE FROM QUENCHING THEORY AND DROPLET HEAT TRANSFER EQUATIONS.

FACTORY MUTUAL MICRO-FOG

PROJECT OBJECTIVE

Select nominal micro-fog conditions
for hydrogen combustion pressure
suppression tests in the Acurex test
vessel.

FACTORY MUTUAL MICRO-FOG

PROJECT METHODOLOGY

Conduct hydrogen flammability tests
with micro-fogs of varying densities,
droplet sizes, and temperatures.

FACTORY MUTUAL MICRO-FOG

PROJECT TEST PARAMETERS

Droplet size:

2-15 microns (number mean diameter)

Concentration:

$2E-5 - 3E-2 \text{ cm}^3 \text{ H}_2\text{O} / \text{cm}^3 \text{ Mixture}$

Temperature:

20-70 °C

FACTORY MUTUAL MICRO-FOG

PROJECT CONCLUSION

- Dense micro-fogs cause only a marginal increase in the hydrogen lower flammability limit (LFL) at room temperature.
- Increasing the micro-fog temperature results in large increases in the hydrogen LFL.
- Micro-fog densities required to achieve hydrogen inerting are strongly dependent on the micro-fog characteristic drop size.

ACUREX MICRO-FOG PROJECT OBJECTIVE

Investigate the hydrogen combustion
pressure suppression characteristics of
a water micro-fog.

ACUREX MICRO-FOG PROJECT

QUIESCENT TEST MATRIX

HYDROGEN CONCENTRATION V/O	FOG NOZZLE PRESSURE (psi)	
	20	30
5.0	—	—
7.5	—	—
10.7	—	—
10.7	—	X
10.7	X	—
7.5	—	X
7.5	X	—

ACUREX MICRO-FOG PROJECT

TRANSIENT TEST MATRIX

HYDROGEN FLOW (lb/min)		STEAM FLOW (lb/min)	FOG NOZZLE PRESSURE (psi)	
0.035	0.105	2.1	20	30
X	—	—	X	—
X	—	X	X	—
X*	—	—	—	X
—	X	—	—	X
X	—	—	—	X
X	—	X	—	X

* vessel mixing fan on

ACUREX MICRO-FOG
PROJECT CONCLUSIONS

-Fogs apparently generated sufficient turbulence in the quiescent tests for hydrogen deflagrations to behave more adiabatically than in tests without fog.

-Fogs apparently generated sufficient turbulence in the transient tests that the increased mixing allowed ignition to occur earlier, resulting in lower pressure rises.

ACUREX IGNITOR LOCATION

PROJECT OBJECTIVE

Investigate the effect of ignitor location on hydrogen combustion during transient conditions.

**ACUREX IGNITOR LOCATION
PROJECT METHODOLOGY**

Conduct transient hydrogen combustion tests with the ignition source at three different locations. Conduct tests with and without steam and water spray.

ACUREX IGNITOR LOCATION PROJECT TEST MATRIX

IGNITOR LOCATION	HYDROGEN FLOW (lb/min)		STEAM FLOW (gpm)	SPRAY FLOW (lb/min)
	0.035	0.105	2.1	15
TOP	X	-	X	-
TOP	X	-	-	-
BOTTOM	X	-	X	X
BOTTOM	X	-	X	-
BOTTOM	X	-	-	-
BOTTOM	-	X	X	-
BOTTOM	-	X	-	-
CENTER	X	-	X	X
CENTER	X	-	X	-
CENTER	X	-	-	-

ACUREX IGNITOR LOCATION

PROJECT CONCLUSIONS

- Ignitor location does affect combustion characteristics in a transient environment.
- For this test configuration, lowering the ignitor location generally produced a milder pressure rise.

NRC / UTILITY

REVIEW OF EPRI HYDROGEN RESEARCH PROGRAM

AUGUST 4, 1982

HYDROGEN MIXING AND DISTRIBUTION

IN

CONTAINMENT ATMOSPHERES

G.R. BLOOM

L.D. MUHLESTEIN

A.K. POSTMA

HANFORD ENGINEERING DEVELOPMENT LABORATORY

WESTINGHOUSE HANFORD COMPANY

RICHLAND, WASHINGTON 99352


HYDROGEN MIXING IN CONTAINMENT ATMOSPHERES

OBJECTIVE:

- MEASURE HYDROGEN MIXING AND DISTRIBUTION IN SIMULATED LWR ACCIDENT ENVIRONMENT
- PROVIDE EXPERIMENTAL BASIS FOR EVALUATION OF ANALYSIS METHODS.

PROGRAM:

- SCALED COMPARTMENT FABRICATED IN 30,000 ft³ CSTF VESSEL
- HYDROGEN DISTRIBUTION AND MIXING DETERMINED FOR CONDITIONS SIMULATING LOSS OF COOLANT ACCIDENT



CONTENTS

INTRODUCTION

SIMILARITY MODELING

TEST MATRIX

TEST DESCRIPTION

TEST RESULTS

SUMMARY AND CONCLUSIONS

PROGRAM EMPHASIS

DETERMINE HYDROGEN MIXING AND DISTRIBUTION
IN LOWER COMPARTMENT AREA OF LWR ICE
CONDENSER PLANT AFTER TWO POSTULATED
HYDROGEN RELEASE SCENARIOS.

HYDROGEN RELEASE SCENARIOS



1. POSTULATED PIPE BREAK

- * 2-INCH PIPE
- * SONIC VELOCITY JET (2080 FT / SEC)
- * CHOKED FLOW CONDITIONS
- * HOT HYDROGEN / STEAM (600 DEG F - 1220 LBS / MIN)
- * HORIZONTAL RELEASE CONFIGURATION

2. POSTULATED RELEASE FROM PRESSURIZER RELIEF TANK

- * 10-INCH RUPTURE DISK
- * HIGH VELOCITY VERTICAL JET (1200 FT / SEC)
- * HOT HYDROGEN / STEAM (600 DEG F - 1220 LBS / MIN)
- * VERTICAL RELEASE CONFIGURATION

TEST COMPARTMENT SCHEMATIC



* SENSOR LOCATION

SIMILARITY MODELING

SIMILARITY THEORY

SCALE MODEL TEST RESULTS CAN BE APPLIED TO FULL-SCALE SYSTEMS PROVIDED ALL RELEVANT SIMILARITY PARAMETERS (DIMENSIONLESS GROUPS) FOR MODEL AND SYSTEM HAVE SAME NUMERICAL VALUE.

NON-IDEAL MODELING

- * DOMINANT SIMILARITY PARAMETERS IDENTIFIED
- * TEST CONDITIONS SELECTED TO YIELD SIMILARITY FOR ESSENTIAL DIMENSIONLESS GROUPS
- * NON-ESSENTIAL PARAMETERS DISTORTED

GEOMETRICAL SIMILARITY

- * ALL IMPORTANT LENGTH RATIOS TO BE THE SAME FOR MODEL AND PROTOTYPE
- * VESSEL SIZE LED TO A 0.3 LINEAR SCALE FACTOR

DOMINANT MIXING PROCESSES

- * HIGH SPEED JET MIXING
 - DOMINATED IN NEAR AND FAR FIELD BY MOMENTUM FORCES.
 - BOUYANCY FORCES CONTRIBUTE IN FAR FIELD

- * FAN-INDUCED RECIRCULATING AIR FLOW
 - INITIAL MOMENTUM EFFECTS FOLLOWED BY EFFECTS OF BOUYANT FORCES

- * NATURAL CONVECTION FLOWS
 - MOMENTUM FORCES GENERATED BY BOUYANT FORCES

MODELING CRITERIA

SUMMARY

- * PRESERVE GEOMETRIC SIMILARITY
- * PRESERVE DENSIMETRIC FROUDE NUMBER
- * PRESERVE SCALED RELATIVE TIMES
(REQUIRED BECAUSE OF COMPETING MIXING PROCESSES)
- * PRESERVE DENSITY RATIOS OF JET TO AMBIENT ATMOSPHERE

DENSIMETRIC FROUDE NUMBER:

RATIO OF MOMENTUM TO BUOYANCE FORCES

$$\bar{F}_R = \frac{u}{\left(gL \frac{\Delta\rho}{\rho_j}\right)^{1/2}}$$

SAMPLE MODELING CALCULATIONS

PLANT CONDITIONS FOR 2-INCH PIPE BREAK

PARAMETER

STEAM FLOW RATE
HYDROGEN FLOW RATE
GAS TEMPERATURE

} GIVEN

MASS FLUX

SONIC VELOCITY

DENSITY OF GAS EXITING PIPE

GAS PRESSURE

VELOCITY OF EXPANDED JET

DENSITY OF EXPANDED JET

VALUE

1200 LB/MIN

20 LB/MIN

600 °F

870 LB/SEC FT²

2080 FT/SEC


0.42 LB/FT³

300 PSIA

1186 FT/SEC

0.030 LB/FT³

CONCEPT



SAMPLE MODELING CALCULATIONS

<u>PARAMETER</u>	<u>VALUE</u>
<u>PLANT</u>	
GAS VELOCITY	1186 FT/SEC
GAS TEMPERATURE	600 °F
GAS DENSITY	0.030 LB/FT ³
AIR DENSITY	0.068 LB/FT ³
DENSITY RATIO	0.44
FR	201.6
VOLUME TURNOVER TIME	1.9 MIN
	} MODELING CRITERIA
<u>TEST</u>	
GAS TEMPERATURE	300 °F
GAS DENSITY	0.028 LB/FT ³
AIR DENSITY	0.063 LB/FT ³
DENSITY RATIO	0.45
GAS VELOCITY	640 FT/SEC
MASS FLOW RATE	55.7 LB/MIN
	(STEAM 54 LB/MIN; HYDROGEN 1.8 LB/MIN)
RECIRCULATION FLOW RATE	3733 FT ³ /MIN
VOLUME TURNOVER TIME	1.1 MIN

PRELIMINARY TESTS, (HM-P1 THROUGH HM-P4)

DETERMINE SEPARATE AND COMBINED EFFECTS
ON GAS DISTRIBUTION FROM
NATURAL AND FORCED AIR RECIRCULATION.

<u>TEST NUMBER</u>	<u>RECIRCULATION FLOW (CFM)</u>	<u>INITIAL LOWER CONTAINMENT GAS TEMP (F)</u>	
HM-P1	0	85	- NATURAL CONVECTION, AMBIENT GAS TEMPERATURE
HM-P2	3700	85	-- FORCED CONVECTION, AMBIENT GAS TEMPERATURE
HM-P3	0	150	- NATURAL CONVECTION, ELEVATED GAS TEMPERATURE
HM-P4	3700	150	- FORCED CONVECTION, ELEVATED GAS TEMPERATURE

HIGH VELOCITY MIXING TESTS, (HM-1 THROUGH HM-5)

DETERMINE SEPARATE AND COMBINED EFFECTS ON GAS DISTRIBUTION FROM FORCED AIR RECIRCULATION AND MOMENTUM OF HIGH VELOCITY JET



<u>TEST NUMBER</u>	<u>RECIRCULATION FLOW (CFM)</u>	<u>SOURCE</u>	<u>He / H₂ FLOW RATE (LB/MIN)</u>	<u>STEAM FLOW RATE (LB/MIN)</u>	
HM-1	0	He-STEAM	0.9	27	} NATURAL CONVECTION HIGH/LOW JET FLOW
HM-2	0	He-STEAM	1.8	54	
HM-3	3700	He-STEAM	0.9	27	} FORCED CONVECTION HIGH/LOW JET FLOW
HM-4	3700	He-STEAM	1.8	54	
HM-5	3700	H ₂ -STEAM	0.9	54	CONFIRMATORY TEST

HIGH VELOCITY VERTICAL MIXING TESTS (HM-6, HM-7)

DETERMINE GAS DISTRIBUTION RESULTING FROM HYDROGEN/STEAM
RELEASE FROM PRESSURE HALF TANK OR
VERTICAL ORIENTED HIGH VELOCITY JET

<u>TEST NUMBER</u>	<u>RECIRCULATION FLOW (CFM)</u>	<u>SOURCE</u>	<u>He FLOW RATE (LB/MIN)</u>	<u>STEAM FLOW RATE (LB/MIN)</u>	
HM-6	3700	He-STEAM	0.9	27	} FORCED CONVECTION HIGH/LOW JET FLOW
HM-7	3700	He-STEAM	1.8	54	

TEST COMPARTMENT SCHEMATIC



* SENSOR LOCATION

INSTRUMENTATION

- * HYDROGEN / HELIUM CONCENTRATION - TWELVE THERMAL CONDUCTIVITY AND TWO COMBUSTIBLE TYPE ANALYZERS
- * OXYGEN CONCENTRATION - FIVE MONITORS
- * GAS TEMPERATURES - OVER 25 TYPE K THERMOCOUPLES
- * COMPARTMENT GAS VELOCITIES - TEN HOT FILM ANEMOMETERS
- * RECIRCULATION AIR FLOW - TWO HOT FILM ANEMOMETERS

ALL DATA COLLECTED BY DATA ACQUISITION SYSTEM
AND DISPLAYED ON STRIP CHART RECORDERS

INSTRUMENTATION LOCATION

<u>DESIGNATION</u>	<u>LOCATION</u>
TOP	9 INCHES BELOW UPPER DECK
MIDPLANE	7.75 FT UP FROM LOWER DECK
BOTTOM	1.0 FT UP FROM LOWER DECK

<u>SENSOR LOCATION</u>	<u>GAS VELOCITY PROBE</u>	<u>GAS SAMPLE</u>	<u>THERMOCOUPLE</u>
5°, TOP	X	X	X
65°, TOP	X	X	X
125°, TOP	X	X	X
185°, TOP	X	X	X
245°, TOP	X	X	X
5°, MIDPLANE			X
65°, MIDPLANE			X
125°, MIDPLANE	X	X	X
185°, MIDPLANE			X
245°, MIDPLANE			X
5°, BOTTOM	X	X	X
65°, BOTTOM			X
125°, BOTTOM	X	X	X
185°, BOTTOM	X	X	X
245°, BOTTOM	X	X	X

INSTRUMENTATION SENSITIVITY

GAS CONCENTRATIONS


- ° DRY BASIS CONCENTRATION
 - RESOLUTION ± 0.25 VOLUME %
 - ACCURACY ± 0.7 VOLUME %
- ° RESPONSE TIME
 - SAMPLE LINE 10 - 20 SEC
 - SENSOR ~ 50 SEC
 - DATA SYSTEM ~ 26 SEC

TEMPERATURE


- ° TEMPERATURE $\pm 4^{\circ}\text{F}$
- ° RESPONSE TIME
 - SENSOR ~ 20 SEC
 - DATA SYSTEM 0 - 30 SEC


GAS VELOCITIES


- ° LOCAL VELOCITY
 - CALIBRATION ± 0.2 SFPS
 - DIRECTION UNKNOWN
 - + 50%
 - 0%
 - WATER VAPOR CONCENTRATION
 - + 50%
 - NOT ACCOUNTED FOR
 - 0%
- ° RESPONSE TIME
 - SENSOR ~ 1 M SEC
 - DATA SYSTEM ~ 2 SEC




DIMENSIONS IN METERS EXCEPT AS NOTED









SUMMARY RESULTS OF PRELIMINARY TESTS
(HM-P1 - HM-P4)

*LOCAL AVERAGE AIR VELOCITIES

	M/MIN (FT/MIN)		
	NEAR FLOOR	MIDDLE	NEAR TOP
NATURAL CONVECTION ONLY AMBIENT TEMP HM-P1	5 (16)	3 (9)	4 (12)
NATURAL CONVECTION ONLY ELEVATED TEMP HM-P3	17 (57)	---	20 (67)
NATURAL CONVECTION + FORCED CONVECTION AMBIENT TEMP HM-P2	5 (16)	7 (24)	13 (43)
NATURAL CONVECTION + FORCED CONVECTION ELEVATED TEMP HM-P4	27 (87)	---	26 (85)

* + 50% FLOW VELOCITY MAGNITUDE UNCERTAINTY DUE TO UNKNOWN
- 0% FLOW DIRECTION.

TEST FROUDE NUMBER SUMMARY

TEST #	JET \overline{FR} NO.			RECIRCULATION \overline{FR} NO.		
	TARGET	ACTUAL		TARGET	ACTUAL	
		START	END		START	END
HM-1	100	113	137	N/A	N/A	N/A
HM-2	200	234	352	N/A	N/A	N/A
HM-3	100	103	110	0.5	0.54	0.52
HM-4	200	221	265	0.5	0.51	0.42
HM-5	200	185	226	0.5	0.52	0.61
HM-6	100	100	106	0.5	0.64	0.61
HM-7	200	160	205	0.5	0.52	0.46

JET \overline{FR} = 200 FOR PLANT

RECIRCULATION \overline{FR} = 0.5 FOR PLANT


TEST DENSITY RATIOS SUMMARY

<u>TEST NO.</u>	JET		RECIRCULATION	
	$*\rho_J/\rho_A$		$**\rho_R/\rho_A$	
	TARGET = 0.45		TARGET = 1.11	
	<u>START</u>	<u>END</u>	<u>START</u>	<u>END</u>
HM-1	0.59	0.63	---	---
HM-2	0.62	0.74	---	---
HM-3	0.51	0.53	1.11	1.12
HM-4	0.56	0.60	1.12	1.18
HM-5	0.53	0.54	1.12	1.08
HM-6	0.53	0.55	1.07	1.08
HM-7	0.53	0.59	1.11	1.15


* JET $\rho_J/\rho_A = 0.44$ FOR PLANT


** RECIRCULATION $\rho_R/\rho_A = 1.50$ FOR PLANT

TEST: HM-1A HELIUM CONCENTRATION




TEST: HM-2 HELIUM CONCENTRATION







TEST: HM-4C HELIUM CONCENTRATION




TEST: HM-4C GAS VELOCITY
PROBE #1



TEST: HM-5A HYDROGEN CONCENTRATION




TEST: HM-5A HYDROGEN CONCENTRATION




- POINT #1 - 5 Degrees, Upper Elevation
- POINT #6 - 5 Degrees, Lower Elevation
- POINT #7 - 125 Degrees, Lower Elevation
- POINT #9 - 185 Degrees, Lower Elevation


CORRECTED HYDROGEN CONCENTRATION FOR TEST HM-5A
AND MEASURED HELIUM CONCENTRATION FOR TEST HM-4C




TEST: HM-6 HELIUM CONCENTRATION




TEST: HM-7 HELIUM CONCENTRATION



MAXIMUM GAS CONCENTRATION DIFFERENCE
FOR TEST HM-3A, HM-5A, AND HM-7



MAXIMUM GAS CONCENTRATION DIFFERENCE
FOR TEST HM-1A, HM-2, HM-4C, AND HM-6



He/H₂ CONCENTRATIONS CORRECTED FOR WATER VAPOR

TEST NO.	RELEASE GAS	PEAK TEMP. (°F)	MAXIMUM PEAK CONC. DRY BASIS (VOL. %)	MAX. Δ CONC. DRY BASIS (VOL. %)	MAXIMUM PEAK CONC. WET BASIS** (VOL. %)	MAX. Δ CONC. WET BASIS** (VOL. %)
HM-1	He	176	13.5	1.5	7.0	0.3
HM-2	He	198	27.7	2.0	6.3	-0.6
HM-3	He	152	5.4	1.1	3.9	0.6
HM-4	He	174	10.7	0.7	5.8	0.2
HM-5	H ₂	165	8.5	0.4	5.4	0.3
HM-6	He	152	*5.5	1.8	4.0	1.0
HM-7	He	178	11.0	2.3	6.0	-0.5

* ESTIMATE BASED ON EXTROPOLATED DATA SINCE THERE WAS INADVERTANT HIGH He RELEASE RATE FOR LAST ONE MINUTE TEST.

** WET BASIS ESTIMATED ASSUMING ATMOSPHERE IS SATURATED WITH WATER VAPOR AT TEMPERATURE OF GAS.

SUMMARY AND CONCLUSIONS



- * MAXIMUM OBSERVED CONCENTRATION DIFFERENCE WAS 2.5 % DURING THE RELEASE PERIOD FOR THE CONFIGURATION TESTED.
- * GOOD MIXING OCCURS IN THE LOWER COMPARTMENT REGION WITH HIGH VELOCITY JET, FORCED AIR RECIRCULATION AND NATURAL CONVECTION GAS MIXING PROCESSES.
- * STRONG INFLUENCE OBSERVED ON LOCAL AIR VELOCITY FROM NATURAL CONVECTION HEAT TRANSFER AND NATURAL CONVECTION PROVIDES WELL MIXED AIR VOLUME.
- * FORCED AIR RECIRCULATION INCREASES GAS MIXING, DECREASES MAXIMUM HELIUM CONCENTRATION, AND DECREASES MIXING TIME.
- * HIGH VELOCITY HELIUM/STEAM JET RELEASE IS DOMINANT MIXING PROCESS, AND SUBSTANTIALLY INCREASES LOCAL AIR VELOCITIES.


IGNITION EFFECTIVENESS STUDIES


AECL - WNRE.

Objective:

to investigate the effectiveness of hydrogen-air-steam ignition systems particularly near the LFL, in both quiescent & turbulent conditions.










INSTRUMENTATION FOR GLOW PLUG EFFECTIVENESS TESTS
(17 - LITRE VESSEL)

MEASUREMENTS


Initial Conditions: - temperature
 Initial Conditions: - temperature
 - pressure - partial press.
 - concentration - partial press.
 - mass spec.

Transient Conditions: - ignition \Rightarrow combustion
 Transient Conditions: - ignition \Rightarrow combustion
 - pressure \Rightarrow peak
 - temperature of air \Rightarrow peak
 - glow plug temp. \Rightarrow ignition temp.
 - glow plug temp. \Rightarrow ignition temp.


Final Conditions: - pressure
 Final Conditions: - pressure
 - concentration (mass spec)
 - concentration (mass spec)



// OBSERVED TRANSIENTS IN THE IGNITER EFFICIENCY TEST. A GM AC NO.7 GLOW PLUG OPERATED AT 12 VAC IN A 12.9%-HYDROGEN / 17.4%-STEAM / 69.7%-AIR MIXTURE IN A 17-LITRE VESSEL.



- 12 OBSERVED TRANSIENTS IN THE IGNITER EFFICIENCY TEST. A GM AC NO. 7 GLOW PLUG OPERATED AT 12 VAC IN A 12.9% - HYDROGEN / 17.4% - STEAM / 69.7% - AIR MIXTURE IN A 17-LITRE VESSEL.



27. OBSERVED TRANSIENTS IN THE IGNITER EFFICIENCY TEST. A GM AC NO. 7 GLOW PLUG OPERATED AT 14 VAC IN A 10%-HYDROGEN / 37.2%-STEAM / 48.8%-AIR MIXTURE IN A 17-LITRE VESSEL.






FIGURE 11. - The flammability domain for upward flame propagation for H₂-Air-H₂O(vapor) mixtures. The flammability limit curve is superimposed on the isobaric contours of calculated, adiabatic explosion pressures.



THE IGNITION LIMITS OF HYDROGEN/AIR/STEAM MIXTURES USING A GM AC MODEL NO. 7 THERMAL GLOW PLUG LOCATED AT THE CENTRE OF A 17-LITRE QUASI-SPHERICAL VESSEL.



GLOW PLUG TEMP. @ IGNITION!
 VS.
 STEAM CONCENTRATION!

CTF Experiments

1. Extent of reaction of lean mixtures

$$4\% < H_2 < 10\%$$

$$0\% \leq H_2O \leq 30\%$$

2. Laminar Spherical Deflagrations


$$10\% \leq H_2 \leq 42\%$$

$$0\% \leq H_2O \leq 30\%$$

3. Effect of Turbulence Induced by Fans & Obstacles


2 fans w/ air deflectors
& continuously variable speed
(7 air changes/min/fan)

horizontal gratings
@ $\frac{1}{3}$ points
1" holes in $\frac{1}{4}$ " plate,
50% blocked area




lean mixtures & richer (10-20%) mixture

4. Sphere & Protruding Pipe



x ignition points








Figure 1: ARRANGEMENT OF FANS IN THE SPHERE AND INSTRUMENTATION




QUENCHING AT THE WALL



FIRE BALL


UPWARD PROPAGATION ONLY




FIRE BALLS


UPWARD FOLLOWED BY
DOWNWARD PROPAGATION

SCHEMATIC OF FLAME PROPAGATION




COMBUSTION NEAR LOWER LIMIT FOR UPWARD FLAME PROPAGATION







EFFECT OF INITIAL TURBULENCE ON H₂ BURN



EFFECT OF INITIAL TURBULENCE ON COMBUSTION




RELATIVE EFFECTS OF STEAM AND TURBULENCE



EFFECT OF IGNITOR LOCATION

Bottom Ignition



HYDROGEN CONCENTRATION, VOL %

PEAK PRESSURE, kPa

Pressure 98 kPa
Temperature 100°C

△ Bottom Ignition
□ Top Ignition

Minimum Concentration for
Downward Propagation

Fan off

Fan on

Series 1 - Near LFL

- small amounts of steam do not markedly affect nature & extent of combustion
- bottom ignition is faster & more complete
- fan-induced turbulence increases rate & extent of combustion
- steam inhibition is more evident with central than with bottom ignition.




Figure 4: EFFECT OF STEAM ON THE EXTENT OF BURN




Figure 3: EFFECT OF STEAM AT HIGH CONCENTRATIONS




Figure 5: COMPARISON BETWEEN PREDICTED AND OBSERVED PRESSURE RISE




Figure: Comparison Between the Predicted and Observed Pressure Rise




Figure: Comparison Between the Predicted and Observed Pressure Rise




Figure: Comparison Between Predicted and Observed Pressure Rise




Figure: Comparison Between Predicted and Observed Pressure Rise




Figure 2: EFFECT OF STEAM ON COMBUSTION UNDER QUIESCENT CONDITIONS




Figure 5(b): THEORETICAL PRESSURE RISE AT 10% HYDROGEN




Figure 6: COMPARISON OF PRESSURE-TIME HISTORY OF
 MAXIMUM BURNING VELOCITY AND STOICHIOMETRY




Figure 7: EFFECT OF TURBULENCE ON COMBUSTION

Series 2

- measured peak pressures $<$ adiabatic, particularly with steam
- fan-induced turbulence effect less pronounced than for Series 1
- combustion time is shortest for a dry stoichiometric mixture




Figure 8: SCHEMATIC OF THE ARRANGEMENT OF
GRATINGS IN THE SPHERE




Figure 11: EFFECT OF GRATINGS ON COMBUSTION IN THE PRESENCE OF TURBULENCE




Figure 9: EFFECT OF GRATINGS ON COMBUSTION AT LOW HYDROGEN CONCENTRATIONS





Figure 10: EFFECT OF GRATINGS ON COMBUSTION AT HIGH HYDROGEN CONCENTRATIONS

Gratings


- increase the extent of combustion and (to a lesser extent) the rate, @ low (ca 6%) concentrations
- @ high H_2 conc. (>10%) gratings act as heat sinks, reducing the peak pressure
- with fan turbulence, ^{gratings} reduced combustion rate & peak pressure.



- pz1 to 7 pressure transducers
- T1 to T6 thermocouples
- 1P, 3P Rosemount transmitters
- lg1, lg2 igniters
- x 33.75 inches spacing

SCHEMATIC OF THE INSTRUMENTED PIPE & SPHERE

FIG. 1






FIG.3





FIG. 4






FIG.6






FIG 7








FIG. 10




FIG. 11




FIG.12

Central Ignition
Hydrogen 20%




FIG. 14

Central Ignition
Hydrogen 20%






FIG.13

Central Ignition

H₂ 25%
Press. 14.2 psi
Temp 24°C








FIG.17


Series 4a

— pipe-end
ignition

— sphere-centre
ignition

—


- for H_2 conc $<$ upward-downward limits, the flame propagates only along top of pipe & virtually no combustion results in sphere
- with fan-induced turbulence, a fully developed flame returns to the pipe
- higher flame speeds are observed with sphere-central ignition
- large acoustic oscillations are seen in the pipe for $H_2 \geq 20\%$
- peak pressures $>$ adiabatic are seen for very high H_2 concentrations.





- pz-1 to pz-7 Pressure Transducers
- t₁ to t₆ Thermocouples
- 1p, 3p Rosemount Transmitters
- lc, le Igniters


Thermocouple spacing 857 mm


SCHEMATIC OF THE INSTRUMENTED PIPE & SPHERE




















acceleration after the best-fit


Pipe-end Ignition
Hydrogen pipe 15% ; sphere 20%
Pressure 98 kPa
Temperature 25°C

Pressure Rise, MPa

Time After Ignition, s

*adiabatic for 20%
= 680 kPa*

pipe



Series 4b

- presence of constriction inhibits flame acceleration
- turbulence produced by constriction, increases combustion rate in sphere.

With rupture disc:

- @ high H_2 in pipe, turbulence produced by sudden rupture increases the extent & rate of combustion in sphere
- disc rupture sets up pressure oscillations during combustion in sphere.




Figure 4-1 . Liquid-Vapor Conversion and Water Vapor Saturation Relationships





Figure 4-2. Detonation and flammability limits for air-hydrogen-steam mixtures
 Data Points represent water fog inerting data obtained
 in this study for nozzles and include water vapor saturation
 concentrations (Curves are from ref. 6)

Table 4-3

HYDROGEN-WATER FOG INERTING DATA AT ~70°C

Nozzle	Press. (psi)	Vol. Mean Dia. Micron	No. Median Micron	Conc.	$\frac{\text{cm}^3 \text{H}_2\text{O}}{\text{cm}^3 \text{Mix}}$	$\text{H}_2\text{O Flux}$ $\text{cm}^3/\text{cm}^2 \text{min}$	$\text{H}_2\text{O Inerting Conc.}$ (%)
Spraco	10	-	-	-	-	-	6.76
2163-7604	20	-	-	-	-	-	7.18
	30	-	-	-	-	-	7.62
	40	-	-	-	-	-	8.46
Spraco	10	-	-	-	-	-	5.88
1405-0604	20	-	-	-	-	-	6.32
	30	-	-	-	-	-	7.62
	40	-	-	-	-	-	7.67
Spraco	10	-	-	-	-	-	4.98
1806-1605	20	-	-	-	-	-	5.43
	30	-	-	-	-	-	5.43
	40	-	-	-	-	-	5.43



COMPARISON OF EXPERIMENT AND THEORY FOR 7.2% HYDROGEN IN AIR AT 50°C

EPRI/NRC HYDROGEN PROJECT REVIEW

HYDROGEN CONTROL STUDIES

BY

RAYMOND C. TOROK


FEBRUARY 3, 1982

TEST SPECIFICATION


- ACCIDENT SCENARIOS
 - PREHEAT
 - QUIESCENT BURNS
 - TRANSIENT BURNS
 - STEAM INJECTION
 - SPRAY

- TEST PARAMETERS
 - HYDROGEN CONCENTRATION
 - HYDROGEN INJECTION RATE
 - INITIAL TEMPERATURE
 - STEAM INJECTION
 - WATER CONCENTRATION/DROP SIZE
 - IGNITOR LOCATION

HYDROGEN CONTROL STUDIES
MECHANICAL SCHEMATIC



HYDROGEN CONTROL STUDIES INSTRUMENTATION LOCATIONS



TEST PROCEDURES

- QUIESCENT

SEAL VESSEL

PREHEAT

INJECT H_2

SAMPLE GAS

IGNITOR ON

BURN

SAMPLE GAS

PURGE + COOL

- DYNAMIC

SEAL VESSEL

PREHEAT

IGNITOR ON

START H_2 FLOW, STEAM FLOW

BURN


STOP H_2 , STEAM

SAMPLE GAS

PURGE + COOL


FLAME FRONT PROPAGATION -- TEST 2.8

$T_0 = 127 \text{ SEC}$




0.105 LBM/MIN HYDROGEN
BOTTOM IGNITOR
NO STEAM FLOW
NO SPRAY

FLAME FRONT DETECTORS




5 CHANNELS
7 FFD'S PER CHANNEL




1 CHANNEL OUTPUT

FLAME FRONT ACTIVITY -- TEST 3.1

GLOBAL
DISCRETE






QUIESCENT
10.7% HYDROGEN
MICROFOG



QUIESCENT BURN -- TEST 3.1

TEST 3.1




10.7 V/O HYDROGEN

MICROFOG

BOTTOM IGNITOR

FLAME FRONT ACTIVITY -- TEST 3.5

(LOCAL
INTERMITTENT)




DYNAMIC
0.035 LBM/MIN HYDROGEN
MICROFOG




FLAME FRONT ACTIVITY -- TEST 2.7


GLOBAL INTERMITTENT
GLOBAL DISCRETE




DYNAMIC
0.105 LBM/MIN HYDROGEN
2.1 LBM/MIN STEAM



PRESSURE AND TEMPERATURE -- TEST 2.7





DYNAMIC
.035 lbm/min H₂
2.1 lbm/min steam
20 PSI fog

SPRAY EFFECTS -- DYNAMIC INJECTION TESTS

0.035 LBM/MIN H₂. BOTTOM IGNITOR

	TEST	SPRAY	MAX ΔP, PSI	GAS ANALYSIS		
				BURN ^A	H ₂	O ₂
W/O STEAM	2.6	--	28	GD, LI	2.1	12
	3.5	20 PSI FOG	2.0	LI	3.3	5.8
	3.9	30 PSI FOG	1	LI	0.1	9.2
W/STEAM	2.5	--	4.5	LI, LD	7.9	5.7
	2.4	SPRAYCO 1713	1	LI	5.5	5.1
	3.6	20 PSI FOG	5.0	LD	6.2	5.1
	3.10	30 PSI FOG	1.6	LD	3.7	3.7

^AL -- LOCAL
G -- GLOBAL

I -- INTERMITTENT
D -- DISCRETE

HYDROGEN CONTROL TESTS -- SUMMARY

QUIESCENT

IGNITION IN ALL TESTS
BURN COMPLETE WITH H₂ 7.5 V/O
MAX ΔP 50 PSI

DYNAMIC

IGNITION IN ALL TESTS

	<u>MAX ΔP</u>
0.035 LBM/MIN H ₂ W/O STEAM	28
0.035 LBM/MIN H ₂ W STEAM	13
0.105 LBM/MIN H ₂ W/O STEAM	23.5
0.105 LBM/MIN H ₂ W STEAM	24
ALL FOG AND SPRAY CASES	5

EQUIPMENT SURVIVABILITY

I. BASED ON NRC QUESTIONS SEPTEMBER 1981 TVA REANALYZED EQUIPMENT ASSUMMING:

- A. 1ft/sec flame speed
- B. A separate radiative heat transfer term

II. MODEL VERIFICATION

- A. Showed the model with same heat transfer coefficients melted teflon on thermocouple wire
- B. Excellent reproduction of Westinghouse results for a transmitter thermal response to a MSLB

III. CONCLUSIONS

- A. Temperatures very reasonable—
all equipment will survive*

- B. Adresses all outstanding NRC
concerns discussed with TVA or ACRS*