

DCS MS-016

OCT 8 1982

Docket Nos. 50-266
and 50-301

Mr. C. W. Fay
Assistant Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Fay:

DISTRIBUTION:

✓ Docket File
NRC PDR
L PDR
NSIC
ORB#3 Rdg
DEisenhut
JHeltemes
OELD
ELJordan
JMTaylor
RAClark
PMKreutzer-3
TColburn
ETourigny
Gray File
ACRS-10

IE Bulletin 80-04 "Analysis of a PWR Main Steam Line Break With Continued Feedwater Addition" was issued on February 8, 1980. This bulletin directed all licensees of pressurized water reactors (PWRs) to review the containment pressure response analysis to determine if the potential for containment overpressurization exists for the case of a main steam line break with continued feedwater addition. If this potential was determined to exist, licensees were to propose corrective action.

You responded to IE Bulletin 80-04 and our additional information request (February 26, 1982) by letters dated April 25, 1980, April 14, 1982 and May 4, 1982.

We and our consultant, Franklin Research Center, have completed our review of your analysis of a main steam line break with continued feedwater addition for Point Beach Nuclear Plant, Units 1 and 2. Our review is contained in the attached Safety Evaluation.

Based on our review, we conclude that your analysis is acceptable and no further action is required regarding this subject.

Sincerely,

Original signed by
Robert A. Clark

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
As stated

cc: See next page

8211080185 821008
PDR ADOCK 05000266
Q PDR

| | | | | | | | |
|---------|------------------------|-------------------------|-----------------------|---------------------|--|--|--|
| OFFICE | ORB#3:DL PMKreutzer | ORB#3:DL TColburn/pn | ORB#3:DL ETourigny | ORB#3:DL RAClark | | | |
| SURNAME | | | | | | | |
| DATE | 10/8/82 | 10/8/82 | 10/8/82 | 10/8/82 | | | |

Wisconsin Electric Power Company

cc:

Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
114 N. Carroll Street
Madison, Wisconsin 53703

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: Regional Radiation
Representative
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702

Regional Administrator
Nuclear Regulatory Commission, Region III
Office of Executive Director for Operations
799 Roosevelt Road
Glen Ellyn, Illinois 60137