



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

November 1, 1982

ØCAN1182Ø3

Mr. Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: Arkansas Nuclear One - Units 1 & 2
Docket No. 50-313 & 50-368
License No. DPR-51 & NPF-6
Request for Additional Information
to Appendix R Compliance Submittal

Gentlemen:

As documentation for our telephone conversation on October 29, 1982, with Mr. Vince Panciera the following additional information is provided concerning our response to Item 6, High/Low Pressure Interfaces, in our October 5, 1982 letter (ØCAN1Ø82Ø3) to you.

An isolation device will be provided "locally" to permit control of the ANO-1 pressurizer ERV block valve as part of our control room alternate shutdown system defined in Appendix A of our July 1, 1982 Appendix R submittal.

Very truly yours,

John R. Marshall
Manager, Licensing

JRM:LVP:s1

A006

8211090011 821101
PDR ADOCK 05000313
F PDR