



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

IOWA ELECTRIC LIGHT AND POWER COMPANY
CENTRAL IOWA POWER COOPERATIVE
CORN BELT POWER COOPERATIVE

DOCKET NO. 50-331

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 78
License No. DPR-49


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Iowa Electric Light & Power Company, et al, dated August 16, 1977 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-49 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 78, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 27, 1982

ATTACHMENT TO LICENSE AMENDMENT NO.78

FACILITY OPERATING LICENSE NO. DPR-49

DOCKET NO. 50-331

Revise the Appendix A Technical Specifications by removing page 6.11-8 and inserting revised page 6.11-8. The revised area is identified by a vertical line.

Note: Leakage of valve packing or gaskets within the limits for identified leakage set forth in technical specifications need not be reported under this item.

- (4) Reactivity anomalies, involving disagreement with the predicted value of reactivity balance under steady state conditions during power operation, greater than or equal to $1\% \Delta k/k$; a calculated reactivity balance indicating a shut-down margin less conservative than specified in the technical specifications; short-term reactivity increases that correspond to a sustained reactor period of less than 5 seconds or, if sub-critical, an unplanned reactivity insertion of more than $0.5\% \Delta k/k$ or occurrence of any unplanned criticality.
- (5) Failure or malfunction of one or more components which prevents or could prevent, by itself, the fulfillment of the functional requirements of system(s) used to cope with accidents analyzed in the SAR.
- (6) Personnel error or procedural inadequacy which prevents or could prevent, by itself, the fulfillment of the functional requirements of systems required to cope with accidents analyzed in the SAR.

Note: For items 6.11.2.a(5) and 6.11.2.a(6) reduced redundancy that does not result in a loss of system function need not be reported under this section but may be reportable under items 6.11.2.b(2) and 6.11.2.b(3) below.