LICENSEE EVENT REPORT

	LICENSEE EVENT REPORT
CON	TROL BLOCK:
01	A D A C 1 2 0 0 - 0 0 0 0 - 1 0 0 0 0 0 0 0 0 0
1011	OURCE 50 0 15 10 10 10 13 3 1 1 0 1 1 4 8 2 1 1 0 2 9 8 2 9
	roescription and probable consequences (10) uring normal operation the 'B' river water supply system (RWSS) traveli
0]3 [n	g screen wash pump, 1P-112B, was found inoperable. The 'B' RWSS was dec
014 1	ared inoperable and a 7-day LCO was entered per T.S.3.5.J.2. The 'A' RW
015 5	S was operable. The 7-day LCO was lifted after approximately one day wh
016 Le	n 1P-112B was proven operable. There have been no previous similar occu
07 Lr	rences with 1P-112B.
08	
0 9	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
0	ER/RO EVENT YEAR AEPORT NO. COOR TYPE NO.
L A	SE DESCRIPTION AND CORRECTIVE ACTIONS (27)
	ne coupling between 1P-112B pump and motor components was broken due to
m Lr	andom failure. The coupling was replaced and 1P-112B was functionally t
112 e	sted with satisfactory results. The coupling for 1P-112A is to be check
113 Le	d for wear.
TI L	
TS E	TO NA OTHER STATUS (30) NA OTHER STATUS (30) NETHOO OF OISCOVERY DESCRIPTION (32) (31) Operator Observation (32)
ACTIVITA	CONTENT TO OF RELEASE AMOUNT OF ACTIVITY 35
17 0	ASONNEL EXPOSURES OF SCRIPTION 39 11 12 13
	ASONNEL INJURIES DESCRIPTION 41
1 9 7	DESCRIPTION 43
ISSUED	DESCRIPTION (4) PDR ADDCK 05000331 PDR ADDCK 05000331
	NAME OF PREPARER Kimuel L. Hill PHONE: 319-851-5611