



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 4, 1982

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Only One of Two Required ECCS
Systems Operable Due to RHR
Associated Standby Diesel
Generator Out of Service
Reference: LER 82-091/03 L-0
AECM-82/526

NOV 5 11:56
USNRC REGION II
ATLANTA, GEORGIA

With the plant in Cold Shutdown, the LPCS System was taken out of service to perform Surveillance Procedure 06-ME-1M61-V-0001. This resulted in only one of the two required ECCS Systems being operable. This event is being reported per T.S.3.5.2 and T.S.6.9.1.13.b. Attached is LER 82-091/03 L-0.

Yours truly,

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8211090144 821104
PDR ADOCK 05000416
S PDR

OFFICIAL COPY
IE 22