

NOV 5 1982

NOTE TO: CRGR Members

Enclosed is a copy of the CRGR activities monthly report for the period October 2, 1982 through October 31, 1982, and open items from previous meetings. The report will be included in the EDO's Weekly Report to the Commission for the week ending November 5, 1982.

Walt Schwink
DEDROGR Staff

Enclosure:
As stated

Distribution
VStello
TMurley
DEDROGR cf
DEDROGR Staff
Central File
PDR (NRG/CRGR)

8211090229 821105
PDR REVGP NRGCRGR
PDR

R-001

OFFICE	DEDROGR	DEDROGR					
SURNAME	Schwink	Murley					
DATE	10/25/82	10/27/82					

NUCLEAR REGULATORY COMMISSION

COMMITTEE TO REVIEW
GENERIC REQUIREMENTS

*** CRGR SUMMARY OF ACTIVITIES ***
10/2/82 THROUGH 10/31/82

<u>ITEM NO.</u>	<u>ITEM DESCRIPTION</u>	<u>LATEST CRGR STATUS</u>
820036	Briefing concerning the NRR recommendations on the issue of pressurized thermal shock (Unresolved Safety Issue A-49).	The Committee made recommendations concerning implementation of NRR's proposed actions. The Committee also requested additional information concerning costs and benefits of near term flux reduced measures. (see Item No. 820039 concerning CRGR consideration of the additional information.)
ORIG. OFC: NRR	CATEGORY: 2	ITEM RECD: 9/22/82
		CRGR REVIEW: 10/06/82
		COMPLETED: Action NRR

820037	Review of the proposed IE bulletin to address corrosion cracking in thick-wall large diameter stainless steel recirculation system piping at BWR plants.	The Committee recommended that the bulletin be issued after taking into account the Committee's recommendations. The bulletin was issued on 10/14/82.
ORIG. OFC: IE	CATEGORY: 1	ITEM RECD: 10/07/82
		CRGR REVIEW: 10/08/82
		COMPLETED: 10/08/82

NUCLEAR REGULATORY COMMISSION

COMMITTEE TO REVIEW
GENERIC REQUIREMENTS

*** CRGR SUMMARY OF ACTIVITIES ***
10/2/82 THROUGH 10/31/82

<u>ITEM NO.</u>	<u>ITEM DESCRIPTION</u>	<u>LATEST CRGR STATUS</u>
820038	Continued discussion of the reactor coolant pump trip issue which was discussed at CRGR Meeting #20.	At CRGR Meeting #20, the Committee deferred making recommendations concerning this issue until additional information was developed by the staff. After considering this information at CRGR meeting #22, the Committee generally agreed with the NRR approach but made recommendations for changes in the method for implementing their approach.
ORIG. OFC:	NRR	CATEGORY: 2
ITEM RECD:	10/07/82	CRGR REVIEW: 10/08/82
COMPLETED:	10/08/82	

820039	Continued discussion of the pressurized thermal shock (PTS) issue which was discussed at CRGR Meeting #21 (see Item No. 820036).	The Committee generally agreed with the proposed NRR approach but made recommendations for near term actions to resolve this issue.
ORIG. OFC:	NRR	CATEGORY: 2
ITEM RECD:	10/14/82	CRGR REVIEW: 10/28/82
COMPLETED:	10/28/82	

NUCLEAR REGULATORY COMMISSION

COMMITTEE TO REVIEW
GENERIC REQUIREMENTS

*** OPEN ITEMS FROM PREVIOUS MEETINGS ***

<u>ITEM NO.</u>	<u>ITEM DESCRIPTION</u>	<u>LATEST CRGR STATUS</u>
810001	IE Bulletin on Elastomers (Viton) used in ASCO NP-1 valves.	Returned to IE 11/25/81 for reassessment of safety benefits: to be resubmitted to CRGR after reassessment.
ORIG. OFC: IE	CATEGORY: 2	ITEM RECD: 11/13/81
		CRGR REVIEW: 11/19/81
		COMPLETED: (Action-IE)

820014	Proposed Post CP Change Rule	Requested future CRGR review when staff work has been completed.
ORIG. OFC: RES	CATEGORY: 2	ITEM RECD: 01/20/82
		CRGR REVIEW: 02/24/82
		COMPLETED: (Action-RES)
