# BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of

CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.

(Perry Nuclear Power Plant, Units 1 and 2) Docket Nos. 50-440 OL 50-441 OL

NRC STAFF SUPPLEMENTAL ANSWERS TO FOURTH SET
OF INTERROGATORIES TO STAFF BY THE OHIO
CITIZENS FOR RESPONSIBLE ENERGY

The following are the NRC Staff's supplemental voluntary answers in response to the fourth set of interrogatories by the Intervenor Ohio Citizens for Responsible Energy (OCRE).  $\frac{1}{2}$ 

Respectfully submitted,

Nathene A. Wright Counsel for NRC Staff

Dated at Bethesda, Maryland this 8th day of November 1982

DESIGNATED ORIGINAL

Certified By\_

050

Ohio Citizens for Responsible Energy Fourth Set of Interrogatories to NRC Staff, dated August 30, 1982.

## Interrogatory 4-2

In the Staff's opinion, could suppression pool swell hydrodynamic loading on the SDV, SDIV, or HCUs and asociated piping cause pipe breaks or any other damage to these components? Could pool swell disrupt instrumentation in the SDIV or valves in the HCU, thereby impairing the scram function?

## Response

The Staff objects to this interrogatory on the grounds that it seeks information which is irrelevant to the contentions admitted in this proceeding, see 10 C.F.R. § 2.740(b)(1), in that with respect to the pertinent contention, Issue #5, the occurrence of the break is assumed.

## Interrogatory 4-3

Would water from an SDV pipe break flashing to steam pressurize the containment? Would this condition harm any equipment located in the containment which was not qualified for this condition?

## Response

An SDV pipe break will pressurize the containment. The PNPP applicant has performed analyses for a number of postulated primary system breaks. These analyses, which are described in Section 6.2 of the PNPP FSAR, include a double-ended rupture of the recirculation line, a double-ended rupture of a main steam line, an intermediate size rupture of a liquid line, and a small size rupture of the steam line. Since the break area of the SDV system piping is within the spectrum of the pipe breaks considered by PNPP, the limiting containment pressure and temperature profiles have been determined. Therefore, since all safety related equipment is qualified to perform its extended function within this spectrum, the equipment will be able to perform at the less severe environment associated with an SDV pipe break.

## BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of

CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.

(Perry Nuclear Power Plant, Units 1 and 2) Docket Nos. 50-440 OL 50-441 OL

## AFFIDAVIT OF THOMAS A. GREENE

- I, Thomas A. Greene, being duly sworn, state as follows:
- I am a containment systems engineer in the Division of Systems Integration, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission.
- 2. I am the NRC staff member responsible for the responses to Interrogatory No. 4-3 of "Ohio Citizens for Responsible Energy Fourth Set of Interrogatories to the Staff" dated August 30, 1982.
- This response is true and accurate to the best of my knowledge and pelief.

Respectfully submitted.

Thomas A. Greene

Sworn and subscribed before me this 8th day of November 1982

Notary Public

My commission expires:

7/1/86

# BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of

CLEVELAND ELECTRIC ILLUMINATING

COMPANY, ET AL.

(Perry Nuclear Power Plant,
Units 1 and 2)

Docket Nos. 50-440 OL
50-441 OL

## NOTICE OF WITHDRAWAL

Notice is hereby given that effective November 8, 1982, I will withdraw my appearance in the above captioned proceeding. All mail and service lists should be amended to delete my name after that date.

Nathene A. Wright Counsel for NRC Staff

## BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of )		
CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.	Docket Nos.	50-440 OL 50-441 OL
(Perry Nuclear Power Plant, ) Units 1 and 2)		

## CERTIFICATE OF SERVICE

I hereby certify that copies of "NRC STAFF SUPPLEMENTAL ANSWERS TO FOURTH SET OF INTERROGATORIES TO STAFF BY THE OHIO CITIZENS FOR RESPONSIBLE ENERGY" and "NOTICE OF WITHDRAWAL" in the above-captioned proceeding have been served on the following by deposit in the United States mail, first class, or, as indicated by an asterisk through deposit in the Nuclear Regulatory Commission's internal mail system, this 8th day of November 1982:

\*Peter B. Bloch, Esq., Chairman
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

\*Dr. Jerry R. Kline
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

\*Mr. Frederick J. Shon
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Jay Silberg, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Susan Hiatt 8275 Munson Avenue Mentor, Ohio 44060

Daniel D. Wilt, Esq. P. O. Box 08159 Cleveland, Ohio 44108

Terry Lodge, Esq. Attorney for Intervenors 915 Spitzer Building Toledo, Ohio 43604

John G. Cardinal, Esq. Prosecuting Attorney Ashtabula County Courthouse Jefferson, Ohio 44047

- \*Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington, D.C. 20555
- \*Atomic Safety and Licensing Appeal Board Panel U.S. Nuclear Regulatory Commission Washington, D.C. 20555
- \*Docketing and Service Section Office of the Secretary U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Nathene A. Wright

Counsel for NRC Staff