

BOSTON EDISON COMPANY
PROMPT REPORTABLE OCCURRENCE
TELECOPY MESSAGE

TO: (215) 337-5324
Telephone Number

DATE/TIME: Oct. 29, 1982 1000

TO: Director, Region I
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

FROM: Pilgrim Nuclear Power Sta.
RFD#1, Rocky Hill Road
Plymouth, MA 02360

Docket Number 50-293
License DPR-35

Assigned LER Number 82-046/01X-0

Reported per T,S,Section 6.9.B.1.e.

Event Description: At 2330 hours on October 28, 1982 the HPCI System was
declared inoperable. Investigations to determine the source of ground detector
indication on the 'B' 125VDC Station Battery uncovered a short to ground in the
limit switches for HPCI Steam Supply Valve MO 2301-3.

Cause and Corrective Action: The cause is primarily attributed to a steam
leak from the valve's stem packing. Repairs and required surveillance testing
are in progress.

Facility Status:

70 % Thermal MW

c) Routine Startup	_____	g) Shutdown	_____
d) Routine Shutdown	_____	h) Refueling	_____
e) Steady State	_____	i) Other	_____
f) Load Changing	<u>X</u>	j) Not Applicable	_____

A written followup report will be sent within two weeks.

NRC Person Notified H. Eichenholz

Prepared by M. Thomas McLoughlin

8211090324 821029
PDR ADOCK 05000293
S PDR

Mail (2) copies to:

Director
Office of Management Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

cc: Standard LER Distribution

IE 29