

January 2, 1991

Docket No. 50-155

DISTRIBUTION

Mr. William L. Beckman
Plant Manager
Big Rock Point Nuclear Plant
10269 US 31 North
Charlevoix, Michigan 49720

| | |
|---------------|-------------|
| Docket File ✓ | PD31 R/F |
| NRC & LPDRs | GHill (4) |
| JZwolinski | Wanda Jones |
| SMeador | JCalvo |
| AMasciantonio | ACRS (10) |
| OGC | EJordan |
| DHagan | GPA/PA |
| ARM/LFMB | |

Dear Mr. Beckman:

SUBJECT: AMENDMENT NO. 105 TO FACILITY OPERATING LICENSE NO. DPR-6:
(TAC NO. 77536)

The Commission has issued the enclosed Amendment No. 105 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications in response to your application dated August 15, 1990.

This amendment would modify Technical Specification 1.1.4 in accordance with the guidance in Generic Letter 89-14, "Line Item Improvement in Technical Specifications - Removal of the 3.25 Limit on Extending Surveillance Intervals." Technical Specification 1.1.4 currently permits surveillance intervals to be extended up to 25 percent of the specified interval. However, the Technical Specification limits the combined time interval for any three consecutive surveillances to less than 3.25 times the specified interval. The proposed change would delete the 3.25 extension limitation. The surveillance interval will still be constrained by the 25 percent interval extension criterion of T/S 1.1.4.

A copy of our related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Armando Masciantonio, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

- Amendment No. 105 to License No. DPR-6
- Safety Evaluation

cc w/enclosures:

See next page

LA/PD31:DRP345

asm
PM/PD31:DRP345

Am
D/PD31:DRP345

OGC *Elb*

~~NRR:OTSB~~

SMeador:dr

AMasciantonio

LMarsh

E. HOLLER

~~TDunning~~

12/17/90 *SM*

12/20/90

12/20/90

12/18/90

1/1/90

[BIG ROCK AMD 105]

9101090232 910102
PDR ADDCK 05000155
P PDR

DF01
11

January 2, 1991

Docket No. 50-155

DISTRIBUTION

Mr. William L. Beckman
Plant Manager
Big Rock Point Nuclear Plant
10269 US 31 North
Charlevoix, Michigan 49720

Docket File
NRC & LPDRs
JZwolinski
SMeador
AMasciantonio
OGC
DHagan
ARM/LFMB

PD31 R/F
GHill (4)
Wanda Jones
JCalvo
ACRS (10)
EJordan
GPA/PA

Dear Mr. Beckman:

SUBJECT: AMENDMENT NO. 105 TO FACILITY OPERATING LICENSE NO. DPR-6:
(TAC NO. 77536)

The Commission has issued the enclosed Amendment No. 105 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications in response to your application dated August 15, 1990.

This amendment would modify Technical Specification 1.1.4 in accordance with the guidance in Generic Letter 89-14, "Line Item Improvement in Technical Specifications - Removal of the 3.25 Limit on Extending Surveillance Intervals." Technical Specification 1.1.4 currently permits surveillance intervals to be extended up to 25 percent of the specified interval. However, the Technical Specification limits the combined time interval for any three consecutive surveillances to less than 3.25 times the specified interval. The proposed change would delete the 3.25 extension limitation. The surveillance interval will still be constrained by the 25 percent interval extension criterion of T/S 1.1.4.

A copy of our related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Armando Masciantonio, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 105 to License No. DPR-6
2. Safety Evaluation

cc w/enclosures:
See next page

LA/PD31:DRP345
SMeador:dr
12/1/90

asm
PM/PD31:DRP345
AMasciantonio
12/20/90

Am
D/PD31:DRP345
LMarsh
12/20/90

OGC *2/6*
E. H. ...
12/27/90

~~NRR:OTS
TDunning
1/1/90~~

[BIG ROCK AMD 105]



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

January 2, 1991

Docket No. 50-155

Mr. William L. Beckman
Plant Manager
Big Rock Point Nuclear Plant
10269 US 31 North
Charlevoix, Michigan 49720

Dear Mr. Beckman:

SUBJECT: AMENDMENT NO. 105 TO FACILITY OPERATING LICENSE NO. DPR-6:
(TAC NO. 77536)

The Commission has issued the enclosed Amendment No. 105 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications in response to your application dated August 15, 1990.

This amendment would modify Technical Specification 1.1.4 in accordance with the guidance in Generic Letter 89-14, "Line Item Improvement in Technical Specifications - Removal of the 3.25 Limit on Extending Surveillance Intervals." Technical Specification 1.1.4 currently permits surveillance intervals to be extended up to 25 percent of the specified interval. However, the Technical Specification limits the combined time interval for any three consecutive surveillances to less than 3.25 times the specified interval. The proposed change would delete the 3.25 extension limitation. The surveillance interval will still be constrained by the 25 percent interval extension criterion of T/S 1.1.4.

A copy of our related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "A.S. Masciantonio".

Armando Masciantonio, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 105 to
License No. DPR-6
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. William L. Beckman
Big Rock Point Nuclear Plant

Big Rock Point Plant

cc:

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Mr. Thomas C. Bordine
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Jane E. Brannon, County Clerk
County Building
Charlevoix, Michigan 49720

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
P. O. Box 30035
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
Big Rock Point Plant
10253 U.S. 31 North
Charlevoix, Michigan 49720