



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CONSUMERS POWER COMPANY

BIG ROCK POINT PLANT

DOCKET NO. 50-155

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 105
License No. DPR-6

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consumers Power Company (the licensee) dated August 15, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. DPR-6 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 105, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



L. B. Marsh, Director
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 2, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 105

FACILITY OPERATING LICENSE NO. DPR-6

DOCKET NO. 50-155

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1-1

INSERT

1-1

1.0 INTRODUCTION

1.1 SCOPE

1.1.1 These technical specifications set forth the principal design features and operating limits and requirements which have an effect on the safety of operation of the Big Rock Point Nuclear plant (the plant).

"1.1.2 Sections 1 through 7 present the plant operating limits (including original fuel) through the period of the full-term license. In the order of presentation, Section 1.0 concerns the introduction, Section 2.0 concerns the site, Sections 3.0 through 6.0 cover the plant and its systems, and Section 7.0 presents procedures for plant start-up and procedures for normal and emergency operation of the plant. This section also includes administrative and procedural safeguards to the extent that these have a potential effect on nuclear safety. Section 8.0 describes Phase II of the Research and Development Program, including parametric variations and operating limits on R&D fuel during Phase II. Section 9.0 presents the primary system surveillance requirements."

1.1.3 The dimensions given in these specifications of the plant design features are subject to normal manufacturing tolerances. The operating limits and requirements which are significant from the standpoint of nuclear safety are specified with each of the plant's systems.

1.1.4 "Surveillance requirements shall be applicable as specified for individual components or systems as stated in individual specification requirements. Each surveillance requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval."