



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 4, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

NOV 5 11:56
USNRC REGION II
ATLANTA, GEORGIA

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416 //
License No. NPF-13
File 0260/L-835.0
Only One of Two Required ECCS
Systems Operable Due to
Inability to Complete
Required Surveillance
Procedure
Reference: LER 82-092/03 L-0
AECM-82/527

With the plant in Cold Shutdown, the LPCS System was declared inoperable when Surveillance Procedure 06-OP-1E21-M-0001 could not be completed on schedule. This resulted in only one of the two required ECCS Systems being operable. This event is being reported per T.S.3.5.2 and T.S.6.9.1.13.b. Attached is LER 82-092/03 L-0.

Yours truly,

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8211090358 821104
PDR ADOCK 05000416
S PDR

per Middle South Utilities System

OFFICIAL COPY
I.E. 22