

OFFSITE DOSE CALCULATION MANUAL
FOR
TEXAS UTILITIES GENERATING COMPANY
COMANCHE PEAK NUCLEAR STATION

OCTOBER 1982

8211090475 821028
PDR ADOCK 05000445
A PDR

TABLE OF CONTENTS

	<u>Page</u>
List of Tables	iii
List of Figures	iv
References	v
Introduction	vi
1.0 Liquid Effluents	1-1
1.1 Liquid Radwaste Monitor Setpoint	1-1
1.2 Turbine Building Sump Effluent Monitor	1-5
1.3 Dose Calculations for Liquid Effluents	1-8
1.4 Service Water Effluent	1-12
2.0 Gaseous Effluents	2-1
2.1 Gaseous Effluent Monitor Setpoints	2-1
2.1.1 Plant Vent Stack Noble Gas Monitors XRE 5570A and XRE5570B	2-1
2.1.2 Plant Vent Stack Iodine Monitors	2-4
2.2 Gaseous Effluent Dose Calculations	2-6
2.2.1 Unrestricted Area Boundary Dose Rates	2-6
2.2.1.a Dose Rates Due to Noble Gases	2-6
2.2.1.b Dose Rates Due to Radioiodine, Tritium, and Particulates	2-6
2.2.2 Unrestricted Area Air Dose and Dose to Individuals	2-7
2.2.2.a Air Dose in Unrestricted Areas	2-7
2.2.2.b Dose to An Individual	2-8
2.2.2.c Dose Calculations to Support Other Technical Specification	2-9
2.3 Meteorological Model	2-25
2.4 Definition of Gaseous Effluent Parameters	2-31

TABLE OF CONTENTS

	<u>Page</u>
3.0 Radiological Environmental Monitoring	3-1
APPENDIX	
A. Pathway Dose Factor (P_1) Determination	A-1
B. Inhalation Pathway Factor (R_1) Determination	B-1
C. Ground Plane Pathway Factor (R_1) Determination	C-1
D. Grass, Cow-Milk Pathway Factor (R_1) Determination	D-1
E. Vegetation Pathway Factor (R_1) Determination	E-1
F. Computer Program (ODCM-1)	F-1

List of Tables

<u>Table No.</u>	<u>Title</u>	<u>Page</u>
1.1	Site Related Ingestion Dose Commitment Factor (A_i)	1-10
2.1	Dose Factors for Exposure to a Semi- Infinite Cloud of Noble Gases	2-5
2.2	Pathway Dose Factors for Section 2.2.1.b (P_i) (For Dose Calculations Required by TS 3.11.2.1)	2-10
2.3	Pathway Dose Factors for Section 2.2.2.b (R_i) (For Dose Calculations Required by TS 3.11.2.3) <u>Infant</u>	2-19
2.4	Pathway Dose Factors for Section 2.2.2.b (R_i) (For Dose Calculations Required by TS 3.11.2.3) <u>Child</u>	2-16
2.5	Pathway Dose Factors for Section 2.2.2.b (R_i) (For Dose Calculations Required by TS 3.11.2.3) <u>Teenager</u>	2-18
2.6	Pathway Dose Factors for Section 2.2.2.b (R_i) (For Dose Calculations Required by TS 3.11.2.3) <u>Adult</u>	2-20
2.7	Atmospheric Dispersion Parameters for Technical Specifications 4.11.2.4.1	2-23
2.8	Controlling Receptor Locations, and Pathways (For Dose Calculations Required by TS 3.11.2.3, 3.11.2.4 and 6.9.1.13)	2-24
3.1	Environmental Sampling Locations	3-2

List of Figures

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1.1	Liquid Effluent Discharge Pathways	1-13
1.2	Example Calibration Curve for Liquid Effluent Monitors	1-14
1.3	Circulating Water Pump Curves	1-15
1.4	Simplified Liquid Waste Processing System	1-16
2.1	Simplified Gaseous Waste Processing System	2-22
2.2	Plume Depletion Effect for Ground Level Releases	2-27
2.3	Vertical Standard Deviation of Material in Plume	2-28
2.4	Relative Deposition for Ground-Level Releases	2-29
2.5	Open Terrain Recirculation Factor	2-30
3.1	Environmental Sampling Locations	3-6

REFERENCES

1. Boegli, T. S., R. R. Bellamy, W. L. Britz, and R. L. Waterfield, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants," NUREG-0133 (October 1978).
2. Calculation of Annual Doses to Man from Routine Release of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR50, Appendix I, U. S. NRC Regulatory Guide 1.109 (March 1976).
3. Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR50, Appendix I, U. S. NRC Regulatory Guide 1.109, Rev. 1 (October 1977).
4. "Environmental Report," Texas Utilities Generating Company, Comanche Peak Steam Electric Station.
5. "Final Safety Analysis Report," Texas Utilities Generating Company, Comanche Peak Steam Electric Station.
6. Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light - Water - Cooled Reactors, U. S. NRC Regulatory Guide 1.111 (March 1976).
7. Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Release from Light - Water - Cooled Reactors, U. S. NRC Regulatory Guide 1.111, Rev. 1 (July 1977).

INTRODUCTION

The OFFSITE DOSE CALCULATION Manual is a supporting document of the RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATIONS. As such the ODCM describes the methodology and parameters to be used in the calculation of offsite doses due to radioactive liquid and gaseous effluents and in the calculation of liquid and gaseous effluent monitoring instrumentation alarm/trip setpoints. The ODCM contains a list and graphical description of the specific sample locations for the radiological environmental monitoring program. Minimum OPERABLE configurations of the liquid and gaseous radwaste treatment systems are shown in Figures 1.4 and 2.1.

The ODCM will be maintained at the plant for use as a reference guide and training document of accepted methodologies and calculations. Changes in the calculational methods or parameters will be incorporated into the ODCM in order to assure that the ODCM represents the present methodology in all applicable areas. Computer software to perform the described calculations will be maintained current with this ODCM.

SECTION 1.0

LIQUID EFFLUENTS

The Comanche Peak Steam Electric Station, Units 1 and 2, is located on the Squaw Creek Reservoir which is a point of supply and discharge for the plant circulating water. Liquid releases are made via the Circulating Water Discharge Canal. Discharge pathways for the liquid radwaste sources are shown in the diagram of Figure 1.1. Although no significant releases of radioactivity are expected from the General Service Water System, this effluent pathway is monitored as a precautionary measure.

1.1 GENERAL METHODOLOGY FOR DETERMINING LIQUID EFFLUENT MONITOR SETPOINTS

Normal liquid releases from the radwaste system will originate from the laundry holdup tanks and waste monitor tanks and terminate in Squaw Creek Reservoir. To ensure such discharges do not exceed the limits of 10CFR20, Appendix B, Table II, Column 2 at the release point to the unrestricted area, an in-line radiation detector monitors discharges to the circulating water discharge canal.

X-RV-5253 is the isolation valve controlled by detector X-RE-5253.

The isolation valve shuts automatically if the detector alarms or is placed out of service. The methodology for determining the setpoint for detector X-RE-5253 is as follows:

- 1.1.1 Determine the isotopic concentration of the waste tank to be released.

$$\sum_i C_i = \sum_g C_g + (C_a + C_s + C_t + C_{Fe})$$

$$\sum_i C_i = \text{batch radioactive concentration } (\mu\text{Ci/ml})$$

$$\sum_g C_g = \text{concentration of each measured gamma emitter } (\mu\text{Ci/ml})$$

$$C_a = \text{concentration of alpha emitters as measured in the monthly composite sample. (Sample analyzed for$$

gross alpha only) ($\mu\text{Ci/ml}$)

C_s = concentration of Sr-89 and Sr-90 as measured in the quarterly composite sample ($\mu\text{Ci/ml}$)

C_t = concentration of H-3 as measured in the monthly composite sample ($\mu\text{Ci/ml}$)

C_{Fe} = concentration of Fe-55 as measured in the quarterly composite sample ($\mu\text{Ci/ml}$)

1.1.2 Determine the Maximum Effluent Flow Rate (f)

The effluent discharge rate is determined from the number of pumps running and their capacity. The radwaste system is comprised of the following pumps:

Laundry Holdup and Monitor Tank Pump - 100 gpm

Waste Monitor Tank Pump #1 - 100 gpm

Waste Monitor Tank Pump #2 - 100 gpm

Normally, only one waste tank will be pumped at a time. If, however, more than one tank is to be pumped, the tanks will be sampled and the maximum isotopic concentrations will be used to determine ΣC_i . As a worst case condition, the effluent flow rate (f) will be determined as total pumping capacity of the Laundry Holdup and Waste Monitor Pumps (300 gpm). To ensure that under no circumstances the effluent flow rate is under estimated, a safety factor of 1.5 will be applied (300×1.5) to yield $f = 450$ gpm. This maximum effluent flow rate of 450 gpm will be used in the calculation of dilution factor for all liquid radwaste system batch discharges.

1.1.3 Dilution of Liquid Effluents Due to Circulating Water Flow (F)

Since liquid effluent from the radwaste treatment system is mixed with circulating water prior to being returned to Squaw

Creek Reservoir, the setpoint for detector X-RE-5253 is a function of the circulating water flow rate. The total circulating water flow rate per plant is 1.1 million gpm. This is determined from the Ingersoll-Rand pump curves (Fig. 1.3) which indicate a flow rate per pump of 275,000 gpm. At least two operating pumps are required for a discharge to take place. Isolation valve, X-RV-5253, will shut automatically if less than two circulating pumps are in operation.

$$F(\text{diluting flow}) = (275,000 \text{ gpm/pump}) \times (\# \text{ of pumps}) \times SF \times AF$$

Where: SF = Safety Factor of (.9). This compensates for flow fluctuations from the rate predicted by the circulating water pump curves (Fig. 1.3).

AF = Allocation Factor of (.5). This compensates for simultaneous turbine building sump discharges with batch radwaste discharges to the environment. Turbine building sumps would only be contaminated upon a significant primary to secondary leak.

1.1.4 Determine the Actual Dilution Factor (ADF)

ADF is the ratio of the effluent flow rate plus the circulating water flow rate divided by the effluent flow rate.

$$ADF = (f + F)/f$$

Where: $f = 450 \text{ gpm}$

$$F = (275,000 \text{ gpm/pump}) \times (\# \text{ of pumps}) \times SF (.9) \times AF (.5)$$

1.1.5 Determine the Required Dilution Factor (RDF)

The required dilution factor ensures that the isotopic concentrations expressed in 10CFR20, Appendix B, Table II, Column 2 are not exceeded during a discharge.

$$\begin{aligned} RDF &= \left(\sum_i (C_i / MPC_i) \right) \times SF \\ &= \left(\sum_g (C_g / MPC_g) + (C_a / MPC_a + C_s / MPC_s + C_t / MPC_t + C_{Fe} / MPC_{Fe}) \right) \times SF \end{aligned}$$

Where: MPC_i = Maximum Permissible Concentrations of Radionuclide i

SF = Safety Factor of 2

NOTE: If RDF is less than 1, the tank effluent meets discharge limits without dilution. Detector, X-RE-5253, would then be set in accordance with Eq. 1 below with RFD set equal to 1.

1.1.6 Determining the Counts/Minute (Upper Setpoint Limit) for Detector X-RE-5253

$$\text{Eq. 1} \quad c = (\text{ADF/RDF}) \times \sum C_g$$

Where c = The gamma concentration corrected for dilution in microcuries/ml. From this concentration level, the detector setpoint in counts/minute is determined from the detector calibration curve (Figure 1.2 Example Only).

As a further consideration, the reservoir into which the diluted rad-waste flows may build up a concentration of radioactive isotopes. It is therefore necessary to account for recirculation of previously discharged radionuclides. This is accomplished as follows:

$$\text{Eq. 2} \quad F' = F (1 - \sum_i (C'_i / \text{MPC}_i))$$

F' = Adjusted Circulating Water Flow Rate

C'_i = Radionuclide Concentration of the Reservoir

MPC_i = Maximum Permissible Concentration of Radionuclide i

$F = (275,000 \text{ gpm/pump}) \times (\# \text{ of pumps}) \times \text{SF} \times \text{AF}$

NOTE: If C_i is less LLD then $F' = F$ and no adjusted flow rate need be considered in the calculation of ADF. LLD is the smallest concentration of radioactive material in a sample that will be detected with a 95% probability.

1.2 Turbine Building Sump Effluent Line Monitor

The Purpose of the detector for the turbine building sumps is to monitor discharges so as to prevent contamination in excess of the 10CFR20 limits from reaching Squaw Creek Reservoir. Because the only sources to the sump effluent are from the secondary steam system, activity is expected in the turbine building sump effluent only if a significant primary-to-secondary leak is present. If a primary-to-secondary leak does exist, the activity in the sump effluent system would be comprised of only those radionuclides found in the secondary system, but with reduced activity due to decay and dilution.

Until activity is measured in the secondary system, it will not be possible to measure all the radionuclides on which the detector should be set. Therefore, the detector will be set administratively as follows:

$$C = MPC (Co^{60}) \times \text{Actual Dilution Factor (ADF)}$$

C in microcuries/ml is then used to determine the count per minute setpoint from the detector curves.

The Actual Dilution Factor is determined in the following manner:

1.2.1 Determine Maximum Effluent Flow Rate (f)

A maximum sump effluent flow rate is determined by summing the combined outputs of the pumps for the turbine building sumps.

Sump No. 2	#1	300 gpm
	#2	300 gpm
Sump No. 2	#1	50 gpm
	#2	50 gpm

Total pumping capacity = 700 gpm x SF (1.5) = 1050 gpm

SF = Safety Factor of 1.5

1.2.2 Determine Minimum Circulating Water Flow (F)

As a worst case, the administrative monitor setpoint will be based upon two operating circulating water pumps out of four. Due to pump cavitation and pump flow vortexing, two pumps is the minimum conceivable circulating water pump lineup.

$$F = 2 \text{ pumps} \times (275,000 \text{ gpm/pump}) \times \text{SF} (.9) \times \text{AF} (.5) = 247,500 \text{ gpm}$$

(SF = Safety Factor of .9), (AF = Allocation Factor of .5)

1.2.3 Determine the Actual Dilution Factor (ADF)

$$\text{ADF} = \frac{f + F}{f}$$
$$= \frac{1050 + 247,500}{1050} = 236.7$$

The administrative setpoint therefore becomes:

$$c = 236.7 (\text{MPC } \text{Co}^{60}) \quad (\text{Setpoint Upper Limit})$$

If the administrative alarm point is exceeded while discharging to the lake, the discharge will be halted or directed to the evaporation ponds as desired.

After a significant primary-to-secondary leak has been confirmed and the isotopic concentration of the secondary has been determined, the monitor alarm point will be redetermined in the following manner:

1.2.4 Determine the Isotopic Concentration of the Secondary Effluent

$$\sum_i C_i = \sum_g C_g + (C_a + C_s + C_t + C_{Fe})$$

$\sum C_i$ = radioactive concentration of the secondary ($\mu C_i/\text{mi}$)

$\sum C_g$ = concentration of each measured gamma emitter in the effluent

C_a = measured concentration of alpha emitters in the effluent

C_s = measured concentration of Sr89 and SR90 in the effluent

C_t = measured concentration of H-3 in the effluent

C_{Fe} = measured concentration of Fe55 in the effluent

1.2.5 Determine the Required Dilution Factor (RDF)

$$RDF = \sum_i (C_i / MPC_i) \times SF$$

MPC_i = Maximum Permissible Concentration of Radionuclide i

SF = Safety Factor of 2

C_i = effluent isotopic concentrations

1.2.6 Determine the Actual Dilution Factor (ADF)

$$ADF = \frac{f + F}{f}$$

f = 1050 gpm

F = (275,000 gpm/pump) x (# of pumps) x SF x AF

Note: See Eq. 2 if C_i' is greater than LLD_i

C_i' = radionuclide concentration of the lake water

1.2.7 Utilizing the information provided above, the turbine building sump detector will be set as follows:

$$c = (ADF/RDF) \times \sum_g C_g$$

c in microcuries/ml is then referenced to the detector curves to determine the proper count per minute setpoint.

If at any time, the administrative or post accident alarm setting is exceeded, effluent flow will be terminated or directed to the evaporation ponds until such time as the effluent meets State and Federal limits for discharge to Squaw Creek Reservoir.

1.3 Dose Calculation for Liquid Effluents

The dose contribution from the release of liquid effluents will be calculated once per 31 days and a cumulative summation of the total body and organ doses will be maintained for each calendar quarter. The dose contribution for all batch releases for the quarter will be calculated using the following equation:

$$D_{i\tau} = \sum_i [A_{i\tau} \sum_{k=1}^n t_k C_{ik} F_k]$$

Where: D = the cumulative dose commitment to the total body or any organ from all liquid effluent releases in a 31 day period.

t_k = the time duration of the batch release in hours.

C_{ik} = the isotopic concentration (microcuries/ml) of radionuclide (i) found in the pre-release sample.

Concentrations are determined primarily from a gamma isotopic analysis of the liquid effluent sample. For Sr89, Sr90, H3, and Fe55, the last measured value will be used in the dose calculation.

F_k = near field average dilution factor during a liquid effluent release. Defined as the ratio of the average undiluted liquid waste flow during release to the average circulating water flow. For conservatism, the maximum effluent flow rate will be used in the calculation.

$$= \frac{\text{Maximum Effluent Flow Rate}}{\text{Circulating Water Flow Rate}}$$

Max. Eff. Flow Rate = 450 for the Waste Processing System or 1050 for the Turbine Building Sump discharge.

$A_{i\tau}$ = the site related ingestion dose commitment factor to the total body or any organ for each identified principle gamma and beta emitter, mRem/hr per microcurie/ml.

$$A_{i\tau} = k_o (U_w / D_w + U_F BF_i) DF_i$$

Where: k_o = unit conversion factor, 1.14×10^5

U_w = adult water consumption, 730 liters/year

U_F = adult fish consumption, 21 liters/year

BF_i = Bio accumulation factor, Table A-1, Ref. 3

DF_i = Dose Conversion Factor, Table II, Ref. 2

D_w = near field dilution factor, (1) for CPSES

Calculated values for $A_{i\tau}$ for nuclides with a half life greater than eight days are given in Table 1.1.

NOTE: It may be necessary to consider the recirculation of previously discharged radionuclides should they be detected in the water of Squaw Creek Reservoir. If C'_i (lake) is greater than LLD, then $D_{i\tau}$ must be calculated and added to the 31 day $D_{i\tau}$ (effluent) amount.

$$D_{i\tau} \text{ (lake)} = A_{i\tau} \times t \times C'_i$$

Where: $t \approx 744$ hours (31 days)

C'_i = isotopic concentration for radionuclides in the lake.

TABLE 1.1
 SITE RELATED INGESTION DOSE COMMITMENT FACTOR, A1%
 (mREM/HR PER μ CI/ML)

ATOM	BONE	LIVER	T-BODY	THYROID	KIDNEY	LUNG	GI-LLI
H3	0.00E+00	8.96E+00	8.96E+00	8.96E+00	8.96E+00	8.96E+00	8.96E+00
C14	3.15E+04	6.30E+03	6.30E+03	6.30E+03	6.30E+03	6.30E+03	6.30E+03
P32	4.62E+07	2.87E+06	1.79E+06	0.00E+00	0.00E+00	0.00E+00	5.20E+06
CR51	0.00E+00	0.00E+00	1.49E+00	3.94E-01	3.29E-01	1.38E+00	3.76E+02
MN54	0.00E+00	4.76E+03	9.08E+02	0.00E+00	1.42E+03	0.00E+00	1.46E+04
FE55	3.87E+02	6.13E+02	1.43E+02	0.00E+00	0.00E+00	3.42E+02	3.52E+02
FE59	1.40E+03	3.29E+03	1.26E+03	0.00E+00	0.00E+00	9.19E+02	1.10E+04
CO58	0.00E+00	1.51E+02	3.39E+02	0.00E+00	0.00E+00	0.00E+00	3.06E+03
CO60	0.00E+00	4.34E+02	9.58E+02	0.00E+00	0.00E+00	0.00E+00	8.16E+03
NI63	4.19E+04	2.91E+03	1.41E+03	0.00E+00	0.00E+00	0.00E+00	6.07E+02
ZN65	2.36E+04	7.50E+04	3.39E+04	0.00E+00	5.02E+04	0.00E+00	4.73E+04
RB86	0.00E+00	1.03E+05	4.79E+04	0.00E+00	0.00E+00	0.00E+00	2.03E+04
SR89	4.78E+04	0.00E+00	1.37E+03	0.00E+00	0.00E+00	0.00E+00	7.66E+03
SR90	1.18E+06	0.00E+00	2.88E+05	0.00E+00	0.00E+00	0.00E+00	3.40E+04
Y91M	1.30E-02	0.00E+00	5.04E-04	0.00E+00	0.00E+00	0.00E+00	3.82E-02
Y91	2.02E+01	0.00E+00	5.39E-01	0.00E+00	0.00E+00	0.00E+00	1.11E+04
ZR95	2.77E+00	8.88E-01	6.01E-01	0.00E+00	1.39E+00	0.00E+00	2.82E+03
NB95	4.47E+02	2.49E+02	1.34E+02	0.00E+00	2.46E+02	0.00E+00	1.51E+06
TC99M	2.94E-02	8.32E-02	1.06E+00	0.00E+00	1.26E+00	4.07E-02	4.92E+01
RU103	1.98E+01	0.00E+00	8.54E+00	0.00E+00	7.57E+01	0.00E+00	2.31E+03
RU106	2.95E+02	0.00E+00	3.73E+01	0.00E+00	5.69E+02	0.00E+00	1.91E+04
AG110M	1.33E+01	1.23E+01	7.32E+00	0.00E+00	2.42E+01	0.00E+00	5.03E+03
TE125M	2.79E+03	1.01E+03	3.74E+02	8.39E+02	1.13E+04	0.00E+00	1.11E+04

TABLE 1.1(Cont)

SITE RELATED INGESTION DOSE COMMITMENT FACTOR, A₁₂
(mREM/hr per uCi/ml)

ATOM	BONE	LIVER	T-BODY	THYROID	KIDNEY	LUNG	GI-LLI
TE127M	7.05E+03	2.52E+03	8.59E+02	1.80E+03	2.86E+04	0.00E+00	2.36E+04
TE127	1.14E+02	4.11E+01	2.48E+01	8.48E+01	4.66E+02	0.00E+00	9.03E+03
TE129M	1.20E+04	4.47E+03	1.89E+03	4.11E+03	5.00E+04	0.00E+00	6.03E+04
TE129	3.27E+01	1.23E+01	7.36E+00	2.51E+01	1.37E+02	0.00E+00	2.47E+01
I131	4.96E+02	7.09E+02	4.06E+02	2.32E+05	1.22E+03	0.00E+00	1.87E+02
CS134	3.03E+05	7.21E+05	5.89E+05	0.00E+00	2.33E+05	7.75E+04	1.26E+04
CS136	3.17E+04	1.25E+05	9.01E+04	0.00E+00	6.97E+04	9.55E+03	1.42E+04
CS137	3.88E+05	5.31E+05	3.48E+05	0.00E+00	1.80E+05	5.99E+04	1.03E+04
BA140	1.88E+03	2.37E+00	1.23E+02	0.00E+00	8.05E-01	1.35E+00	3.88E+03
CE144	4.18E+01	1.75E+01	2.24E+00	0.00E+00	1.04E+01	0.00E+00	1.41E+04
PR143	1.32E+00	5.28E-01	6.52E-02	0.00E+00	3.05E-01	0.00E+00	5.77E+03
ND147	9.00E-01	1.04E+00	6.22E-02	0.00E+00	6.08E-01	0.00E+00	4.99E+03
W187	3.04E+02	2.55E+02	8.90E+01	0.00E+00	0.00E+00	0.00E+00	8.34E+04
NP239	1.28E-01	1.25E-02	6.91E-03	0.00E+00	3.91E-02	0.00E+00	2.57E+03

1.4 SERVICE WATER EFFLUENT RADIATION MONITOR RF 4270

Concentration of radioactivity in this effluent line normally is expected to be insignificant. Therefore, the monitor setpoint should be established as close to background as practical to prevent spurious alarms and yet alarm should an inadvertent release occur.

If this effluent stream should become contaminated with radioactivity, radionuclide concentrations must be determined and a radiation monitor setpoint determined as follows:

$$C = (\sum C_g) \div DF \text{ (Setpoint upper limit)}$$


Where $\sum C_g$ = the concentration of each measured gamma emitter observed in the effluent ($\mu\text{Ci/ml}$)

$$DF = \sum_i (C_i / MPC_i)$$

For this release pathway no additional dilution is available. Therefore, releases are permissible if DF is greater than 1.

FIGURE 1.1

LIQUID EFFLUENT DISCHARGE PATHWAYS



1-13

FIGURE 1.2

EXAMPLE CALIBRATION CURVE FOR LIQUID EFFLUENT MONITOR




FIGURE 1.3

INGERSOLL-RAND CURVE # NY-3552-4
for Pump 83 APMA-1
DATE 8/25/77

DESIGN CONDITIONS

GPM 275,000 EFF 88
TH (FT) 28 BHP 2209 @ Q 1.0
RPM 250 DRIVER 2500
1.15 SF

CIRCULATING WATER PUMP CURVES

1-15





FIGURE 1.4

LIQUID WASTE PROCESSING SYSTEM



91-1

SECTION 2.0

GASEOUS EFFLUENTS

2.1 GASEOUS EFFLUENT MONITOR SETPOINTS

The gaseous monitor setpoint values determined in the following sections will be regarded as upper bounds for the actual setpoint adjustments. That is, setpoint adjustments are not required to be made if the existing setpoint level corresponds to a lower count rate than the calculated value. Setpoints may be established at values lower than the calculated values if desired.

If a calculated setpoint is less than the monitor reading associated with the particular release pathway, no release may be made. Under such circumstances, contributing source terms may be reduced and the setpoint recalculated.

At CPSES, all gaseous effluents are released to the atmosphere through the two Plant Vent Stacks (Figure 2.1). Setpoint methodology for the noble gas monitors associated with the plant vent is addressed in the following section.

2.1.1 PLANT VENT STACK NOBLE GAS MONITORS XRE5570A and XRE5570B

For implementation of Technical Specification 3.3.3.11, the alarm setpoint level for these noble gas monitors will be calculated as follows:

C_S = Monitor reading of the noble gas monitor at the alarm setpoint concentration.

$(SF) \times R_t \times D_{TB} \times AF$
= the lesser of or

$(SF) \times R_s \times D_{SS} \times AF$

- SF = Safety Factor (.5); a conservative factor applied to each noble gas monitor to compensate for statistical fluctuations and errors of measurement.
- AF = Allocation Factor (.5); a factor allowing for releases from both plant stacks simultaneously.
- R_t = monitor reader per mrem/yr to the total body

$$= C \div (\overline{X/Q}) \sum_i K_i Q_i$$
- K_i = total body dose factor due to gamma emissions from noble gas radionuclide i (mrem/year per microcurie/m³) from Table 2.1.
- R_s = monitor reading per mrem/yr to the skin

$$= C \div (\overline{X/Q}) \sum_i (L_i + 1.1 M_i) Q_i$$
- L_i = skin dose factor due to beta emissions from noble gas radionuclide i (mrem/yr per microcurie/m³) from Table 2.1.
- 1.1 = mrem skin dose per mrad air dose
- M_i = air dose factor due to gamma emissions from noble gas radionuclide i (mrad/yr per microcurie/m³) from Table 2.1)
- Q_i = the release rate of noble gas radionuclide i from the Plant Vent Stack (microcurie/sec).
 = the product of X_{iv} and F_v , where X_{iv} is the concentration of noble gas radionuclide i (microcurie/ml) as measure at the vent and F_v is the flowrate at the vent (ml/sec).
- C = monitor reading of a noble gas monitor corresponding to the grab sample radionuclide concentrations taken in accordance with RETS Table 4.11-2. The count rate corresponding to the measured concentration is determined from the monitor calibration curve supplied by the instrument manufacturer or based on historical data for a particular monitor.

$\overline{X/Q}$ = the highest annual average relative concentration at the site boundary. (If desired, the annual average relative concentration at the site boundary for the particular release point may be used).
 = 3.3×10^{-6} sec/m³ in the NNW sector.

D_{TB} = dose rate limit to the total body of an individual in an unrestricted area.

= 500 mrem/year (Technical Specification 3.11.2.1a).

D_{SS} = Dose rate limit to the skin of the body of an individual in an unrestricted area.

= 3000 mrem/year (Technical Specification 3.11.2.1.a).

With the addition of a batch release (waste gas decay tank or containment purge) into the effluent stream, the Q_i term will be calculated in a similar manner as previously shown. The flow rate at the vent monitor is given by

$$F_v = F_c + F_B$$

where

F_c = the flow rate contribution of the plant ventilation system (ml/sec).

F_B = the flow rate contribution associated with the release rate of the batch source (ml/sec). This value will be very small as compared to the value of F_c .

The resulting concentration due to the combined sources that would be detected by the Plant Vent Stack Monitor is given by:

$$X_{iv} = \frac{X_{ic} F_c + X_{iB} F_B}{F_c + F_B}$$

where:

X_{ic} = the concentration of noble gas radionuclide i (microcurie/ml) in the continuous release stream as sampled in accordance with RETS Table 4.11-2.

X_{iB} = the concentration of noble gas radionuclide i (microcurie/ml) in the continuous release stream as sampled in accordance with RETS Table 4.11-2.

The count rate corresponding to this combined concentration (X_{iv}) at the vent monitor is determined by the monitor calibration curve as previously described. The release rate at the vent for noble gas radionuclide i (microcurie/sec) is given by

$$\begin{aligned} Q_i &= F_v X_{iv} \\ &= X_{ic} F_c + X_{iB} F_B \end{aligned}$$

2.1.2 PLANT VENT STACK IODINE MONITORS

In general it is not practical to establish a setpoint for the Plant Vent Stack Radioiodine Monitors to ensure compliance with Technical Specification 3.11.2.1b. Therefore, dose rate calculations should be performed in accordance with Section 2.2.1 and compared with the Technical Specification dose rate limit of 1500 mrem/year for compliance. An Allocation Factor and Safety Factor should also be utilized for this determination.

TABLE 2-1

DOSE FACTORS FOR EXPOSURE TO A SEMI-INFINITE CLOUD OF NOBLE GASES,*

<u>Nuclide</u>	<u>γ-Body*** (K)</u>	<u>β-Skin***(L)</u>	<u>γ-Air**(M)</u>	<u>β-Air**(N)</u>
Kr-85m	1.17E+03****	1.46E+03	1.23E+03	1.97E+03
Kr-85	1.61E+01	1.34E+03	1.72E+01	1.95E+03
Kr-87	5.92E+03	9.73E+03	6.17E+03	1.03E+04
Kr-88	1.47E+04	2.37E+03	1.52E+04	2.93E+03
Kr-89	1.66E+04	1.01E+04	1.73E+04	1.06E+04
Kr-90	1.56E+04	7.29E+03	1.63E+04	7.83E+03
Xe-131m	9.15E+01	4.76E+02	1.56E+02	1.11E+03
Xe-133m	2.51E+02	9.94E+02	3.27E+02	1.48E+03
Xe-133	2.94E+02	3.06E+02	3.53E+02	1.05E+03
Xe-135m	3.12E+03	7.11E+02	3.36E+03	7.39E+02
Xe-135	1.81E+03	1.86E+03	1.92E+03	2.46E+03
Xe-137	1.42E+03	1.22E+04	1.51E+03	1.27E+04
Xe-138	8.83E+03	4.13E+03	9.21E+03	4.75E+03
Ar-41	8.84E+03	2.69E+03	9.30E+03	3.28E+03

*Values taken from Reference 3, Table B-1

** $\frac{\text{mrad-m}^3}{\mu\text{Ci-yr}}$

*** $\frac{\text{mrem-m}^3}{\mu\text{Ci-yr}}$

**** $1.17\text{E}+03 = 1.17 \times 10^3$

2.2 GASEOUS EFFLUENT DOSE CALCULATIONS

2.2.1 Unrestricted Area Boundary Dose Rates

2.2.1.a Dose Rates Due to Noble Gases

For implementation of Technical Specifications 3.11.2.1.a, the dose rate at the unrestricted area boundary due to noble gases shall be calculated as follows:

D_t = average total body dose rate in the current year (mrem/yr)

$$= (\bar{X}/Q) \sum_i K_i Q_i$$

D_s = average skin dose rate in the current year (mrem/yr)

$$= (\bar{X}/Q) \sum_i (L_i + 1.1 M_i) (Q_i)$$

2.2.1.b Dose Rates Due to Radioiodines, Tritium and Particulates

Organ doses due to radioiodines, tritium, and all radioactive materials in particulate form with half-lives greater than eight days, will be calculated to implement the requirements of Technical Specification 3.11.2.1.b as follows:

D_o = average organ dose rate in the current year (mrem/yr)

$$= (\bar{X}/Q) \sum_i P_i Q_i$$

where: P_i = dose parameter factor for radionuclide i ;
(mrem/yr per microcurie/m³), for inhalation.
(Table 2.2)

Q_i = the release rate of radionuclide i for (radioiodine, tritium, and particulates) as determined from the concentrations measured in the analysis of the appropriate sample required by Technical Specification 3.11.2.1.b.

2.2.2 Unrestricted Area (Air Dose/Dose to Individual)

2.2.2.a Air Dose in Unrestricted Areas

For implementation of Technical Specification 3.11.2.2 and 3.11.2.4, the air dose in unrestricted areas shall be determined as follows:

D_γ = air dose due to gamma emissions from noble gas radionuclide i (mrad)

$$= 3.17 \times 10^{-8} \sum_i M_i (\overline{X/Q}) \tilde{Q}_i$$

where: 3.17×10^{-8} = the fraction of a year represented by one second

M_i is defined in section 2.1.1

$\overline{X/Q}$ = the relative concentration for the location occupied by the maximum exposed individual
= 3.3×10^{-6} sec/m³ in the NNW Sector

\tilde{Q}_i = the cumulative release of noble gas radionuclide i (microcuries) for the type of release under consideration

D_β = air dose due to beta emissions from noble gas radionuclide i (mrad)

$$= 3.17 \times 10^{-8} \sum_i N_i (\overline{X/Q}) \tilde{Q}_i$$

where: N_i = the air dose factor due to beta emissions from noble gas radionuclide i (mrad/yr per microcurie/m³) Table 2.i

2.2.2.b Dose to an Individual

Dose to an individual from radioiodine, tritium, and radioactive materials in particulate form will be calculated to implement Technical Specification 3.11.2.3. and 3.11.2.4 as follows:

$$D_p = \text{dose to an individual from radioiodine, tritium, and radionuclides in particulate form (mrem)}$$
$$= 3.17 \times 10^{-8} \sum_i R_i W' \tilde{Q}_i$$

where: W' = relative dispersion parameter
= for inhalation of all tritium pathways
= $2.8 \times 10^{-9} M^{-2}$ in the WNW Sector

R_i = dose factor for radionuclide i (Table 2.3 - 2.6)

\tilde{Q}_i = cumulative release of radionuclide i as required by Technical Specification 3.11.2.3 in (microcuries)

2.2.2.c DOSE CALCULATIONS TO SUPPORT OTHER TECHNICAL SPECIFICATIONS

For the purpose of implementing Technical Specification 6.9.1.13 dose calculations will be performed using the above equations with the substitution of average meteorological parameters for the period of the report, and the appropriate pathway receptor dose factors (R_1). Values for R_1 may be found in Tables 2.3 through 2.6.

For the purpose of implementing Technical Specification 6.9.1.9, dose calculations may be performed using the above equations with the substitution of the dispersion parameters (X/Q, D/Q) which are concurrent with actual releases, and the appropriate pathway receptor dose factors.

For the purpose of implementing Technical Specification 3.12.2, dose calculations may be performed using the above equations substituting the appropriate pathway receptor dose factors and the appropriate dispersion parameters for the location(s) of interest. Annual average dispersion parameters (or grazing period average for D/Q may be used for these calculations).

TABLE 2.2

PATHWAY DOSE FACTORS FOR SECTION 2.2.1.b (P₁)*
 (For Dose Calculation Required by TS 3.11.2.1)

Page 1 of 4

AGE GROUP	(CHILD)
: ISOTOPE :	INHALATION :
: H-3 :	1.125E+03 :
: C-14 :	3.589E+04 :
: NA-24 :	1.610E+04 :
: P-32 :	2.605E+06 :
: CR-51 :	1.698E+04 :
: MN-54 :	1.576E+06 :
: MN-56 :	1.232E+05 :
: FE-55 :	1.110E+05 :
: FE-59 :	1.269E+06 :
: CO-58 :	1.106E+06 :
: CO-60 :	7.067E+06 :
: NI-63 :	8.214E+05 :
: NI-65 :	8.399E+04 :
: CU-64 :	3.670E+04 :
: ZN-65 :	9.953E+05 :
: ZN-69 :	1.018E+04 :
: BR-83 :	4.736E+02 :
: BR-84 :	5.476E+02 :

* Values based on Reference 1, Section 5.2.1 assumptions unless otherwise indicated in Reference 5.

1 - mrem/yr per $\mu\text{Ci}/\text{m}^3$

TABLE 2.2 (Continued)
 PATHWAY DOSE FACTORS FOR SECTION 2.2.1.b (P_i)

Page 2 of 4

AGE GROUP	(CHILD)
: ISOTOPE :	INHALATION :
: BR-85 :	2.531E+01 :
: RB-86 :	1.983E+05 :
: RB-88 :	5.624E+02 :
: RB-89 :	3.452E+02 :
: SR-89 :	2.157E+06 :
: SR-90 :	1.010E+08 :
: SR-91 :	1.739E+05 :
: SR-92 :	2.424E+05 :
: Y-90 :	2.679E+05 :
: Y-91M :	2.812E+03 :
: Y-91 :	2.627E+06 :
: Y-92 :	2.390E+05 :
: Y-93 :	3.885E+05 :
: ZR-95 :	2.231E+06 :
: ZR-97 :	3.511E+05 :
: NB-95 :	6.142E+05 :
: MO-99 :	1.354E+05 :
: TC-99M :	4.810E+03 :
: TC-101 :	5.846E+02 :
: RU-103 :	6.623E+05 :
: RU-105 :	9.953E+04 :

1 - mrem/yr per $\mu\text{Ci}/\text{m}^3$

TABLE 2.2 (Continued)
 PATHWAY DOSE FACTORS FOR SECTION 2.2.1.b (P_i)
 Page 3 of 4

AGE GROUP	(CHILD)
:ISOTOPE :	INHALATION :
:RU-106 :	1.432E+87 :
:AG-110M :	5.476E+06 :
:TE-125M :	4.773E+05 :
:TE-127M :	1.480E+06 :
:TE-127 :	5.624E+84 :
:TE-129M :	1.761E+06 :
:TE-129 :	2.549E+04 :
:TE-131M :	3.078E+05 :
:TE-131 :	2.054E+03 :
:TE-132 :	3.774E+05 :
:I-138 :	1.046E+06 :
:I-131 :	1.624E+07 :
:I-132 :	1.935E+05 :
:I-133 :	3.848E+86 :
:I-134 :	5.069E+04 :
:I-135 :	7.918E+05 :
:CS-134 :	1.014E+06 :
:CS-136 :	1.709E+05 :
:CS-137 :	9.065E+05 :
:CS-138 :	8.399E+02 :
:BA-139 :	5.772E+04 :

1 - mrem/yr per $\mu\text{Ci}/\text{m}^3$

TABLE 2.2 (Continued)
 PATHWAY DOSE FACTORS FOR SECTION 2.2.1.b (P_i)
 Page 4 of 4

AGE GROUP	(CHILD)
: ISOTOPE :	INHALATION :
: BA-148 :	1.743E+06 :
: BA-141 :	2.919E+03 :
: BA-142 :	1.643E+03 :
: LA-140 :	2.257E+05 :
: LA-142 :	7.585E+04 :
: CE-141 :	5.439E+05 :
: CE-143 :	1.273E+05 :
: CE-144 :	1.195E+07 :
: PR-143 :	4.329E+05 :
: PR-144 :	1.565E+03 :
: ND-147 :	3.282E+05 :
: W-187 :	9.102E+04 :
: NP-239 :	6.401E+04 :

1 - mrem/yr per $\mu\text{Ci}/\text{m}^3$

TABLE 2.3
 PATHWAY DOSE FACTOR (R)
 INFANT

ATOM	INHAL	G/F	CON/MILK	CON/MEAT	VEG	BT/MILK
H3	6.468E+02	0.000E+00	2.382E+03	0.000E+00	0.000E+00	4.860E+03
C14	2.646E-04	0.000E+00	1.579E+09	0.000E+00	0.000E+00	1.579E+09
P32	2.030E+06	0.000E+00	8.053E+10	0.000E+00	0.000E+00	9.663E+10
CR51	1.284E+04	5.517E+06	2.429E+06	0.000E+00	0.000E+00	2.927E+05
MN54	9.996E+05	1.629E+09	2.522E+07	0.000E+00	0.000E+00	3.027E+06
FE55	9.594E+04	0.000E+00	8.975E+07	0.000E+00	0.000E+00	1.167E+06
FE59	1.015E+06	3.238E+08	2.137E+08	0.000E+00	0.000E+00	2.778E+06
CO58	7.770E+05	4.490E+08	3.475E+07	0.000E+00	0.000E+00	4.170E+06
CO60	4.508E+06	2.528E+10	1.404E+08	0.000E+00	0.000E+00	1.685E+07
NI63	3.388E+05	0.000E+00	2.357E+10	0.000E+00	0.000E+00	2.828E+09
ZN65	6.538E+05	8.574E+08	1.210E+10	0.000E+00	0.000E+00	1.452E+09
RB86	1.904E+05	1.029E+07	1.128E+10	0.000E+00	0.000E+00	1.353E+09
SR89	2.030E+06	2.523E+04	6.945E+09	0.000E+00	0.000E+00	1.459E+10
SR90	4.088E+07	0.000E+00	8.195E+10	0.000E+00	0.000E+00	1.721E+11
Y91	2.450E+06	1.217E+06	2.950E+06	0.000E+00	0.000E+00	3.540E+05
ZR95	1.750E+06	2.915E+08	4.713E+05	0.000E+00	0.000E+00	5.656E+04
NB95	4.788E+05	1.614E+08	1.094E+08	0.000E+00	0.000E+00	1.313E+07
TC99M	2.030E+03	2.101E+05	8.037E+03	0.000E+00	0.000E+00	9.644E+02
RU103	5.516E+05	1.226E+08	5.682E+04	0.000E+00	0.000E+00	6.819E+03
RU106	1.156E+07	5.063E+08	9.359E+05	0.000E+00	0.000E+00	1.123E+05
AG110M	3.668E+06	4.062E+09	9.306E+09	0.000E+00	0.000E+00	1.117E+09
TE125M	4.466E+05	2.133E+06	9.408E+07	0.000E+00	0.000E+00	1.009E+07
TE127M	1.312E+06	1.083E+05	6.206E+08	0.000E+00	0.000E+00	7.447E+07

TABLE 2.3 (cont)
 PATHWAY DOSE FACTOR (R)
 INFANT

ATOM	INHAL	G/P	CGW/MILK	CGW/MEAT	VEG	GT/MILK
TE129M	1.680E+06	2.348E+07	7.396E+08	0.000E+00	0.000E+00	8.876E+07
I131	1.484E+07	2.095E+07	5.278E+11	0.000E+00	0.000E+00	6.334E+11
CS134	7.028E+05	7.972E+09	4.495E+10	0.000E+00	0.000E+00	1.349E+11
CS136	1.345E+05	1.690E+08	2.892E+09	0.000E+00	0.000E+00	8.677E+09
CS137	6.118E+05	1.203E+10	4.060E+10	0.000E+00	0.000E+00	1.218E+11
BA140	1.596E+06	2.351E+07	1.210E+08	0.000E+00	0.000E+00	1.452E+07
CE141	5.166E+05	1.539E+07	7.181E+06	0.000E+00	0.000E+00	8.617E+05
CE144	9.842E+06	8.046E+07	8.547E+07	0.000E+00	0.000E+00	1.026E+07
PR143	4.326E+05	0.000E+00	3.935E+05	0.000E+00	0.000E+00	4.722E+04
ND147	3.220E+05	1.015E+07	2.887E+05	0.000E+00	0.000E+00	3.464E+04
NP239	5.950E+04	1.978E+06	4.708E+04	0.000E+00	0.000E+00	5.649E+03

TABLE 2.4
PATHWAY DOSE FACTOR (R)
CHILD

ATOM	INHAL	G/P	COU/MILK	COU/MEAT	VEG	GT/MILK
H3	1.125E+03	0.000E+00	1.570E+03	2.341E+02	4.008E+03	3.203E+03
C14	3.589E+04	0.000E+00	3.064E+08	2.588E+08	3.894E+08	3.064E+08
P32	2.605E+06	0.000E+00	3.908E+10	3.730E+09	3.375E+09	4.690E+10
CR51	1.702E+04	5.517E+06	2.801E+06	2.421E+05	6.232E+06	3.361E+05
MN54	1.576E+06	1.629E+09	1.349E+07	5.155E+06	6.651E+08	1.019E+06
FE55	1.110E+05	0.000E+00	7.426E+07	3.037E+08	3.012E+08	9.553E+05
FE59	1.269E+06	3.238E+08	1.104E+08	3.466E+08	6.766E+08	1.436E+06
CO58	1.110E+06	4.490E+08	4.063E+07	5.512E+07	3.786E+08	4.875E+06
CO60	7.067E+06	2.528E+10	1.601E+08	2.569E+08	2.095E+09	1.921E+07
NI63	8.214E+05	0.000E+00	2.000E+10	1.965E+10	3.949E+10	2.400E+09
ZN65	9.953E+05	8.574E+08	6.998E+09	6.355E+08	2.164E+09	8.398E+08
R886	1.983E+05	1.029E+07	4.445E+09	2.926E+08	4.539E+08	5.334E+08
SR89	2.157E+06	2.523E+04	3.653E+09	2.061E+08	3.611E+10	7.670E+09
SR90	1.010E+08	0.000E+00	7.530E+10	7.008E+09	1.243E+12	1.581E+11
Y91	2.627E+06	1.217E+06	2.921E+06	1.351E+06	2.501E+09	3.505E+05
ZR95	2.231E+06	2.915E+08	5.015E+05	3.504E+08	9.025E+08	6.018E+04
NB95	6.142E+05	1.614E+08	1.214E+08	1.184E+09	2.969E+08	1.457E+07
TC99M	4.310E+03	2.101E+05	7.198E+03	2.816E-18	5.185E+03	3.637E+02
RU103	6.623E+05	1.226E+08	5.966E+04	2.168E+09	4.031E+08	7.160E+03
RU106	1.432E+07	5.063E+08	9.308E+05	4.471E+10	1.160E+10	1.117E+05
AG110M	5.476E+06	4.062E+09	1.069E+10	4.298E+08	2.587E+09	1.283E+09
TE125M	4.773E+05	2.133E+06	4.132E+07	3.188E+08	3.512E+08	4.958E+06
TE127M	1.480E+06	1.083E+05	3.551E+08	3.030E+09	3.769E+09	4.262E+07

TABLE 2.4 (cont)

PATHWAY DOSE FACTOR (R)

CHILD

ATOM	INHAL	G/P	COW/MILK	COW/MEAT	VEG	GT/MILK
TE129M	1.761E+06	2.348E+07	4.231E+08	2.807E+09	2.521E+09	5.077E+07
I131	1.624E+07	2.095E+07	2.172E+11	2.771E+09	4.770E+10	2.606E+11
CS134	1.014E+06	7.972E+09	2.456E+10	1.000E+09	2.631E+10	7.367E+10
CS136	1.709E+05	1.690E+08	1.384E+09	2.193E+07	2.216E+08	4.152E+09
CS137	9.065E+05	1.203E+10	2.173E+10	8.989E+08	2.392E+10	6.519E+10
BA140	1.743E+06	2.351E+07	5.380E+07	2.205E+07	2.777E+08	7.056E+06
CE141	5.439E+05	1.539E+07	7.152E+06	7.258E+06	4.078E+08	8.582E+05
CE144	1.195E+07	8.046E+07	8.497E+07	1.212E+08	1.039E+10	1.020E+07
PR143	4.329E+05	0.000E+00	3.889E+05	1.810E+07	1.574E+08	4.667E+04
ND147	3.282E+05	1.015E+07	2.871E+05	7.614E+06	9.287E+07	3.445E+04
NP239	6.401E+04	1.978E+06	4.577E+04	1.125E+03	1.358E+07	5.492E+03

TABLE 2.5
 PATHWAY DOSE FACTOR (R)
 TEENAGER

ATOM	INHAL	G/P	COU/MILK	COU/MEAT	VEG	GT/MILK
H3	1.272E+03	0.000E+00	9.938E+02	1.938E+02	2.588E+03	2.027E+03
C14	2.600E+04	0.000E+00	3.312E+08	1.390E+08	3.726E+08	3.312E+08
P32	1.888E+06	0.000E+00	1.585E+10	1.978E+09	1.611E+09	1.902E+10
CR51	2.096E+04	5.517E+06	4.352E+06	4.919E+05	1.040E+07	5.222E+05
MN54	1.984E+06	1.629E+09	1.850E+07	9.243E+06	9.324E+08	2.220E+06
FE55	1.240E+05	0.000E+00	2.959E+07	1.582E+08	3.259E+08	3.846E+05
FE59	1.528E+06	3.238E+08	1.560E+08	6.405E+08	1.000E+09	2.028E+06
CO58	1.344E+06	4.490E+08	6.285E+07	1.115E+08	6.057E+08	7.542E+06
CO60	8.800E+06	2.528E+10	2.424E+08	5.087E+08	3.237E+09	2.909E+07
VI53	5.800E+05	0.000E+00	7.975E+09	1.025E+10	1.606E+10	9.570E+08
ZN65	1.240E+06	8.574E+08	4.648E+09	5.520E+08	1.471E+09	5.578E+08
RB86	1.304E+05	1.029E+07	2.396E+09	2.063E+08	2.747E+08	2.876E+08
SR89	2.416E+06	2.523E+04	1.476E+09	1.406E+08	1.521E+10	3.099E+09
SR90	1.080E+08	0.000E+00	4.456E+10	5.425E+09	7.507E+11	9.358E+10
Y91	2.936E+06	1.217E+06	3.637E+06	2.200E+06	3.233E+09	4.365E+05
ZR95	2.688E+06	2.915E+08	6.856E+05	6.265E+08	1.278E+09	8.227E+04
NB95	7.512E+05	1.614E+08	1.771E+08	2.260E+09	4.581E+08	2.125E+07
TC99M	6.128E+03	2.101E+05	5.150E+03	2.636E-18	4.344E+03	6.180E+02
RU103	7.832E+05	1.226E+08	8.150E+04	3.874E+09	5.788E+08	9.780E+03
RU106	1.608E+07	5.063E+08	1.165E+06	7.322E+10	1.484E+10	1.399E+05
AG110M	6.752E+06	4.062E+09	1.631E+10	8.576E+08	4.039E+09	1.957E+09
TE125M	5.360E+05	2.133E+06	4.964E+07	5.010E+08	4.363E+08	5.957E+06
TE127M	1.656E+06	1.083E+05	2.048E+08	2.285E+09	2.236E+09	2.457E+07

TABLE 2.5 (cont)
 PATHWAY DOSE FACTOR (R)
 TEENAGER

ATOM	INHAL	G/P	COW/MILK	COW/MEAT	VEG	GT/MILK
TE129M	1.976E+06	2.348E+07	2.446E+08	2.123E+09	1.544E+09	2.935E+07
II31	1.464E+07	2.095E+07	1.100E+11	1.835E+09	3.149E+10	1.320E+11
CS134	1.128E+06	7.972E+09	1.527E+10	8.134E+08	1.670E+10	4.581E+10
CS136	1.936E+05	1.690E+08	8.778E+08	1.319E+07	1.688E+08	2.633E+09
CS137	8.480E+05	1.203E+10	1.200E+10	6.493E+08	1.348E+10	3.600E+10
BA140	2.032E+06	2.351E+07	3.756E+07	1.843E+07	2.137E+08	4.508E+06
CE141	6.136E+05	1.539E+07	8.914E+06	1.183E+07	5.399E+08	1.070E+06
CE144	1.336E+07	8.046E+07	1.060E+08	1.979E+08	1.326E+10	1.272E+07
PR143	4.832E+05	0.000E+00	4.792E+05	2.917E+07	2.308E+08	5.751E+04
ND147	3.720E+05	1.015E+07	3.577E+05	1.241E+07	1.436E+08	4.293E+04
NP239	1.320E+05	1.978E+06	5.309E+04	1.706E+03	2.100E+07	6.371E+03

TABLE 2-6
 PATHWAY DOSE FACTOR (R)
 ADULT

ATOM	INHAL	G/P	CDW/MILK	CDW/MEAT	VEG	BT/MILK
H3	1.264E+03	0.000E+00	7.629E+02	0.248E-02	2.260E+03	1.556E+03
C14	1.816E+04	0.000E+00	1.778E+08	1.630E+08	2.276E+08	1.778E+08
P32	1.320E+06	0.000E+00	8.588E+09	2.341E+09	1.406E+09	1.031E+10
CR51	1.440E+04	5.517E+06	3.729E+06	9.205E+05	1.171E+07	4.475E+05
MN54	1.400E+06	1.629E+09	1.659E+07	1.810E+07	9.589E+08	1.990E+06
FE55	7.208E+04	0.000E+00	1.568E+07	1.948E+08	2.096E+08	2.169E+05
FE59	1.016E+06	3.238E+08	1.269E+08	1.137E+09	9.969E+08	1.649E+06
CO58	9.280E+05	4.490E+08	5.489E+07	2.127E+08	6.274E+08	6.586E+06
CO60	5.968E+06	2.528E+10	2.063E+08	9.456E+08	3.139E+09	2.476E+07
NI63	4.320E+05	0.000E+00	4.540E+09	1.274E+10	1.040E+10	5.448E+08
ZN65	8.640E+05	8.574E+08	2.774E+09	7.193E+08	1.009E+09	3.329E+08
RB86	1.352E+05	1.029E+07	1.315E+09	2.472E+08	2.201E+08	1.578E+08
SR89	1.400E+06	2.523E+04	8.006E+08	1.666E+08	1.001E+10	1.681E+09
SR90	9.920E+07	0.000E+00	3.154E+10	8.384E+09	6.046E+11	6.624E+10
Y91	1.704E+06	1.217E+06	2.655E+06	3.506E+08	2.831E+09	3.186E+05
IR95	1.768E+06	2.915E+08	5.473E+05	1.092E+09	1.216E+09	6.567E+04
NB95	5.048E+05	1.614E+08	1.478E+08	4.119E+09	4.826E+08	1.774E+07
TC99M	4.160E+03	2.101E+05	2.711E+03	3.030E-18	5.117E+03	3.253E+02
RU103	5.048E+05	1.226E+08	6.406E+04	6.649E+09	5.649E+08	7.687E+03
RU106	9.360E+06	5.063E+08	8.552E+05	1.173E+11	1.248E+10	1.026E+05
AG110M	4.632E+06	4.062E+09	1.401E+10	1.608E+09	3.987E+09	1.681E+09
TE125M	3.136E+05	2.133E+06	3.711E+07	8.179E+08	3.934E+08	4.453E+06
TE127M	9.600E+05	1.083E+05	1.113E+08	2.713E+09	1.418E+09	1.336E+07

TABLE 2.6 (cont)


PATHWAY DOSE FACTOR (R)

ADULT

ATOM	INHAL	G/P	COW/MILK	COW/MEAT	VEG	GT/MILK
TE129M	1.160E+06	2.348E+07	1.609E+08	3.049E+09	1.288E+09	1.931E+07
I131	1.192E+07	2.095E+07	6.956E+10	2.534E+09	3.795E+10	8.347E+10
CS134	8.480E+05	7.972E+09	8.891E+09	1.034E+09	1.110E+10	2.667E+10
CS136	1.464E+05	1.690E+08	5.172E+08	2.341E+07	1.660E+08	1.552E+09
CS137	6.208E+05	1.203E+10	6.804E+09	8.039E+08	8.696E+09	2.041E+10
BA140	1.272E+06	2.351E+07	2.778E+07	2.976E+07	2.652E+08	3.334E+06
CE141	3.616E+05	1.539E+07	6.582E+06	1.908E+07	5.094E+08	7.899E+05
CE144	7.776E+06	8.046E+07	7.747E+07	3.157E+08	1.112E+10	9.297E+06
PR143	2.808E+05	0.000E+00	3.473E+05	4.615E+07	2.747E+08	4.167E+04
ND147	2.208E+05	1.015E+07	2.629E+05	1.991E+07	1.865E+08	3.155E+04
NP239	1.192E+05	1.978E+06	3.698E+04	2.596E+03	2.876E+07	4.438E+03

FIGURE 2.1

GASEOUS WASTE PROCESSING SYSTEM



2-22

Table 2.7

ATMOSPHERIC DISPERSION PARAMETERS*
FOR TECHNICAL SPECIFICATION 4.11.2.4.1

<u>Sector</u>	<u>Miles</u>	<u>X/Q</u>	<u>D/Q</u>
N	4.2	2.7E-07	1.2E-09
NNE	3.9	1.9E-07	7.5E-10
NE	3.4	1.7E-07	5.0E-10
ENE	2.6	2.1E-07	5.5E-10
E	3.4	1.6E-07	2.9E-10
ESE	3.8	1.4E-07	2.7E-10
SE	2.8	3.7E-07	1.2E-09
SSE	2.9	2.8E-07	1.3E-09
S	4.2	1.2E-07	4.6E-10
SSW	4.4	9.0E-08	2.6E-10
SW	1.5	6.4E-07	2.5E-09
WSW	1.7	5.2E-07	1.6E-09
W	1.6	7.8E-07	2.5E-09
WNW	1.9	8.2E-07	2.8E-09
NW	5.0	2.4E-07	5.6E-10
NNW	4.9	2.6E-07	8.0E-10

TABLE 2.8

CONTROLLING RECEPTORS, LOCATIONS, AND PATHWAYS

(For Dose Calculations required by Technical Specifications
3.11.2.3, 3.11.2.4 and 6.9.1.13)

<u>SECTOR</u>	<u>DISTANCE (MILES)</u>	<u>PATHWAY</u>	<u>AGE GROUP</u>
N	4.2	Goat/Milk	Infant
NNE	3.9	Cow/Milk	Infant
NE	3.4	Cow/Milk	Infant
ENE	2.6	Vegetation	Child
E	3.4	Goat/Milk	Infant
ESE	3.8	Cow/Milk	Infant
SE	2.8	Vegetation	Child
SSE	2.9	Cow/Milk	Infant
S	4.2	Goat/Milk	Infant
SSW	4.4	Cow/Milk	Infant
SW	1.5	Cow/Milk	Infant
WSW	1.7	Vegetation	Child
W	1.6	Cow/Milk	Infant
WNW	1.9	Cow/Milk	Infant
NW*	5.0	Cow/Milk	Infant
NNW	4.9	Goat/Milk	Infant

*No pathway currently exists in this sector. Cow/Milk pathway to infant is assumed at distance of 5 miles.

2.3 METEOROLOGICAL MODEL

Atmospheric dispersion for releases are calculated using a straight line flow Gaussian model.

X/Q = average atmospheric dispersion (sec/m^3) for a given wind direction (sector) and distance.

$$= 2.032 \delta K_{j,k}^{\Sigma} \left(\frac{n_{j,k}}{Nr u_{jk} \Sigma_j} \right)$$

2.03 = $(2/\pi)^{1/2}$ divided by the width in radians of a 22.5° sector (0.3927 radians).

$n_{j,k}$ = number of hours meteorological conditions are observed to be in a given wind direction, windspeed class k, and atmospheric stability class j which establishes a joint frequency distribution of grouped meteorological data.

NOTE: If periodic data (hourly) are used instead of the joint frequency data, all variable subscripts are dropped, the $n_{j,k}$ is set equal to 1 and the hourly averaged meteorological variables are entered into the model.

N = total hours of valid meteorological data throughout the period of effluent release.

r = distance from the release point to location of interest (meters)

$u_{j,k}$ = wind speed (midpoint of windspeed class k) measured at the 10 meter level (m/sec) during atmospheric stability class j

Σ_j = building wake corrected vertical standard deviation of the plume concentration.

$$(\sigma_j^2 + b^2/2\pi)^{1/2}$$

= the lesser of or

$$(\sqrt{3} \sigma_j) \quad \text{where:}$$

σ_j = vertical standard deviation of the plume concentration (meters) at distance r for releases (Fig. 2.3)

K = terrain recirculation factor (Fig. 2.5)

δ = plume depletion factor (radioiodines and particulates) at distance r for the applicable stability class. Normally a factor of 1 is assumed when undepleted X/Q values are to be used in dose calculations. (Fig. 2.2)

π = 3.1416

b = vertical height of reactor containment structure (79.4 meters).

ΔT = vertical temperature gradient ($^{\circ}\text{C}/100\text{M}$).

Relative deposition per unit area is calculated.

D/Q = relative deposition per unit area (m^{-2}), for a given wind direction and at a given distance, r

$$= \frac{2.55K}{r} D_g$$

D_g = relative deposition rate for a ground-level release determined from Figure 2.4.

2.55 = (radians per 22.5° Sector) $^{-1}$

FIGURE 2.2

Plume Depletion Effect for Ground-Level Releases (All Atmospheric Stability Classes)




FIGURE 2.3

Vertical Standard Deviation of Material in a Plume (Letters denote Pasquill Stability Class)




FIGURE 2.4

Relative Deposition for Ground-Level Releases (All Atmospheric Stability Classes)





FIGURE 2.5

Open Terrain Recirculation Factor



2.4 DEFINITIONS OF GASEOUS EFFLUENTS PARAMETERS

<u>Term</u>	<u>Definition</u>	<u>Section of Initial Use</u>
B	= administrative allocation factor for gaseous effluent pathways	2.1.1
b	= maximum height of the adjacent building.	2.3.1
C	= monitor reading of a gaseous effluent monitor corresponding to associated sample radionuclide concentrations.	2.1.1
D_o	= average organ dose rate in the current year (mrem/yr)	2.2.1.b
D_p	= dose to an individual from radioiodines and radionuclides in particulate form with half-lives greater than eight days (mrem).	2.2.2.b
D_s	= calculated skin dose rate (mrem/yr)	2.2.1.a
D_{ss}	= limiting dose rate to the skin = 3000 mrem/yr	2.1.1
D_t	= calculated total body dose rate (mrem/yr)	2.2.1.a
D_{TB}	= limiting dose rate to the body = 500 mrem/yr	2.1.1
D_β	= air dose due to beta emissions from noble gas	2.2.2.a
D_γ	= air dose due to gamma emissions from noble gas	2.2.2.a
D/Q	= the sector averaged annual average relative deposition for any distance in a given sector.	

2.4 DEFINITIONS OF GASEOUS EFFLUENTS PARAMETERS (CONTINUED)

<u>Term</u>	<u>Definition</u>	<u>Section of Initial Use</u>
D/Q'	= annual average relative deposition at the location of the maximum exposed individual. = $2.8 \times 10^{-9} \text{ m}^{-2}$ in the WNW sector	2.2.2.b
δ	= plume depletion factor at distance r for the appropriate stability class (radioiodines and particulates).	2.3.1
K_i	= total body dose factor due to gamma emissions from isotope i (mrem/year per microcurie/m ³)	2.1.1
L_i	= skin dose factor due to beta emissions from isotope i (mrem/yr per microcurie/m ³)	2.1.1
M_i	= air dose factor due to gamma emissions from isotope i (mrad/yr per microcurie/m ³)	2.1.1
N_i	= air dose factor due to beta emissions from noble gas radionuclide i (mrad/yr per microcurie/m ³)	2.2.2.a
n_{jk}	= number of hours meteorological conditions are observed to be in a given wind direction, wind-speed class k, and atmospheric stability class j.	2.3.1
N	= total hours of valid meteorological data.	2.3.1
P_i	= dose parameter for radionuclide i, (mrem/yr per microcurie/m ³)	2.2.1.b

2.4 DEFINITIONS OF GASEOUS EFFLUENTS PARAMETERS (CONTINUED)

<u>Term</u>	<u>Definition</u>	<u>Section of Initial Use</u>
Q_i	= rate of release of noble gas radionuclide i (microcurie/sec)	2.1.1
Q_i'	= rate of release of isotope i for radioiodine, tritium, and radionuclides in particulate form. (microcurie/sec)	2.1.3
\bar{Q}_i	= cumulative release of noble gas radionuclide i over the period of interest (microcurie).	2.2.2.a
\bar{Q}_i'	= cumulative release of radionuclide i of iodine or material in particulate form over the period of interest (microcurie).	2.2.2.b
R_i	= dose factor for radionuclide i, (mrem/yr per microcurie/m ³) or (m ² -mrem/yr per microcurie/sec)	2.2.2.b
R_s	= monitor reading per mrem/yr to the skin.	2.1.1
R_t	= monitor reading per mrem/yr to the total body.	2.1.1
r	= distance from the point of release to the location of interest for dispersion calculations (meters).	2.3.1
C_s	= monitor reading of the noble gas monitor at the alarm setpoint for the release pathway under consideration.	2.1.1
Σ_j	= vertical standard deviation of the plume concentration with building wake correction.	2.3.1

2.4 DEFINITIONS OF GASEOUS EFFLUENTS PARAMETERS (CONTINUED)

<u>Term</u>	<u>Definition</u>	<u>Section of Initial Use</u>
σ_j	= vertical standard deviation of the plume concentration (in meters), at distance r for ground level releases under the stability category j indicated by ΔT	2.3.1
ΔT	= vertical temperature gradient ($^{\circ}\text{C}/100\text{m}$).	2.3.1
K	= terrain recirculation factor.	2.3.1
u_{jk}	= wind speed (midpoint of windspeed class k) at ground level (m/sec) during atmospheric stability class j .	2.3.1 2.3.1
W'	= relative dispersion for unrestricted areas at the controlling receptor.	2.2.2.b
X/Q	= the sector-averaged annual average relative concentration at any distance r in a given sector. (sec/m^3)	2.3.1 2.3.1
$\overline{X/Q}$	= the highest annual average relative concentration in any sector, at the site boundary. (sec/m^3) = $3.3 \times 10^{-6} \text{ sec}/\text{m}^3$ in the NNW sector	2.1.1
$\overline{X/Q}'$	= relative concentration for the location occupied by the maximum exposed individual = $8.2 \times 10^{-7} \text{ sec}/\text{m}^3$ in the WNW sector	2.2.2.b

SECTION 3.0

RADIOLOGICAL ENVIRONMENTAL MONITORING

Sampling locations as required in Technical Specification 3/4.12.1 are described in Table 3.1 and shown on the map in Figure 3.1.

NOTE: For the purpose of implementing Technical Specification 3.12.2, sampling locations will be modified as required to reflect the findings of the Land Use Census.

Table 3.1

Environmental Sampling Locations

<u>Sampling Point</u>	<u>Location (Sector - Miles)</u>	<u>Sample Type*</u>
1	E-0.5	A
2	N-2.2	A
3	W-2.0	A
4	NNW-4.6	A
5	E-3.5	A
6	SE-3.85	A
7	SSE-4.5	A
8	N-9.4	A
9	SW-12.3	A
10	N-1.2	R
11	N-4.4	R
12	N-6.5	R
13	N-9.4	R
14	NNE-1.1	R
15	NNE-5.65	R
16	NE-1.7	R
17	NE-4.8	R
18	ENE-2.5	R
19	ENE-5.0	R
20	E-0.5	R

Table 3.1 (Continued)
Environmental Sampling Locations

<u>Sampling Point</u>	<u>Location (Sector - Miles)</u>	<u>Sample Type*</u>
21	E-1.9	R
22	E-3.5	R
23	E-4.2	R
24	ESE-1.4	R
25	ESE-4.7	R
26	SE-1.3	R
27	SE-3.85	R
28	SE-4.6	R
29	SSE-1.3	R
30	SSE-4.4	R
31	SSE-4.5	R
32	S-1.5	R
33	S-4.2	R
34	SSW-1.0	R
35	SSW-4.4	R
36	SW-0.9	R
37	SW-4.8	R
38	SW-12.3	R
39	WSW-1.0	R
40	WSW-5.35	R

Table 3.1 (Continued)
Environmental Sampling Locations

<u>Sampling Point</u>	<u>Location (Sector - Miles)</u>	<u>Sample Type*</u>
41	WSW-7.0	R
42	W-1.0	R
43	W-2.0	R
44	W-5.5	R
45	WNW-1.0	R
46	WNW-5.0	R
47	WNW-6.7	R
48	NW-1.0	R
49	NW-5.7	R
50	NW-9.9	R
51	NNW-1.35	R
52	NNW-4.6	R
53	ESE-0.5	SW
54	ESE-2.2	SW
55	N-9.9	SW
56	E-0.5	GW
57	SSE-4.5	GW
58	NNE-1.0	SS
59	N-9.9	SS
60	**	M

Table 3.1 (Continued)
Environmental Sampling Locations

<u>Sampling Point</u>	<u>Location (Sector - Miles)</u>	<u>Sample Type*</u>
61	**	M
62	**	M
63	SW-13.5	M
64	ENE-2.0	F
65	NNE-8.0	F
66	E-4.2	V
67	SW-13.5	V
68	W-1.8	V
69	SE-1.3	V
70	SSE-1.3	V
71	SW-13.5	V

*Types: A - Air Sample, R - Direct Radiation, SW - Surface Water, GW - Ground Water, SS - Shoreline Sediment, M - Milk, F - Fish; V - Vegetation.

**As determined from yearly milk animal census.




Figure 3.1
 Comanche Peak S.E.S.
 Radiological Environmental Monitoring Program
 Sample Locations Within 10 Miles of the Site

APPENDIX A

Calculation of P_i (Inhalation)

$$P_i = k' (BR) DFA_i$$

where

P_i = the dose parameter for radionuclides other than noble gases for the inhalation pathway, in mrem/yr per microcurie/ m^3 . The dose factors are based on the critical individual organ for the child age group.

k' = conversion factor, 10^6 pCi/microcurie

BR = 3700 m^3 /yr, breathing rate for child, Ref. 3

DFA_i = the maximum organ inhalation dose factor for the child age group

Resolution of the units yields:

$$P_i \text{ (Inhalation)} = 3.7 \times 10^9 DFA_i$$

The latest NRC guidance has deleted the requirement to determine P_i (ground plane) and P_i (food). In addition, the critical age group has been changed from infant to child.

APPENDIX B

Inhalation Pathway Factor, R_1^I (X/Q)

$$R_1^I (X/Q) = k' (BR) (DFA_i) \text{ (mrem/yr per microcurie/m}^3\text{)}$$

where

k' = conversion factor, 10^6 pCi/microcurie

BR = breathing rate, 1400, 3700, 8000, 8000 m^3/yr for infant, child, teenager, and adult respectively

DFA_i = the maximum organ inhalation dose factor for the receptor of given age group for the i th radionuclide, in mrem/pCi. The total body is considered as an organ in the selection of (DFA_i).

APPENDIX C

Ground Plane Pathway Factor, R_i^G (D/Q)

$$R_i^G \text{ (D/Q)} = k' k'' (\text{SF}) \text{DFG}_i \left((1 - e^{-\lambda t}) / \lambda \right)$$

where

k' = conversion factor, 10^6 pCi/microcurie

k'' = conversion factor, 8760 hr/yr

λ = radionuclide decay constant, sec^{-1}

t = the decay time, assuming that decay is the only operating removal mechanism, 4.73×10^8 sec.

DFG_i = the ground plane dose conversion factor for the i th radionuclide (mrem/hr per pCi/m^2).

SF = .7, shielding factor, from Table E15 Reg. Guide 1.109

APPENDIX D

Grass-Cow-Milk Pathway Factor, R_i^C (D/Q)

$$R_i^C (D/Q) = k' (Q_F \times U_{AP}) / (\lambda_i + \lambda_w) \times F_m \times r \times DFL_i \times ((fp \times fs) / Y_p + ((1-fp \times fs) e^{-\lambda_i t_h}) Y_s) e^{-\lambda_i t_f}$$

where

- k' = conversion factor, 10^6 pCi/microcurie
- Q_F = cow consumption rate, 50 kg/day, R.G.1.109
- U_{AP} = receptor's milk consumption rate; 330,330,400,310 for infant, child, teenager, and adult resp. R.G. 1.109
- Y_p = agricultural productivity by unit area of pasture feed grass, $.7 \text{ kg/m}^2$, NUREG 133
- Y_s = agricultural productivity by unit area of stored feed, 2.0 kg/m^2 , NUREG 133
- F_m = stable element transfer coefficient, Table E1 R.G. 1.109
- r = fraction of deposited activity retained on cow's feed grass, .2 for particulates, 1.0 for radioiodine.
- DFL_i = the maximum organ ingestion dose factor for the i th radionuclide for each respective age group tables E-11 to E-14 R. G. 1.109
- λ_i = decay constant
- λ_w = decay constant for weathering, $5.73 \times 10^{-7} \text{ sec}^{-1}$, NUREG 133
- t_f = 1.73×10^5 sec, the transport time from pasture to cow, to milk to receptor, in seconds
- t_h = 7.78×10^6 sec, the transport time from pasture, to harvest, to cow to milk, to receptor
- fp = 1.0, the fraction of the year that the cow is on pasture. Land Census Report 1982

APPENDIX D (CONTINUED)

f_s = .5, the fraction of the cow feed that is stored feed while the cow is on pasture. Land Census 1982

The concentration of tritium in milk is based on the airborne concentration rather than the deposition. Therefore $R_1^C (X/Q)$ becomes:

$$R_1^C (X/Q) = k'k''' FM Q_F U_{AP} DFL_1 (.75 (.5/H))$$

where

k''' = 10^3 grams/kg

H = 8 grams/m³, absolute humidity of the atmosphere

.75 = fraction of total feed grass mass that is water

.5 = ratio of the specific activity of the feed grass water to the atmospheric water. NUREG 133

APPENDIX E

Vegetation Pathway Factor, R_i^V (D/Q)

$$R_i^V (D/Q) = k' \times r / (Yv (\lambda_i + \lambda_w)) \times DFL_i \times U_A^L f_L e^{-\lambda_i t_L} + U_A^S f_g e^{-\lambda_i t_h}$$

where

$$k' = 10^6 \text{ pCi/microcurie}$$

$$U_A^L = \text{the consumption rate of fresh leafy vegetation, } 0, 26, 42, 64 \text{ for infant, child, teen, or adult respectively}$$

$$U_A^S = \text{the consumption rate of stored vegetation, } 0, 520, 630, 520 \text{ for infant, child, teen, or adult respectively}$$

$$f_L = \text{the fraction of the annual intake of fresh leafy vegetation grown locally, } 1.0 \text{ NUREG 133}$$

$$f_g = \text{the fraction of the stored vegetation grown locally } .76 \text{ NUREG 133}$$

$$t_L = \text{the average time between harvest of leafy vegetation and its consumption, } 8.6 \times 10^4 \text{ seconds Table E-15 R.G. 1.109}$$

$$t_h = \text{the average time between harvest of stored vegetation and its consumption, } 5.18 \times 10^6 \text{ seconds Table E-15 R.G.1.109}$$

$$Yv = 2.0 \text{ kg/m}^2 \text{ Table E-15 R.G.1.109}$$

The concentration of tritium in vegetation is based on the airborne concentration rather than the deposition. Therefore, R_i^V is based on (X/Q)

$$R_i^V = k' k''' U_A^L f_L + U_A^S f_g (DFL_i) (.75 (.5/H))$$

$$k''' = 10^3 \text{ grams/kg}$$

$$H = 8 \text{ grams/m}^3$$

$$.75 = \text{the fraction of total feed grass mass that is water}$$

$$.5 = \text{the ratio of the specific activity of the feed grass water to the atmospheric water}$$

Appendix F

478 : THIS PROGRAM COMPUTES (R). PATHWAY DOSE FACTORS FOR ADULTS, TEENAGERS, C
CHILDREN, AND INFANTS
479 : TO USE THE PROGRAM, PRESS RUN AND THEN RESPOND TO THE QUESTIONS ASKED.
480 :
482 : DEFINITION OF TERMS
483 :
490 : DFA=MAX ORGAN INHALATION DOSE FACTOR. TABLE E-6 THROUGH E-10 R.G. 1.
109
500 :
510 : DFG=GROUND PLANE DOSE CONVERSION FACTOR. TABLE E-6 R.G. 1.109
520 :
530 : DFL=MAX ORGAN INGESTION DOSE FACTOR. TABLE E-11 THROUGH E-14. R.G. 1.109
540 :
550 : FM=STABLE ELEMENT TRANSFER COEFFICIENT MILK. TABLE E1 R.G. 1.109
551 :
560 : FF=STABLE ELEMENT TRANSFER COEFFICIENT MEAT. TABLE E1 R.G. 1.109
570 :
580 : K=CONSTANT. 1.0E6. NUREG 133
590 :
600 : BR=BREATHING RATE. 1400, 3700, 8000 8000 FOR INFANT, CHILD, TEEN, ADULT
RESP.
610 :
620 : Kk=CONSTANT, 8760. NUREG 133
630 :
640 : SF=SHIELDING FACTOR, .7. TABLE E15 R.G. 1.109
650 :
660 : LAMDA=NUCLIDE DECAY CONSTANT
670 :
680 : T=DECAY TIME, ASSUMING THAT DECAY IS THE ONLY REMOVAL MECHANISM. 4.73E3.
NUREG 133
690 :
700 : QF=COW'S CONSUMPTION RATE, 50. TABLE E3. R.G. 1.109
710 :
720 : R=FACTION OF DEPOSITED ACTIVITY RETAINED ON COW'S FEED GRASS. 1.0 FOR I
DDINE, .2 FOR
721 : PARTICULATE.
740 :
750 : UAP1=RECEPTOR'S MILK CONSUMPTION RATE. 330, 330, 400, 310 FOR INFANT, CHI
LD, TEENAGER AND
750 : ADULT RESPECTFULLY.
770 :
780 : Yp=AGRICULTURAL PRODUCTIVITY. .7. NUREG 133
790 :
800 : Ys=AGRICULTURAL PRODUCTIVITY (STORED FEED), 2.0. NUREG 133.
910 :
820 : Tf=TRANSPORT TIME FROM PASTURE TO RECEPTOR. 1.73E5, NUREG 133.
830 :
840 : Th=TRANSPORT TIME FROM PASTURE TO HARVEST TO RECEPTOR. 7.78E6. NUREG 133
.
850 :
860 : FP=FACTION OF YEAR COW IS ON PASTURE, 1.0. LAND CENSUS. NOTE. THIS FAC
TOR CAN POTENTIALLY
870 : CHANGE ANNUALLY.
871 :
880 : FS=FACTION OF THE COW FEED THAT IS STORED FEED WHILE THE COW IS ON PAST
URE, .5. LAND CENSUS
890 : FS CAN POTENTIALLY CHANGE ANNUALLY. TO UP-DATE THIS VALUE, SIMPLY CHANGE
THE FS ASSIGNMENT
891 : INSTRUCTION IN THE FIRST PART OF THE PROGRAM.
900 : KKK=CONSTANT 1.0E3. NUREG 133

```

000 |
010 | H=HUMIDITY, 9, NUREG 133
020 |
030 |
040 | LAMDAW=DECAY CONSTANT FOR REMOVAL OF ACTIVITY FROM PLANTS BY WEATHERING,
050 | 5.73E-7, NUREG 133
060 |
070 | UAP2=RECEPTOR'S MEAT CONSUMPTION, 0, 41, 65, 110 FOR INFANT,CHILD,TEENAGE
080 | ER, AND ADULT
090 | RESPECTFULLY, NUREG 133
100 |
110 | UAL=CONSUMPTION RATE OF FRESH LEAFY VEGETABLES 0, 26, 42, 64, FOR INFANT
120 | CHILD, TEENAGER,
130 | AND ADULT RESPECTFULLY, NUREG 133
140 |
150 | UAS=CONSUMPTION RATE OF STORED VEGETABLES 0, 520, 630, 520, NUREG 133
160 | FOR INFANT, CHILD, TEENAGER, AND ADULT,
170 | RESPECTIVELY
180 |
190 | FL=FRACTION FRESH VEGETABLES GROWN LOCALLY
200 |
210 | FG=FRACTION STORED VEGETABLES GROWN LOCALLY
220 |
230 | TL=AVG. TIME BETWEEN HARVEST OF VEGETABLES AND CONSUMPTION, 8.6 E4 SEC.
240 | NUREG 133
250 |
260 | THH=AVERAGE TIME BETWEEN HARVEST OF STORED VEGETABLES AND CONSUMPTION 5.
270 | 8E6 SEC. NUREG 133
280 |
290 |
300 |
310 | K=1.0E+6 ! UNITS CONVERSION FACTOR
320 | Kk=8760 ! UNITS CONVERSION FACTOR
330 | Sf=.7 ! SHIELDING FACTOR
340 | T=4.73E+8 ! DECAY TIME FOR DECAY AS ONLY REMOVAL MECHANISM.
350 | Qf=50 ! COW CONSUMPTION RATE
360 | R=.2 ! FRACTION OF DEPOSITED ACTIVITY RETAINED ON THE COW'S FEED GRASS.
370 | Yp=.7 ! AGRICULTURAL PRODUCTIVITY
380 | Ys=2.0 ! AGRICULTURAL PRODUCTIVITY FOR STORED FEED.
390 | Tf=1.73E+5 !TRANSPORT TIME FROM PASTURE TO RECEPTOR.
400 | Yv=2 !
410 | Tff=1.73E+6
420 | Th=7.78E+6 ! TRANSPORT TIME FROM PASTURE TOHARVEST TO RECEPTOR.
430 | Fp=.67 ! FRACTION OF THE YEAR COW IS ON PASTURE.
440 | Fs=1.0 ! FRACTION OF THE COW'S FEED THAT IS STORED FEED WHILE COW ON PAST
450 | RE.
460 |
470 | Kkx=1.0E+3 ! UNITS CONVERSION FACTOR.
480 | H=8 ! ABSOLUTE HUMIDITY-DEFAULT VALUE
490 | Lamdaw=5.73E-7 !DECAY CONSTANT FOR WEATHERING.
500 | Fl=1 ! FRACTION OF FRESH VEG. GROWN LOCALLY
510 | Fg=.76 ! FRACTION OF STORED VEG. GROWN LOCALLY.
520 | Tl=8.6E+4 ! AVG. TIME BETWEEN HARVEST OF VEG. AND CONSUMPTION.
530 | Thh=5.18E+6 ! AVG. TIME BETWEEN HARVEST OF STORED VEG. AND CONSUMPTION.
540 | ! BY ENTERING THE AGE GROUP OF CONCERN, THE COMPUTER WILL GENERATE A TABLE
550 | OF PATHWAY DOSE
560 | ! FACTORS (R).
570 | INPUT "PLEASE INDICATE INFANT.CHILD.TEENAGER. OR ADULT",Age$
580 | INPUT "PLEASE INDICATE PATHWAY DOSE FACTOR R OR P",As
590 | IF As<>"P" THEN 1394
600 | PRINT USING "28X.26A,/,/,";"PATHWAY DOSE FACTOR (P)";Age$
610 | PRINT " "
620 | IMAGE 6X.7A.5X.22A,/
630 | PRINT USING 1317;"NUCLIDE","INHALATION DOSE FACTOR"

```


Appendix F-2

```

319 IMAGE 6X.6A.9X.D.3DE
321 READ AtomS,Dfa1,Dfa2,Dfa3,Dfa4,Df11,Df12,Df13,Df14,Dfg,Fm,Ff,Lamda
322 P1=K=1400=Dfa4
323 PRINT USING 1319:AtomS,P1
324 PRINT " "
325 IF AtomS<>"TE125M" THEN 1321
327 IF AtomS="NP239" THEN 1391
328 PRINT USING "9.#"
329 PRINT USING "28X.26A./././.";"PATHWAY DOSE FACTOR (P)";Age5
330 PRINT " "
331 IMAGE 6X.7A.5X.22A./
332 PRINT USING 1331;"NUCLIDE","INHALATION DOSE FACTOR"
333 GOTO 1321
352 IF AtomS="NP239" THEN 1391 ! CHECK FOR END OF DATA.
353 READ AtomS,Dfa1,Dfa2,Dfa3,Dfa4,Df11,Df12,Df13,Df14,Dfg,Fm,Ff,Lamda ! THIS
TATEMENT READS THE
354 ! DATA ASSOCIATED WITH THE PATHWAY DOSE FACTOR (R) CALCULATIONS.
355 IF Age5<>"INFANT" THEN 1364 !ASSIGNS AGE GROUP SPECIFIC DATA.
356 Dfa=Dfa4
357 Df1=Df14
358 Br=1400
359 Uap1=330
360 Uap2=0
361 Ual=0
362 Uas=0
363 GOTO 1333
364 IF Age5<>"CHILD" THEN 1373 !ASSIGNS AGE GROUP SPECIFIC DATA.
365 Dfa=Dfa3
366 Df1=Df13
367 Br=3700
368 Uap1=330
369 Uap2=41
370 Ual=26
371 Uas=520
372 GOTO 1333
373 IF Age5<>"TEENAGER" THEN 1382 ! ASSIGNS AGE GROUP SPECIFIC DATA.
374 Dfa=Dfa2
375 Df1=Df12
376 Br=8000
377 Uap1=400
378 Uap2=65
379 Ual=42
380 Uas=630
381 GOTO 1333
382 IF Age5<>"ADULT" THEN 1390 ! ASSIGNS AGE GROUP SPECIFIC DATA.
383 Dfa=Dfa1
384 Df1=Df11
385 Br=8000
386 Uap1=310
387 Uap2=110
388 Ual=63
389 Uas=520
390 GOTO 1333
391 GOTO 2370
392 ! THE FOLLOWING CODE PRINTS THE PAGE TITLE AND THE COLUMN HEADS.
393 !
394 PRINT USING "28X.26A./././.";"PATHWAY DOSE FACTOR (R) ";Age5
395 IMAGE 6X.4A.4X.5A.6X.3A.8X.8A.3X.8A.6X.3A.6X.7A./
396 PRINT USING 1395:"ATOM","INHAL","G/P","COW/MILK","COW/MEAT","VEG","GT/MILK

```

Appendix F-3

```

397 ! THIS READ STATEMENT READS THE NUCLIDE OF CONCERN PLUS THE DFA AND DFL VAL
ES FOR THAT NUCLIDE
398 ! NOTE DFA1 IS THE DFA VALUE FOR AN ADULT. DFA2 IS THE VALUE FOR A TEEN, DF
3 AND DFA4 ARE THE
399 ! VALUES FOR CHILDREN AND INFANTS RESPECTIVELY.
400 READ AtomS,Dfa1,Dfa2,Dfa3,Dfa4,Df11,Df12,Df13,Df14,Dfg,Fm,Ff,Lamda
401 IF AgeS<>"INFANT" THEN 1480
402 Dfa=Dfa4 ! ASSIGN INFANT RELATED VALUES
410 Df1=Df14
420 Br=1400
430 Uap1=330
440 Uap2=0
450 Ual=0
460 Uas=0
461 IF AS="P" THEN 1329
470 GOTO 1740
480 IF AgeS<>"CHILD" THEN 1570
490 Dfa=Dfa3 ! ASSIGN CHILD RELATED VALUES
500 Df1=Df13
510 Br=3700
520 Uap1=330
530 Uap2=41
540 Ual=26
550 Uas=520
551 IF AS="P" THEN 1329
560 GOTO 1740
570 IF AgeS<>"TEENAGER" THEN 1660
580 Dfa=Dfa2 ! ASSIGN TEENAGER RELATED VALUES
590 Df1=Df12
600 Br=8000
610 Uap1=400
620 Uap2=65
630 Ual=42
640 Uas=630
641 IF AS="P" THEN 1329
650 GOTO 1740
660 IF AgeS<>"ADULT" THEN 1740
670 Dfa=Dfa1 ! ASSIGN ADULT RELATED VALUES
680 Df1=Df11
690 Br=8000
700 Uap1=310
710 Uap2=110
720 Ual=64
730 Uas=520
731 IF AS="P" THEN 1329
740 IF AtomS="I131" THEN R=1 !SEE NUREG 133 P.34 FOR EXPLANATION.
750 IF AtomS="I132" THEN R=1
760 IF AtomS="I130" THEN R=1
770 IF AtomS="I133" THEN R=1
780 IF AtomS="I134" THEN R=1
790 IF AtomS="I135" THEN R=1
791 ! THE FOLLOWING CODE CALCULATES FOUR EXPONENTIAL VALUES. A DEFAULT VALUE
792 ! TO AVOID THE ERROR "REAL UNDERFLOW".
793 IF Lamda*Tff<700 THEN 1796
794 Expo7=1.0E-300
795 GOTO 1800
796 Expo7=EXP(-Lamda*Tff)
800 IF Lamda*Th<700 THEN 1830
810 Expo1=1.0E-300

```

```

820 GOTO 1840
830 Expo1=EXP(-Lamda*Th)
840 IF Lamda*Tf<700 THEN 1870
850 Expo2=1.0E-300
860 GOTO 1880
870 Expo2=EXP(-Lamda*Tf)
880 IF Lamda*Tl<700 THEN 1910
890 Expo3=1.0E-300
900 GOTO 1920
910 Expo3=EXP(-Lamda*Tl)
920 IF Lamda*Thh<700 THEN 1950
930 Expo4=1.0E-300
940 GOTO 1960
950 Expo4=EXP(-Lamda*Thh)
951 ! EXPOA IS A FACTOR UTILIZED IN THE CALCULATION OF THE COW/MILK AND COW/ME
IT DOSE PATHWAYS.
960 Expoa=((Fp*Fs)/Yp+((1-Fp*Fs)*Expo1)/Ys)*Expo2
961 ! EXPOB IS USED IN THE CALCULATION OF VEGETABLE DOSE PATHWAY.
970 Expob=Ual*F1*Expo3+Uas*Fg*Expo4
971 Expoc=((Fp*Fs)/Yp+((1-Fp*Fs)*Expo1)/Ys)*Expo7
980 IF AtomS<>"H3" THEN 2030
990 R3=K*Kkk*Fm*Qf*Uap1*Df1*((.75*.5/H)) ! H3 COW/MILK PATHWAY
000 R4=K*Kkk*Ff*Qf*Uap2*Df1*((.75*.5/H)) !H3 COW/MEAT PATHWAY
010 R5=K*Kkk*(Ual*F1+Fg*Uas)*Df1*((.75*.5/H)) !H3 VEGETABLE PATHWAY
020 R6=K*Kkk*.17*Uap1*6*Df1*((.75*.5/H)) !H3 GT/MILK PATHWAY
030 R1=K*Br*Dfa !INHALATION DOSE FACTOR
040 IF Lamda*T<700 THEN 2070
050 Expo5=1.0E-300 !DEFAULT VALUE TO AVOID "REAL UNDERFLOW"
060 GOTO 2080
070 Expo5=EXP(-Lamda*T)
080 R2=K*Kk*Sf*Dfg*((1-Expo5)/Lamda) !GROUND PLANE DOSE FACTOR
090 IF AtomS="H3" THEN 2340 !H3 VALUES WERE CALCULATED ABOVE
100 R3=K*(Qf*Uap1)/(Lamda+Lamdaw)*Fm*R*Df1*Expoa!COW/MILK PATHWAY
110 R4=K*(Qf*Uap2)/(Lamda+Lamdaw)*Ff*R*Df1*Expoc!COW/MEAT PATHWAY
111 !
120 R5=K*R/(Yv*(Lamda+Lamdaw))*Df1*Expob
121 !THE FOLLOWING CODE ITEMS ASSIGN FM VALUES FOR THE GOAT/MILK CALCULATION.
130 IF AtomS="H3" THEN Fm=.17
140 IF AtomS="C14" THEN Fm=.1
150 IF AtomS="P32" THEN Fm=.25
160 IF AtomS="FE55" THEN Fm=1.3E-4
170 IF AtomS="FE59" THEN Fm=1.3E-4
180 IF AtomS="CU64" THEN Fm=.013
190 IF AtomS="SR89" THEN Fm=.014
200 IF AtomS="SR90" THEN Fm=.014
210 IF AtomS="I130" THEN Fm=.06
220 IF AtomS="I131" THEN Fm=.06
230 IF AtomS="I132" THEN Fm=.06
240 IF AtomS="I133" THEN Fm=.06
250 IF AtomS="I134" THEN Fm=.06
260 IF AtomS="I135" THEN Fm=.06
270 IF AtomS="CS134" THEN Fm=.3
280 IF AtomS="CS136" THEN Fm=.3
290 IF AtomS="CS137" THEN Fm=.3
300 IF AtomS="CS138" THEN Fm=.3
310 Qf=6
311 ! R6 CALCULATES THE GOAT/MILK PATHWAY.
320 R6=K*(Qf*Uap1)/(Lamda+Lamdaw)*Fm*R*Df1*Expoa
330 Qf=50
331 R=.2 !REASSIGN FOR NON-IODINE

```

Appendix F-5

```
340 IMAGE 6X.6A.2X.D.3DE.2X.D.3DE.2X.D.3DE.2X.D.3DE.3X.D.3DE.2X.D.3DE./
350 PRINT USING 2340:AtomS.R1.R2.R3.R4.R5.R6
351 IF AtomS<>"TE127M" THEN 236!
355 PRINT USING "@,@"
356 PRINT USING "28X.26A././.";"PATHWAY DOSE FACTOR (R)".AgeS
357 IMAGE 6X.4A.4X.5A.6X.3A.8X.8A.3X.8A.6X.3A.6X.7A./
358 PRINT USING 2357:"ATOM"."INHAL"."G/P"."COW/MILK"."COW/MEAT"."VEG"."GT/MIL
..
361 IF AtomS<>"NP239" THEN 1400
370 END
```