

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I | L | Z | I | S | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | L | 0 | 5 | 0 | 0 | 0 | 3 | 0 | 4 | 1 | 0 | 0 | 2 | 8 | 2 | 1 | 1 | 0 | 1 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | With Unit Two at Cold Shutdown, pressurizer level channel 2L-461 failed
0 3 | to zero and would not respond with the other redundant channels. This
0 4 | channel deviation is non-conservative for pressurizer high level
0 5 | Reactor trip. Redundant level channels 2L-459 & 460 were operable. The
0 6 | health and the safety of the public were not affected. Previous LER's
0 7 | 50-304/82-19, 50-304/81-07, 50-295/80-36.

0 8 | _____
7 8 9 80

0 9 | I | A | E | I | N | S | T | R | U | T | Z |
7 8 9 10 11 12 13 14 15 16 17 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
17 | LER/RO REPORT NUMBER | 8 | 2 | 0 | 2 | 6 | 0 | 3 | L | 0
21 22 23 24 25 26 27 28 29 30 31 32
EVENT YEAR SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E | C | Z | Z | 0 | 0 | 0 | 0 | N | Y | N | B | 0 | 8 | 0 |
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause was transmitter drift on 2 LT-461 (Barton #386) and a leaking
1 1 | Kerotest isolation valve. The valve was repaired and the transmitter
1 2 | recalibrated. All three Barton transmitters on each unit will be
1 3 | changed (Per I.E. Bulletin 79-01B).

1 4 | _____
7 8 9 80

1 5 | G | 0 | 0 | 0 | NA | A | Operator Observation
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | NA | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 | 0 | 0 | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
ISSUE DESCRIPTION PUBLICITY

8211090514 821101
PDR ADDCK 05000304
S PDR

NRC USE ONLY

NAME OF PREPARER P. F. Cantwell

PHONE: 312-746-2084 ext.320