Process Technology North Jersey White

Subsidiary of RTI Inc.

108 LAKE DENMARK ROAD, ROCKAWAY, NJ 07866 (201) 625-8400 • FAX: (201) 625-7820

May 4, 1989

Ref: Mail Control #106655 Docket #030-07022 License #29-13613-02

Mr. Malcolm R. Knapp, Director Division of Radiation Safety & Safeguards United States Nuclear Regulatory Commission, Region I 475 Allendale Road King of Prussia, PA 19406

Dear Mr. Knapp:

Maze Door Computer Entry

At the Enforcement Conference Meeting held on April 26, 1989, we were asked, "if the maze gate was opened without using the irradiator key while the source is in the shielded position would this initiate a computer print-out. Our response was, "yes it

To validate our answer we attempted to open the maze gate without using the key. We were not able to open it. We then performed the following test:

With the source in the shielded position and maze gate closed, without using the irradiator key, we pushed on the upper portion of the gate. Because of the sensitivity of the micro switch, pushing on the door will activate the alarm. This can be monitored by observing the red LED in series with the micro switch circuitry. With the alarm activated the gate remained closed and the computer did not print out a message.

We did not validate our response. Please note this.

Maze Door Keys

The following is a clarification of the keys available for the

- The irradiator key operates:
 - 1.1 An electric latch that locks the door shut,
 - 1.2 the 90 second start-up time delay switch, and

9101100325 900717 PDR FDIA JONES90-333 PDF

RECEIPE - TOTALL

'89 MAY -8 P4:43

Brain by by the first

PAGE 2 OF 4 PAGE(S)

Mr. Malco

May 2, 1989 Mr. Malcolm R. Knapp, Director NRC

1.3 the "machine key" switch located on the console.

There are two such keys. One, used by the operator, is permanently connected to a chain and a Radiation Survey Meter. The second is under lock and key in the Corporate RSO's office.

2. In the unlikely event that the electric latch, item 1.1 above, fails, the door latch may be opened from the outside of the cell by means of a key for the purpose of repair only. Procedure 12.1 deals with the replacement of the electric latch. There are two such key: available, under lock and key, one with the Plant RSO and the second with the Corporate RSO. Use of this key must be documented.

If we can be of any further assistance please let us know.

Very truly,

John B. Russen Plant Manager &

Radiation Safety Officer

JBR:jk

PAGE 3 OF 4 PAGE(S)

RTI Inc.

108 LAKE DENMARK ROAD
ROCKAWAY, NJ 07866





Mr. Malcolm R. Knapp, Director Division of Radiation Safety and Safeguards Unites States Muclear Regulatory Commission, Region 1 475 Allendate Road King of Prussia, PA 19406